

 Print Close**Date**

Nov 5, 2019 01:26 PM (US/Eastern)

**Subject**

RFI Response #2

**From**

Samantha Pimentel (SPPimentel@cumberlandfarms.com)

**To**

Susan Courter (scourter@recrawford.com)

Hello All,

Please see the follow question and response for Micco, FL

I was looking through the plans and the only detail for Asphalt is for Hwy US1. Also the Details are showing concrete. when the site is Asphalt. Please let me know if there a specific Detail that you want to use for Onsite Asphalt.

Site should be all concrete. The only asphalt is turning lane .

Thanks,

Samantha