


SITE KEYNOTE SCHEDULE	
#	KEYNOTE DESCRIPTION
S1	ROUTE (3/4" SCH 40 PVC CONDUITS FROM COMMUNICATIONS DEMARC LOCATION TO PROPERTY LINE AND CAP. PLACE RED FLAGS ABOVE CAPPED ENDS AND LEAVE CONDUITS WITH PULL STRING FOR CONNECTION BY COMMUNICATIONS SERVICE CO. CONDUITS SHALL BE GALVANIZED RIGID STEEL CONDUIT UNDER THE PARKING & DRIVE AREAS. SEE SPECIFICATIONS. COORDINATE SERVICE CONNECTION POINT WITH SERVICE COMPANY PRIOR TO INSTALLATION OF ANY RACEWAYS.
S2	PAD MOUNTED TRANSFORMER AND METER FURNISHED BY UTILITY CO. COORDINATE EXACT LOCATION AND SERVICE ENTRANCE INSTALLATION REQUIREMENTS WITH UTILITY PRIOR TO BID. ROUTE (1) 1-1/2" EMPTY CONDUIT FROM TRANSFORMER TO THE METER.
S4	MAIN SERVICE GROUND RODS. REFER TO RISER DIAGRAM, MAIN GROUNDING SCHEMATIC AND SECTION 28.05.26.
S6	PROVIDE FIRE ALARM TROUBLE SIGNAL CONNECTION VIA 3/16" IN A 3/4" TAMPERS SWITCHES AT FIRE SPRINKLER POST INDICATOR VALVE AND/OR CHECK VALVE ASSEMBLY. REFER TO PLUMBING DRAWINGS FOR EXACT LOCATION. CONDUIT SHALL BE GALVANIZED RIGID STEEL UNDER PARKING AND DRIVE AREAS AND HERE EXPOSED.
S7	MAIN FIRE ALARM CONTROL PANEL LOCATION. PROVIDE (1) 1/2" CONDUIT FROM LOCATION TO MAIN TELEPHONE BACKBOARD. LEAVE CONDUIT WITH PLUGS AND BUSHED OPENINGS.
S13	EXISTING UTILITY POWER POLE SHALL BE RELOCATED. COORDINATE RELOCATION WITH UTILITY COMPANY.
S14	PROPOSED NEW LOCATION FOR EXISTING UTILITY POWER POLE.

Order Plans @ www.LDILINE.com

ELECTRICAL SITE PLAN  
1" = 20'-0"



SA&E PROJECT NUMBER	01-615-057
BID PACKAGE / PHASING	BP-1
ISSUED FOR CONSTRUCTION	10/15/2019
<b>Southern AE</b> 7951 Tricon Circle Austell, Ga 30168 (770) 819-7777 architects & engineers	REVISIONS
	R # Doc # Date

ADD ALTERNATE #1  
 BOARD OF EDUCATION OFFICE FOR:  
**HEARD COUNTY SCHOOLS**  
 4647 PEA RIDGE ROAD, FRANKLIN, GA 30217  
 HEARD COUNTY SCHOOL SYSTEM  
 FRANKLIN, GEORGIA

ELECTRICAL SITE PLAN



DRAWING NUMBER  
**E004**