



TELECOM. GROUNDING & BONDING ONE-LINE NOTES:

- GROUNDING AND BONDING OF TELECOMMUNICATIONS EQUIPMENT SHALL CONFORM TO ANSI/TIA/EIA 607 AND GROUNDING & BONDING SPECIFICATION SECTION.
- BONDING CONDUCTORS TO ALL TELECOMMUNICATIONS EQUIPMENT, RACKS, CABINETS, ETC. LOCATED WITHIN THIS SPACE.
- BONDING CONDUCTOR TO BUILDING STEEL.
- TELECOM. BONDING CONDUCTOR TO SERVICE ENTRANCE PANEL GROUND BUS.
- TELECOM. BONDING CONDUCTOR TO LOCAL PANELBOARD GROUND BUS.
- ALL CONNECTIONS TO TELECOMMUNICATION GROUNDING BUSBARS SHALL BE MADE WITH LONG BARREL, TWO-HOLE, COMPRESSION LUGS. MECHANICAL LUGS ARE NOT ACCEPTABLE.
- PROVIDE A VINYL LABEL FOR EACH CONDUCTOR NOT ORIGINATING IN THE SAME SPACE INDICATING THE PURPOSE AND LOCATION OF THE OTHER END OF THE CONDUCTOR.

Order Plans @ www.LDILine.com



SA&E PROJECT NUMBER	01-615-057
BID PACKAGE / PHASING	BP-1
ISSUED FOR CONSTRUCTION	10/15/2019
Southern AE 7951 Truon Circle Austell, Ga 30168 (770) 819-7777 architects & engineers	REVISIONS
	R # Doc # Date

ADD ALTERNATE #1
BOARD OF EDUCATION OFFICE FOR:
HEARD COUNTY SCHOOLS
4647 PEA RIDGE ROAD, FRANKLIN, GA 30217
HEARD COUNTY SCHOOL SYSTEM
FRANKLIN, GEORGIA

DETAILS

DRAWING NUMBER
E504