

**LIGHTING FIXTURE SCHEDULE NOTES:**

1. PROVIDE REMOTE TEST SWITCH FOR EMERGENCY BATTERY OPERATION AT LOCATION SHOWN ON DRAWING. SWITCH SHALL CONTROL ALL EMERGENCY BALLAST LOCATED IN THAT SPACE.
2. THIS FIXTURE SHALL BE DIMMING IN CERTAIN LOCATIONS AS SHOWN ON FLOOR PLANS. PROVIDE 0-10V DIMMING DRIVER AND ALL ASSOCIATED 0-10V CABLING IN SPACES BEING CONTROLLED BY WALL MOUNTED DIMMER SWITCHES AND/OR ROOM CONTROLLERS.
3. THIS FIXTURE IS ORDERED BY LENGTH. CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATION OF FIXTURE LENGTH WITH ARCHITECTURAL DETAILS, SECTIONS, MILLWORK, ETC FOR PROPER GUARDS, END CAPS, LAMPS AND ETC FOR A NEAT AND COMPLETE INSTALLATION.
4. THIS FIXTURE IS ORDERED BY LENGTH. CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATION OF FIXTURE LENGTH WITH ELECTRICAL DRAWINGS. PROVIDE ALL REQUIRED COMPONENTS SUCH AS TRANSFORMERS, CIRCUIT BREAKERS, WIRING HARNESS, WIREWAY BASE & COVER, COVER PIECE, ETC FOR A NEAT AND COMPLETE INSTALLATION.
5. WHERE INSTALLED IN GYPSUM BOARD CEILINGS, REMOTE MOUNT DRIVER - REFER TO FLOOR PLAN FOR DRIVER LOCATION. FOR EXTERIOR LOCATIONS, COORDINATE ACCESS PANEL LOCATIONS WITH VENDOR.
6. THIS FIXTURE IS INSTALLED IN A LINEAR ROW. CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATION OF ROW LENGTH WITH DRAWINGS. PROVIDE ALL REQUIRED COMPONENTS SUCH AS INTEGRAL POWER FEED, ADJUSTABLE SUPPORT HANGERS, SECTION JOINERS, AND END CAPS ON EACH ROW FOR A NEAT AND COMPLETE INSTALLATION.
7. FIXTURE COLOR TBD BY ARCHITECT. PROVIDE MANUFACTURER FULL RANGE OF COLORS TO CHOOSE FROM, INCLUDING PREMIUM, CUSTOM AND PLATED FINISHES.
8. PROVIDE ALL TRACK ENDMID FEEDS, COUPLERS, CANOPY COVERS, AND T-BAR MOUNTING CLIPS AS REQUIRED FOR COMPLETE CONTINUOUS TRACK INSTALLATION.

**LIGHTING FIXTURE SCHEDULE**

Type	Lamp (Lumens)	Initial CCT	Voltage	Input Power	Mounting Height	Approved Manufacturers and Catalog Numbers			Type Comments			
						Manufacturer 1	Model 1	Manufacturer 2		Model 2	Manufacturer 3	Model 3
A3	3000	3500 K	120/277	33 VA	RECESSED 2x4 LIGHT FIXTURE	METALLUX	24CZ-LD5-30-UNV-L835-HCD	LITHONIA	2BLT4-30L-ADP-LP835	COLUMBIA	LCAT-24-35-VW-G-ED1	RECESSED 2X4 W/ CENTER CURVED PRISMATIC LENS. DRIVER: 0-10V (1% DIMMING).
A4	4000	3500 K	120/277	33 VA	RECESSED 2x4 LIGHT FIXTURE	METALLUX	24CZ-LD5-40-UNV-L835-HCD	LITHONIA	2BLT4-40L-ADP-LP835	COLUMBIA	LCAT-24-35-LW-G-ED1	RECESSED 2X4 W/ CENTER CURVED PRISMATIC LENS. DRIVER: 0-10V (1% DIMMING).
A5	5000	3500 K	120/277	45 VA	RECESSED 2x4 LIGHT FIXTURE	METALLUX	24CZ-LD5-50-UNV-L835-HCD	LITHONIA	2BLT4-48L-ADP-LP835	COLUMBIA	LCAT-24-35-ML-G-ED1	RECESSED 2X4 W/ CENTER CURVED PRISMATIC LENS. DRIVER: 0-10V (1% DIMMING).
A6	6000	3500 K	120/277	56 VA	RECESSED 2x4 LIGHT FIXTURE	METALLUX	24CZ-LD5-60-UNV-L835-HCD	LITHONIA	2BLT4-60L-ADP-LP835	COLUMBIA	LCAT-24-35-HL-G-ED1	RECESSED 2X4 W/ CENTER CURVED PRISMATIC LENS. DRIVER: 0-10V (1% DIMMING).
BC	825FT	3500 K	120/277	30 VA	ASYMMETRIC WALL WASH FIXTURE, WALL MOUNTED - 9' AFF W/ 12' ARM	VODE LIGHTING	107-BX-01-WA-12-IP-AE-2-0-ZHO-359-A1-0-A1-0	OR APPROVED EQUAL				WALL MOUNTED ASYMMETRIC WALL WASH FIXTURE W/ 12' ARM. DRIVER: 0-10V (1%), INTEGRAL. FINISH: MATTE BLACK. DISTR: 85 DEG ASYMMETRIC. CR: 90%. FIXTURE ORDER BY LENGTH, REFER TO PLANS FOR OVERALL LENGTH.
C4	4500	3500 K	120/277	44 VA	RECESSED 2x4 FLAT PANEL LIGHT FIXTURE	METALLUX	24FP4735C	LITHONIA	EPANL-2x4-5000LM-80CRI-MIN10-2T-M VOLT	COLUMBIA	CFP24-5535	FROSTED ACRYLIC FLAT PANEL. DRIVER: 0-10V (10% DIMMING)
C6	6000	3500 K	120/277	61 VA	RECESSED 2x4 FLAT PANEL LIGHT FIXTURE	METALLUX	24FP6435C	LITHONIA	EPANL-2x4-6000LM-80CRI-MIN10-2T-M VOLT	OR APPROVED EQUAL		FROSTED ACRYLIC FLAT PANEL. DRIVER: 0-10V (10% DIMMING)
CV5	5500	3500 K	120/277	50 VA	RECESSED 2x4 VANDAL RESISTANT LIGHT FIXTURE	NEWSTAR	57L24-D-C-L235-2/C-UN	OR APPROVED EQUAL				VANDAL RESISTANT .375" STATIC LENS. DRIVER: 0-10V (1% DIMMING)
D4	4000	3500 K	120/277	42 VA	RECESSED 2X2 LIGHT FIXTURE	METALLUX	22CZ-LD5-44-UNV-L835-HCD	COLUMBIA	LCAT-22-35-VL-G-ED-U	LITHONIA	2BLT2-40L-ADP-LP835	RECESSED 2X2 W/ CENTER CURVED PRISMATIC LENS. DRIVER: 0-10V (1% DIMMING).
F	5000	4000 K	120/277	42 VA	SURFACE OR SUSPENDED VIA Y-TOGGLE & AIRCRAFT CABLE. HEIGHT: 12'-0" AFF, U.O.N.	METALLUX	4SNLED-LD5-50SL-LW-UNV-L835-CD1	LITHONIA	ZL1D-L48-SMR-5000LM-FST-MVOLT-40-K-80CRI-WH	COLUMBIA	LCL4-40ML-E-U	SURFACE OR SUSPENDED STRIP FIXTURE. COLOR: WHITE. FINISH: ROUND, FROSTED, WIDE DISTRIBUTION.
F4	5000	3500 K	120/277	42 VA	SURFACE OR SUSPENDED VIA Y-TOGGLE & AIRCRAFT CABLE. HEIGHT: 28'-0" AFF, U.O.N.	METALLUX		LITHONIA	CLX-L24-5000LM-MEF-RDL-MOLT-EZ13-5K-80CRI-MB	OR APPROVED EQUAL		SURFACE OR SUSPENDED STRIP FIXTURE. FINISH: MATTE BLACK. LENS: ROUND DIFFUSE ACRYLIC. DRIVER: 0-10V (1% DIMMING)
FBS	7000	3500 K	120/277	42 VA	SURFACE OR SUSPENDED VIA Y-TOGGLE & AIRCRAFT CABLE. HEIGHT: 20'-0" AFF, U.O.N.	METALLUX		LITHONIA	CLX-L48-7000LM-SEF-RDL-MVOLT-EZ13-5K-80CRI-MB	OR APPROVED EQUAL		4 PENDANT LED STRIP FIXTURE W/ ROUND DIFFUSER AND 0-10V DIMMING. FINISH: MATTE BLACK. DRIVER: 0-10V (1% DIMMING)
FE	5000	4000 K	120/277	42 VA	SURFACE OR SUSPENDED VIA Y-TOGGLE & AIRCRAFT CABLE. HEIGHT: 10'-0" AFF, U.O.N.	METALLUX	4SNLED-LD5-50SL-LW-UNV-EL14W-L84-0-CD1	LITHONIA	ZL1D-L48-SMR-5000LM-FST-277-40K-80-CRI-E15W/CLP-WH	COLUMBIA	LCL4-40ML-E-U-ELL14	SURFACE OR SUSPENDED STRIP FIXTURE. COLOR: WHITE. LENS: ROUND, FROSTED, WIDE DISTRIBUTION. PROVIDED W/ EMERGENCY BATTERY PACK. REFER TO SECTION 26 51 00 FOR REQUIREMENTS.
G1	5000	3500 K	120/277	47 VA	SURFACE	METALLUX	4WNLED-LD4-50SL-F-UNV-L835	COLUMBIA	LWC-4-35-ML-E-U	OR APPROVED EQUAL		4" WRAP AROUND LENS.
G3	4000	3500 K	120/277	39 VA	WALL MOUNTED IN STAIRWELL	METALLUX	4SRL-LD5-50SL-LW-UNV-L835-HCD1-S VPD2	LITHONIA	WL4-40L-EZ1-LP835-N100-NESPDT7-DI M10	COLUMBIA	LBIL-4-35-ML-EDU	ILLUMINATED OCC. SENSOR WITH 10% STANDBY MODE.
JC	8000	4000 K	120/277	69 VA	EXTERIOR SURFACE MOUNTED @ 14'-0" AFF, U.O.N.	LITHONIA	CSXW-30C-700-40K-TFTM-277	DECO	D443-LED-80-40-UNV-CU	ACCULITE	LW-B09-4K-UN-FT-CC	
JW	33,000	4000 K	120/277	319 VA	WALL/COLUMN MOUNTED, 20' AFF, U.O.N.	COOPER LIGHTING	ASYX-WM-L6-U-F-L40-1-UNV-TBD-C-ST D	OR APPROVED EQUAL				WALL MOUNTED COLUMN W/ FACTORY SURFACE J-BOX. AIM LIGHT SOURCE UPWARDS (-15 DEG) TOWARD UNDERSIDE OF SOFFIT.
K	8000	4000 K	36VDC	89 VA	WALL MOUNTED 18" AFF	ETC	BLUE DOME	OR APPROVED EQUAL				PROVIDE EYELID ACCESSORY FOR EACH
L3	3250	3500 K	120/277	27 VA	RECESSED 1X4 LIGHT FIXTURE	METALLUX	14CZ-LD5-29-UNV-L835	LITHONIA	BLT4-30L-ADP-LP835	COLUMBIA	LCAT-14-35-VW-G-ED-U	RECESSED 1X4 W/ CENTER CURVED PRISMATIC LENS. DRIVER: 0-10V (1% DIMMING).
L4	4000	3500 K	120/277	46 VA	RECESSED 1X4 LIGHT FIXTURE	METALLUX	14CZ-LD5-39-UNV-L835	LITHONIA	BLT4-40L-ADP-LP835	COLUMBIA	LCAT-14-35-VW-G-ED-U	RECESSED 1X4 W/ CENTER CURVED PRISMATIC LENS. DRIVER: 0-10V (1% DIMMING).
LV5	4500	3500 K	120/277	50 VA	RECESSED 1X4 VANDAL RESISTANT LIGHT FIXTURE	NEWSTAR	57L14-D-C-L235-2/C-UN	OR APPROVED EQUAL				VANDAL RESISTANT .375" STATIC LENS.
M1	24000		277		PENDANT, 33'-6" AFF LEVEL 1. SUSPEND FROM UNISTRUT @ TOP CORD OF TRUSS	LUX DYNAMICS						
M2	48000		277		PENDANT, 33'-6" AFF LEVEL 1. SUSPEND FROM UNISTRUT @ TOP CORD OF TRUSS	LUX DYNAMICS						
N	LED	3200 K	120/277	43 VA	RECESSED LINEAR IN GYPSUM BOARD CEILING	LUMENWERX	VIA1-5R-HLO-LED-80-500-35-8FT-UNV-D1-1-W	OR APPROVED EQUAL				RECESSED LINEAR RGBW WALL WASH FIXTURE. DRIVER: INTEGRAL, DMX CONTROLLED.
P1	1000	3500 K	120/277	10 VA	RECESSED 4" DOWNLIGHT	GOTHAM	ICO-35/10-4AR-65D	OR APPROVED EQUAL				WHERE INSTALLED IN GYPSUM BOARD CEILINGS, REMOTE MOUNT DRIVER. SEMI-SPECULAR ALUMINUM REFLECTOR. 0-10V DIMMING.
P2	2000	3500 K	120/277	23 VA	RECESSED 4" DOWNLIGHT	GOTHAM	ICO-35/20-4AR-55D	MAXILUME	SHLED-20-DM10-37-35K-HH4-450-CL-SCH-W	OR APPROVED EQUAL		WHERE INSTALLED IN GYPSUM BOARD CEILINGS, REMOTE MOUNT DRIVER TO ADJACENT ACCESSIBLE CEILING. REFLECTOR: SEMI-SPECULAR ALUMINUM. DISTR: WIDE (65 DEG).
P3	3000	3500 K	120/277	42 VA	RECESSED 6" DOWNLIGHT	GOTHAM	ICO-35/30-6AR-55-MVOLT	OR APPROVED EQUAL				WHERE INSTALLED IN GYPSUM BOARD CEILINGS, REMOTE MOUNT DRIVER. SEMI-SPECULAR ALUMINUM REFLECTOR. 40 DEGREE BEAM ANGLE. 0-10V DIMMING.
PC4	LED	3500 K	277	58 VA	PENDANT, 48" STEM (BOTTOM: 22'-0" AFF)	OCL	TB5-P1FF-48-MM-WTP-LED2-35K-WF-L ED2-35K-UNV-100-DM1	OR APPROVED EQUAL				5' DIA x 48" HIGH FULLY ILLUMINATED BODY CYLINDER W/ ALUMINUM CAPS & DOWNLIGHT. DRIVER: 0-10V (1% DIMMING).
PC6	LED	3500 K	277	71 VA	PENDANT, 48" STEM (BOTTOM: 20'-0" AFF)	OCL	TB5-P1FF-72-MM-WTP-LED2-35K-WF-L ED2-35K-UNV-100-DM1	OR APPROVED EQUAL				5' DIA x 72" HIGH FULLY ILLUMINATED BODY CYLINDER W/ ALUMINUM CAPS & DOWNLIGHT. DRIVER: 0-10V (1% DIMMING).
PG3	LED	3500 K	277	41 VA	PENDANT, 24" STEM (BOTTOM: 11'-0" AFF LEVEL 2)	OCL	TB5-P1FF-36-MM-WTP-LED2-35K-WF-L ED1-35K-UNV-100-DM1	OR APPROVED EQUAL				5' DIA x 36" HIGH FULLY ILLUMINATED BODY CYLINDER W/ ALUMINUM CAPS & DOWNLIGHT. DRIVER: 0-10V (1% DIMMING).
PG4	LED	3500 K	277	58 VA	PENDANT, 36" STEM (BOTTOM: 25'-0" AFF)	OCL	TB5-P1FF-48-MM-WTP-LED2-35K-WF-L ED2-35K-UNV-100-DM1	OR APPROVED EQUAL				5' DIA x 48" HIGH FULLY ILLUMINATED BODY CYLINDER W/ ALUMINUM CAPS & DOWNLIGHT. DRIVER: 0-10V (1% DIMMING).
PG6	LED	3500 K	277	71 VA	PENDANT, 36" STEM (BOTTOM: 23'-0" AFF)	OCL	TB5-P1FF-72-MM-WTP-LED2-35K-WF-L ED2-35K-UNV-100-DM1	OR APPROVED EQUAL				5' DIA x 72" HIGH FULLY ILLUMINATED BODY CYLINDER W/ ALUMINUM CAPS & DOWNLIGHT. DRIVER: 0-10V (1% DIMMING).
PN	5000	3500 K	120/277	61 VA	PENDANT MOUNT 20' AFF, UNLESS OTHERWISE NOTED	GOTHAM	ICO-CYL-35-6BR-LSS-700-MVOLT-E-Z1-EM-DBL	MAXILUME	SCH6-LED-SM-5000L-DM10-MVOLT-W-E-30K-90-TBD-HH6-6501-SHZ-SHZ	OR APPROVED EQUAL		DRIVER: 0-10V, 1% DIMMING. FINISH: TBD BY ARCH.
PS	1400	3500 K	120/277	20 VA	RECESSED 6" DOWNLIGHT	GOTHAM	ICO-35/10-4AR-55D	OR APPROVED EQUAL				NON-CONDUCTIVE SHOWER LIGHT. WET LOCATION IP65 RATED.
Q1	1000	2700 K	120/277	10 VA	RECESSED 4" DOWNLIGHT	GOTHAM	ICO-35/10-4AR-55D	OR APPROVED EQUAL				DRIVER: 0-10V, 1% DIMMING, DIM TO WARM (3000K-1800K). WHERE INSTALLED IN GYPSUM BOARD CEILINGS, REMOTE MOUNT DRIVER IN AN ACCESSIBLE SPACE. TRIM FINISH: SEMI-SPECULAR. DISTR: 60 DEGREE.
RT	3000 PER HEAD	3500 K	277	84 VA	RECESSED MULTI-HEAD ADJUSTABLE SPOT LIGHT	BETA-CALCO	AR-RA3-R1-N1-B1-D1	OR APPROVED EQUAL				3-HEAD FIXTURE IN COMMON RECESSED BOX. FIXTURE HEAD SHALL SLIDE UP TO 12" FROM THEIR CENTER FOR FIELD ADJUSTMENTS. DISTR: NARROW (21 DEG). DRIVER: 0-10V (1% DIMMING) FINISH: WHITE
SL	480	3500 K	120/277	8 VA	RECESSED STAIR LIGHT. PROVIDE CONCRETE ROUGH-IN BOX AS REQUIRED	BEG LIGHTING	SL-3-65-K35	OR APPROVED EQUAL				DRIVER: 0-10V (1%), INTEGRATE. FINISH: TBD BY ARCH. COORDINATE INSTALLATION W/ CONCRETE VENDOR, PROVIDE CONCRETE ROUGH-IN BOX AS REQUIRED.
SQ3	3000	3500 K	120/277	29 VA	RECESSED ADJUSTABLE SQUARE DOWNLIGHT MOUNTED IN GYPSUM BOARD CEILING	PATHWAY LIGHTING - CONVENTRY	6SQSCALBV3035KE1L-6SQSCAL6SCL	OR APPROVED EQUAL				RECESSED ADJUSTABLE LED DOWNLIGHT. DRIVER: DMX CONTROLLED MULTI-CHANNEL REMOTE MOUNTED DRIVER. TRIM FINISH: MATCH CEILING. REFLECTOR: MATTE DIFFUSE. REFER TO PLANS AND SPECIFICATIONS.
SQ6	6000	3500 K	120/277	65 VA	RECESSED ADJUSTABLE SQUARE DOWNLIGHT MOUNTED IN GYPSUM BOARD CEILING	PATHWAY LIGHTING - CONVENTRY	6SQSCALBV6035KE1L-6SQSCAL6SCL	OR APPROVED EQUAL				RECESSED ADJUSTABLE LED DOWNLIGHT. DRIVER: DMX CONTROLLED MULTI-CHANNEL REMOTE MOUNTED DRIVER. TRIM FINISH: MATCH CEILING. REFLECTOR: MATTE DIFFUSE. REFER TO PLANS AND SPECIFICATIONS.
TQ	7000 DOWN/5000 UP	3500 K	277	80 VA	SUSPENDED, 18" BELOW CEILING TO BOTTOM OF FIXTURE. AIRCRAFT CABLE	BETA-CALCO	983950-WDI48-D35-N35-S3-MS-PR2	OR APPROVED EQUAL				DIRECT/INDIRECT FIXTURE SUSPENDED 18" BELOW CEILING (TO BOTTOM OF FIXTURE) VIA AIR CRAFT CABLE. FINISH: TBD BY ARCH. DRIVER: 0-10V (1%), INTEGRAL. PROVIDE CUSTOM DRIVER OUTPUT TO MATCH LUMENS AS SPECIFIED.
V2S	LED	3500 K	277	17 VA	SURFACE MOUNT LIGHT BENEATH STAIR	LUMENWERX	Via2 Surface	OR APPROVED EQUAL				
VL	1150 LMFT	2700 K	120/277	46 VA	VARIETY LIGHT - SURFACE MOUNT ABOVE MIRROR @ 6'-7" TO CENTER OF FIXTURE	PRIMUS	ALX1-RLR-LED-H-27K-UNV-SM-AEB-S-4	OR APPROVED EQUAL				REFER TO DRESSING ROOM DETAIL. 0-10V DIMMING. FIXTURE COLOR: SATIN.
W	1984	3500 K	277	64 VA	REFLECTOR MOUNTED ASYMMETRIC WALL LIGHT	LUMENPULSE	LOGI-277V-48-RGBW-WW-SAM-CC-DM	OR APPROVED EQUAL				RGBW LINEAR (LENGTH PER DRAWING) SURFACE MOUNT WALL WASH FIXTURE. PROVIDE JOINING BRACKETS AND INTERCONNECT CABLES FOR A COMPLETE SYSTEM. CONTROL: DMX FROM A FINISHED. CUSTOM COLOR, T.B.D. BY ARCH.
X1C	LED	3500 K	120/277	6 VA	EXIT SIGN - CEILING MOUNTED, SINGLE FACE	LITHONIA	LE-S-W-1-R-ELN	MULE LIGHTING	MD-B-1-R-WW	DUAL-LITE	SE-S-R-W-E	COORDINATE MOUNTING WITH ARCHITECTURAL DRAWINGS.
X1W	LED	3500 K	120/277	6 VA	EXIT SIGN - WALL MOUNTED, SINGLE FACE	LITHONIA	LE-S-W-1-R	SURE-LITES	CX6-1-WH-R	DUAL-LITE	SE-S-R-W	COORDINATE MOUNTING WITH ARCHITECTURAL DRAWINGS.
X1WG	LED	3500 K	120/277	6 VA	EXIT SIGN - WALL MOUNTED, SINGLE FACE	LITHONIA	LE-S-1-G	SURE-LITES	CX6-1-G	DUAL-LITE	SE-S-G-BN	WALL MOUNTED LED EXIT SIGN SINGLE FACE. WITH DIE-CAST ALUMINUM HOUSING. STENCIL AND TRIM. HOUSING COLOR: MATTE BLACK W/ BRUSHED ALUMINUM FACE. LED COLOR: GREEN.
X2C	LED	3500 K	120/277	6 VA	EXIT SIGN - CEILING MOUNTED, DOUBLE FACE	LITHONIA	LE-S-W-2-R	MULE LIGHTING	MD-A-2-R-WW	DUAL-LITE	SE-D-R-W	CEILING MOUNTED, COORDINATE MOUNTING REQ. W/ ARCHITECTURAL DRAWINGS.
Y1	LED	3500 K	12VDC	0 VA	aisle light - surface mount w/ carpet edge to surface style	TIVOLI LIGHTING	SATT-CE-AM-12-C-PSU	OR APPROVED EQUAL				
Y2	LED	3500 K	12VDC	1 VA	stage limit light - recessed at stage edge	TIVOLI LIGHTING	STEG-12-017-12	OR APPROVED EQUAL				
Z	3000	4000 K	120/277	21 VA	sign light - mount to concrete base flush in grade	LITHONIA LIGHTING	DSXF1-LED-P1-40K-WFL-MVOLT-THK-VG-DBXD	OR APPROVED EQUAL				

SA&E PROJECT NUMBER: 01-615-056  
 BID PACKAGE: BP-1  
 ISSUED FOR CONSTRUCTION: 10/15/2019

**Southern AE**  
 7951 Truon Circle  
 Austell, Ga 30168  
 (770) 819-7777  
 architects & engineers

REVISIONS  
 R # 1  
 Doc # AD1  
 Date 11.4.2019

FACILITY CODE NUMBER: 674-0110  
**GYMNASIUM/AUDITORIUM FOR:  
 HEARD COUNTY SCHOOLS**  
 545 MAIN STREET, FRANKLIN, GA 30217  
**HEARD COUNTY SCHOOL SYSTEM**  
 FRANKLIN, GEORGIA

DRAWING NUMBER: E002