


#	KEYNOTE DESCRIPTION
L7	PROVIDE CONNECTION FROM POWER PACK AND/OR FIRE ALARM SYSTEM CONTROL MODULE TO FIRE ALARM SYSTEM CONTROL MODULE (SENSORS) DURING AN ALARM EVENT.
L12	ALL LIGHTING CONTROL CABLING INSTALLED IN THIS SPACE SHALL BE INSTALLED IN EMT CONDUIT. PAINT ALL CONDUIT, BOXES AND SUPPORTS TO MATCH STRUCTURE.
L23	DOWNWIRING (PURPOSE) IS SHOWN IN THIS PLAN BUT SHALL BE PROVIDED IN SPACES THAT HAVE MINIMUM



SA&E PROJECT NUMBER	01-615-056
BID PACKAGE	BP-1
ISSUED FOR CONSTRUCTION	10/15/2019
<b>Southern AE</b>	
7951 Traxon Circle Austell, Ga 30168 (770) 519-7777 architects & engineers	
R #	Doc #
1	AD1
Date	11.4.2019

FACILITY CODE NUMBER: 674-0110  
**GYMNASIUM/AUDITORIUM FOR:  
 HEARD COUNTY SCHOOLS**  
 545 MAIN STREET, FRANKLIN, GA 30217  
**HEARD COUNTY SCHOOL SYSTEM**  
 FRANKLIN, GEORGIA

GYMNASIUM - LEVEL 02 - LIGHTING PLAN

		DRAWING NUMBER
		<b>E105</b>

**1 LEVEL 02 - GYMNASIUM - LIGHTING PLAN**  
 1/8" = 1'-0"