


#	KEYNOTE DESCRIPTION
E1	JUNCTION BOXES AND CONDUIT FOR SCOREBOARD, SHOT CLOCK AND/OR LOCKER ROOM CLOCK POWER AND CONTROL. COORDINATE EXACT LOCATION AND HEIGHT WITH OWNER AND EQUIPMENT PROVIDER PRIOR TO ROUGH-IN.
E2	ROUTE THIS CIRCUIT THROUGH ELECTRICALLY OPERATED ELECTRICALLY HELD 4-POLE CONTACTOR LOCATED IN ELEC ROOM 138. LOCATE CONTROL SWITCH BEHIND DOOR IN STORAGE RM 103. PROVIDE ENGRAVED PHENOLIC PLATE ON SWITCH COVER THAT READS "SCOREBOARD POWER". COORDINATE EXACT SWITCH LOCATION WITH OWNER PRIOR TO ROUGH-IN.
E3	THIS RECEPTACLE SHALL BE LOCATED IN FACE OF BLEACHER. PROVIDE 28-9" OF #12 AWG TYPE SO CORD TERMINATED WITH PLUG. PROVIDE HOOK ON UNDERSIDE OF BLEACHER FOR STORING CABLE WHEN NOT IN USE.
E5	PROVIDE 240V/3P/3ØA NON-FUSED DISCONNECT(S) IN NEMA 1 ENCLOSURE. MAKE CONNECTION TO BLEACHER MOTOR(S). PROVIDE NEUTRAL CONDUCTOR. REFER TO VENDOR SHOP DRAWING FOR EXACT LOCATION AND NUMBER OF CONNECTION POINTS PRIOR TO ROUGH-IN.
E11	DUPLEX RECEPTACLE AT THIS LOCATION SHALL BE INSTALLED IN RECESSED DISPLAY WALL BOX AT 8' AFF. U.O.N.
E13	INSTALL AND PROVIDE CONNECTION TO PUSH BUTTON CONTROL DOOR LIMIT SWITCHES, OBSTRUCTION SENSORS AND OTHER ACCESSORIES FURNISHED WITH OVERHEAD DOOR.
E19	PROVIDE CONDUIT AND WIRING FROM FLOOR UNIT TO CONDENSING OUTDOOR UNIT FOR INTERLOCK WIRING AND CONTROL. PROVIDE RECEPTACLE ABOVE CEILING FOR CONDENSATE PUMP, WHERE REQUIRED. REFER TO MINI-SPLIT INDOOR UNIT CONNECTION DETAIL ON DRAWING.
E38	THIS RECEPTACLE SHALL BE SUSPENDED FROM ACoustICAL CEILING TO 42" AFF. REFER TO DROP CEILING DETAIL FOR INSTALLATION REQUIREMENTS.
E40	PROVIDE POWER CONTROL WIRING AND RACEWAY CONNECTION TO EACH AUTOMATED HOIST ASSOCIATED HOIST CONTROL STATION LOCATED AT STAGE LEVEL. COORDINATE REQUIREMENTS WITH VENDOR SHOP DRAWINGS PRIOR TO ROUGH-IN.

Order Plans @ www.LDILLI.com



SA&E PROJECT NUMBER	01-615-056
BID PACKAGE	BP-1
ISSUED FOR CONSTRUCTION	10/15/2019
Southern AE 7951 Tricon Circle Austell, Ga 30168 (770) 519-7777 architects & engineers	REVISIONS R # Doc # Date 1 AD1 11.4.2019
	FACILITY CODE NUMBER: 674-0110 GYMNASIUM/AUDITORIUM FOR: HEARD COUNTY SCHOOLS 545 MAIN STREET, FRANKLIN, GA 30217 HEARD COUNTY SCHOOL SYSTEM FRANKLIN, GEORGIA
GYMNASIUM - LEVEL 02 - POWER PLAN DRAWING NUMBER E106	STATE OF GEORGIA REGISTERED PROFESSIONAL ARCHITECT STATE OF GEORGIA REGISTERED PROFESSIONAL ENGINEER STATE OF GEORGIA REGISTERED PROFESSIONAL ELECTRICAL ENGINEER

1 LEVEL 02 - GYMNASIUM - POWER PLAN
1/8" = 1'-0"