



#	KEYNOTE DESCRIPTION
C4	ALL CABLING WITHIN THIS SPACE SHALL BE INSTALLED IN RACEWAY. PAINT EXPOSED RACEWAY TO MATCH FINISH OF WALL OR CEILING.
C6	AT THIS OPENING, PROVIDE CONDUIT AND BOXES FOR ACCESS CONTROL DOOR ROUGH-IN. PER DETAIL.
C13	JUNCTION BOX INSTALLED @ STRUCTURE FOR SCOREBOARD COMMUNICATIONS.
C14	PROVIDE CONNECTION FROM FIRE ALARM CONTROL MODULE (IF SMOKE RATED) OR FIRE ALARM MONITOR MODULE (IF FIRE RATED ONLY) TO MOTOR OPERATED COILING DOOR CLOSER AND DOOR ALARM SIREN AND BEACON. REFER TO SHOP DRAWINGS FOR COILING DOOR ASSEMBLY. PROVIDE RELAY AS REQUIRED.
C15	PROVIDE AND INSTALL FIRE ALARM CONTROL MODULE TO MUTE SOUND SYSTEM UPON ACTIVATION OF THE FIRE ALARM SYSTEM.
C16	DATA DROP TO BE INSTALLED IN RECESSED DISPLAY WALLBOX.
C20	ALL LOW VOLTAGE CABLING ROUTED THROUGH THIS SPACE SHALL BE INSTALLED IN RACEWAY. RACEWAY SHALL BE PAINTED TO MATCH ROOF AND/OR WALL COLOR.
C36	ROUTE RACEWAY IN GYM AREA AS HIGH AS POSSIBLE. DO NOT ROUTE ALONG BOTTOM CORD OF TRUSS. MAINTAIN NEC CLEARANCE REQUIREMENT FROM ROOFDECK OR INSTALL CABLING IN GALVANIZED RIGID CONDUIT.

Order Plans @

WWW.LDILine.com



SA&E PROJECT NUMBER	01-615-056					
BID PACKAGE	BP-1					
ISSUED FOR CONSTRUCTION	10/15/2019					
Southern AE 7951 Traxon Circle Austell, Ga 30168 (770) 519-7777 architects & engineers	REVISIONS					
	<table border="1"> <thead> <tr> <th>R #</th> <th>Doc #</th> <th>Date</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>AD1</td> <td>11.4.2019</td> </tr> </tbody> </table>	R #	Doc #	Date	1	AD1
R #	Doc #	Date				
1	AD1	11.4.2019				

FACILITY CODE NUMBER: 674-0110
 GYMNASIUM/AUDITORIUM FOR:
HEARD COUNTY SCHOOLS
 545 MAIN STREET, FRANKLIN, GA 30217
HEARD COUNTY SCHOOL SYSTEM
 FRANKLIN, GEORGIA

GYMNASIUM - LEVEL 02 - SPECIAL SYSTEMS PLAN

		DRAWING NUMBER
		E107

1 LEVEL 02 - GYMNASIUM - SPECIAL SYSTEMS PLAN
 1/8" = 1'-0"