



#	KEYNOTE DESCRIPTION
E29	DUPLEX GFCI RECEPTACLE AND/OR DISCONNECT SWITCH INSTALLED ON ROOFTOP STRUT STAND. REFER TO DETAIL FOR INSTALLATION OF ROOFTOP RECEPTACLE AND DISCONNECT SWITCH (TYPICAL)
E45	DISCONNECT SWITCH AND/OR DUPLEX RECEPTACLE INSTALLED ON UNSTRUT FRAME SUPPORTED FROM HVAC EQUIPMENT RAILS/ CURB. REFER TO ROOFTOP MINI-SPLIT DETAIL ON DRAWING E501 AND COORDINATE EXACT REQUIREMENTS WITH HVAC CONTRACTOR.

#	KEYNOTE DESCRIPTION
C2	DUCT SMOKE DETECTOR INSTALLED IN HVAC PACKAGE UNIT. PROVIDE NEW ADDRESSABLE SMOKE DETECTOR, COMPATIBLE WITH FIRE ALARM SYSTEM. (TYPICAL)

Order Plans @ www.LDILine.com



SA&E PROJECT NUMBER	01-615-056
BID PACKAGE	BP-1
ISSUED FOR CONSTRUCTION	10/15/2019
Southern AE 7951 Traxon Circle Austell, Ga 30168 (770) 519-7777 architects & engineers	REVISIONS R # Doc # Date 1 AD1 11.4.2019
	FACILITY CODE NUMBER: 674-0110 GYMNASIUM/AUDITORIUM FOR: HEARD COUNTY SCHOOLS 545 MAIN STREET, FRANKLIN, GA 30217 HEARD COUNTY SCHOOL SYSTEM FRANKLIN, GEORGIA
GYMNASIUM - ROOF - POWER PLAN	
	DRAWING NUMBER
	E109

1 ROOF - GYM - POWER PLAN
1/8" = 1'-0"