


3 LEVEL 02 - MEZZANINE & AUDITORIUM LIGHTING PLAN
1/8" = 1'-0"

#	KEYNOTE DESCRIPTION
L12	ALL LIGHTING CONTROL CABLING INSTALLED IN THIS SPACE SHALL BE INSTALLED IN EMT CONDUIT. PAINT ALL CONDUIT, BOXES AND SUPPORTS TO MATCH STRUCTURE.
L13	ROUTE TO REMOTE DRIVER AS INDICATED.
L14	ROUTE THROUGH RELAY PANEL.
L21	THEATRICAL LIGHTING NETS DMX OUT AS REQUIRED FOR CONNECTION AND CONTROL OF TYPE 'W' WALL WASH FIXTURES IN LOBBY AREA.
L22	ASIS & STAGE LIMIT LIGHTING SYSTEM TRANSFORMER, 0-10V CONTROLLERS AND BREAKER BOX. COORDINATE INSTALLATION REQUIREMENTS WITH VENDOR SHOP DRAWINGS.



SA&E PROJECT NUMBER	01-615-056
BID PACKAGE	BP-1
ISSUED FOR CONSTRUCTION	10/15/2019
Southern AE	
7951 Traxon Circle Austell, Ga 30168 (770) 519-7777	architects & engineers
R #	Doc #
1	AD1
Date	11.4.2019

FACILITY CODE NUMBER: 674-0110
GYMNASIUM/AUDITORIUM FOR:
HEARD COUNTY SCHOOLS
 545 MAIN STREET, FRANKLIN, GA 30217
HEARD COUNTY SCHOOL SYSTEM
 FRANKLIN, GEORGIA

AUDITORIUM - LEVEL 01 - LIGHTING PLAN

		DRAWING NUMBER
		E110

1 LEVEL 01 - AUDITORIUM - LIGHTING PLAN
1/8" = 1'-0"