



1 LEVEL 01 - THEATRICAL RIGGING & CURTAIN PLAN  
3/16" = 1'-0"

2 THEATRICAL RIGGING - STAGE SECTION  
1/4" = 1'-0"

STAGE RIGGING SCHEDULE

Reference	Reference Name	Distance (1)	Curtain Description	Curtain Fullness	Curtain Material (2)	Curtain Color (2)	Track Length	Pipe Length	Pipe Type and Size	Rigging	# of Lines	Capacity	Low Trim	High Trim	Comments
1	VALANCE	0'-3"	1 SECT @ 60'-0" x 2'-0"	100%	Syn Heavyweave Polyester	WHITE	N/A	1 SECT @ 60'-0"	1-1/2" SCH 40 BLACK PIPE	WALL MOUNTED	7	0.00 lbf	16'-6"	18'-6"	WALL MOUNT VALANCE BELOW PROJECTION SCREEN.
2	PROJECTION SCREEN	0'-8"	N/A	N/A	<By Contractor>	MATTE WHITE	N/A	N/A	1-1/2" SCHED 40 BLACK PIPE	CEILING/WALL SUSPENDED	4	0.00 lbf	0'-0"	0'-0"	WALL/CEILING MOUNTED UNIT. COORDINATE MOUNTING RAN SPACE REQUIREMENTS W/ PROJECTION SCREEN VENDOR SHOP DRAWINGS PRIOR TO ROUGH-IN.
3	FRONT CURTAIN	1'-2"	MOTORIZED FRONT CURTAIN (BI-PARTING)	100%	Syn Heavyweave Polyester Velour	PEWTER	2 SECT EA @ 33'-0" (+2' OVERLAP)	66'-0"	1-1/2" SCHED 40 BLACK PIPE W/ WALK-ALONG TRACK	DEAD HUNG	8	0.00 lbf	0'-0"	21'-0"	MOTORIZED BI-PARTING FRONT CURTAIN SYSTEM MOUNTED ON TRACK. PROVIDE CONTROL STATIONS ON STAGE AND CONTROL RM.
4	STAGE ELECTRIC #1	2'-10"	N/A	N/A	None	N/A	N/A	62'-0" (TOP/BOTTOM PIPE), 60'-0" (CONNECTOR STRIP)	1-1/2" SCH 40 BLACK PIPE W/ CONNECTOR STRIP	MOTORIZED HOIST	7	2000.00 lbf	25'-0"	3'-0"	REFER TO SECTION 11 61 73 & DETAILS FOR HOIST REQUIREMENTS. REFER TO SECTION 26 55 61 & DETAILS FOR CONNECTOR STRIP REQUIREMENTS.
5	SCENERY BATTEN #1	4'-8"	N/A	N/A	None	N/A	N/A	60'-0"	1-1/2" SCHED 40 BLACK PIPE	DEAD HUNG	7	0.00 lbf	0'-0"	0'-0"	
6	BORDER #1	6'-4"	1 SECT @ 62'-0" x 4'-0"	50%	MED. WEIGHT WOVEN COTTON VELOUR	BLACK	N/A	62'-0"	1-1/2" SCHED 40 BLACK PIPE	DEAD HUNG	7	0.00 lbf	17'-0"	21'-0"	
7	LEG #1 - W/ TORM	6'-8"	LEG: 2 SECT @ 10'-0"W, TORM: 2 SECT @ 4'-0"W	50%	MED. WEIGHT WOVEN COTTON VELOUR	BLACK	LEG: 14'-0" (EACH SIDE), TORM: 2 SECT @ 4'-0"	LEG: 14'-0" (EACH SIDE), TORM: 2 SECT @ 4'-0"	1-1/2" SCHED 40 BLACK PIPE W/ WALK-ALONG TRACK	DEAD HUNG	5	0.00 lbf	0'-0"	20'-0"	PROVIDE WALK ALONG TYPE TRACK SYSTEM FOR LEG & TORM. TORM ANGLE SHOULD BE 30 DEG.
8	SCENERY BATTEN #2	7'-6"	N/A	N/A	None	N/A	N/A	60'-0"	1-1/2" SCHED 40 BLACK PIPE	DEAD HUNG	7	0.00 lbf	0'-0"	0'-0"	
9	SCENERY BATTEN #3	8'-9"	N/A	N/A	None	N/A	N/A	60'-0"	1-1/2" SCHED 40 BLACK PIPE	DEAD HUNG	7	0.00 lbf	0'-0"	0'-0"	
10	SCENERY BATTEN #4	10'-0"	N/A	N/A	None	N/A	N/A	60'-0"	1-1/2" SCHED 40 BLACK PIPE	DEAD HUNG	7	0.00 lbf	0'-0"	0'-0"	
11	BORDER #2	11'-0"	1 SECT @ 62'-0" x 4'-0"	50%	MED. WEIGHT WOVEN COTTON VELOUR	BLACK	N/A	62'-0"	1-1/2" SCHED 40 BLACK PIPE	DEAD HUNG	7	0.00 lbf	17'-0"	21'-0"	
12	LEG #2 - W/ TORM	11'-4"	LEG: 2 SECT @ 10'-0"W, TORM: 2 SECT @ 4'-0"W	50%	MED. WEIGHT WOVEN COTTON VELOUR	BLACK	LEG: 14'-0" (EACH SIDE), TORM: 2 SECT @ 4'-0"	LEG: 14'-0" (EACH SIDE), TORM: 2 SECT @ 4'-0"	1-1/2" SCHED 40 BLACK PIPE W/ WALK-ALONG TRACK	DEAD HUNG	5	0.00 lbf	0'-0"	22'-0"	PROVIDE WALK ALONG TYPE TRACK SYSTEM FOR LEG & TORM. TORM ANGLE SHOULD BE 30 DEG.
13	STAGE ELECTRIC #2	10'-0"	N/A	N/A	None	N/A	N/A	62'-0" (TOP/BOTTOM PIPE), 60'-0" (CONNECTOR STRIP)	1-1/2" SCH 40 BLACK PIPE W/ CONNECTOR STRIP	MOTORIZED HOIST	7	2000.00 lbf	25'-0"	3'-0"	REFER TO SECTION 11 61 73 & DETAILS FOR HOIST REQUIREMENTS. REFER TO SECTION 26 55 61 & DETAILS FOR CONNECTOR STRIP REQUIREMENTS.
14	SCENERY BATTEN #5	14'-0"	N/A	N/A	None	N/A	N/A	60'-0"	1-1/2" SCHED 40 BLACK PIPE	DEAD HUNG	7	0.00 lbf	0'-0"	0'-0"	
15	SCENERY BATTEN #6	15'-8"	N/A	N/A	None	N/A	N/A	60'-0"	1-1/2" SCHED 40 BLACK PIPE	DEAD HUNG	7	0.00 lbf	0'-0"	0'-0"	
16	SCENERY BATTEN #7	16'-10"	N/A	N/A	None	N/A	N/A	60'-0"	1-1/2" SCHED 40 BLACK PIPE	DEAD HUNG	7	0.00 lbf	0'-0"	0'-0"	
17	BORDER #3	17'-8"	1 SECT @ 62'-0" x 4'-0"	50%	MED. WEIGHT WOVEN COTTON VELOUR	BLACK	N/A	62'-0"	1-1/2" SCHED 40 BLACK PIPE	DEAD HUNG	7	0.00 lbf	17'-0"	21'-0"	
18	REAR CURTAIN W/ TORM	18'-4"	CURTAIN: MANUAL (BI-PARTING), TORM: 2 SECT @ 4'-0"W	50%	MED. WEIGHT WOVEN COTTON VELOUR	BLACK	CURTAIN: 2 SECT EA @ 31'-0" (+2' OVERLAP), TORM: 2 SECT @ 4'-0"	62'-0"	1-1/2" SCHED 40 BLACK PIPE W/ WALK-ALONG TRACK	DEAD HUNG	9	0.00 lbf	0'-0"	0'-0"	MANUAL BI-PARTING CURTAIN SYSTEM W/ FLYING END PULLEY. TORM ANGLE SHOULD BE 30 DEG.
19	CYCLORAMA	18'-10"	CYCLORAMA: 1 SECT @ 60'-0" x 20'-0"	N/A	SHARKTOOTH SCRIM	WHITE	1 SECT @ 60'-0"	60'-0"	1-1/2" SCHED 40 BLACK PIPE W/ WALK-ALONG TRACK	DEAD HUNG	7	0.00 lbf	0'-0"	0'-0"	
A	FOH ELECTRIC 'A'	11'-8"	N/A	N/A	None	N/A	N/A	57'-0" (TOP/BOTTOM PIPE), 55'-0" (CONNECTOR STRIP)	1-1/2" SCH 40 BLACK PIPE W/ CONNECTOR STRIP	MOTORIZED HOIST	7	2000.00 lbf	3'-0"	28'-0"	REFER TO SECTION 11 61 73 & DETAILS FOR HOIST REQUIREMENTS. REFER TO SECTION 26 55 61 & DETAILS FOR CONNECTOR STRIP REQUIREMENTS.
B	FOH ELECTRIC 'B'	26'-0"	N/A	N/A	None	N/A	N/A	67'-0" (TOP/BOTTOM PIPE), 65'-0" (CONNECTOR STRIP)	1-1/2" SCH 40 BLACK PIPE W/ CONNECTOR STRIP	MOTORIZED HOIST	7	2000.00 lbf	32'-0"	3'-0"	REFER TO SECTION 11 61 73 & DETAILS FOR HOIST REQUIREMENTS. REFER TO SECTION 26 55 61 & DETAILS FOR CONNECTOR STRIP REQUIREMENTS.

RIGGING SCHEDULE NOTES:  
1. DISTANCE MEASURED FROM STAGE SIDE OF PROCEMIUM WALL.  
2. COORDINATE CURTAIN MATERIAL AND COLOR WITH ARCHITECT AND OWNER PRIOR ORDERING.

SA&E PROJECT NUMBER: 01-615-056  
 BID PACKAGE: BP-1  
 ISSUED FOR CONSTRUCTION: 10/15/2019

**Southern AE**  
 7951 Traxon Circle  
 Austell, Ga 30168  
 (770) 519-7777  
 architects & engineers

REVISIONS  
 R# 1 Doc# AD1 Date 11.4.2019

FACILITY CODE NUMBER: 674-0110  
**HEARD COUNTY SCHOOLS**  
 545 MAIN STREET, FRANKLIN, GA 30217  
**HEARD COUNTY SCHOOL SYSTEM**  
 FRANKLIN, GEORGIA

AUDITORIUM - LEVEL 01 - THEATRICAL RIGGING & CURTAIN PLAN

DRAWING NUMBER: **E115**