


#	KEYNOTE DESCRIPTION
L14	ROUTE THROUGH RELAY PANEL
L15	THEATRICAL LIGHTING FLOOR POCKET FLUSH MOUNTED IN STAGE FLOOR. FLOOR POCKET PROVIDED BY THEATRICAL LIGHTING CONTRACTOR AND INSTALLED BY E.C. COORDINATE INSTALLATION REQUIREMENTS WITH VENDOR SHOP DRAWINGS PRIOR TO ROUGH-IN. PROVIDE (1) 1" TO TCR RACK FOR LOW VOLTAGE CABLING. PROVIDE CONDUIT/CONDUCTORS FOR LIGHTING CIRCUITS PER PANEL AND/OR RELAY PANEL SCHEDULE.
L16	THEATRICAL LIGHTING WALL BOX FLUSH MOUNTED IN STAGE WALL. WALL BOX PROVIDED BY THEATRICAL LIGHTING CONTRACTOR AND INSTALLED BY E.C. COORDINATE INSTALLATION REQUIREMENTS WITH VENDOR SHOP DRAWINGS PRIOR TO ROUGH-IN. PROVIDE (1) 1" TO TCR RACK FOR LOW VOLTAGE CABLING. PROVIDE CONDUIT/CONDUCTORS FOR LIGHTING CIRCUITS PER PANEL AND/OR RELAY PANEL SCHEDULE.
L17	THEATRICAL LIGHTING SYSTEM RELAY PANEL. FURNISHED BY 26 55 61 CONTRACTOR AND INSTALLED BY E.C. COORDINATE ROUGH-IN REQUIREMENTS WITH VENDOR SHOP DRAWINGS.
L18	THEATRICAL LIGHTING SYSTEM MAIN FEED BREAKER/RELAY PANEL. FURNISHED BY 26 55 61 CONTRACTOR AND INSTALLED BY E.C. COORDINATE ROUGH-IN REQUIREMENTS WITH VENDOR SHOP DRAWINGS.
L19	THEATRICAL LIGHTING SYSTEM PROCESSOR CONTROL RACK TCR. REFER TO THEATRICAL LIGHTING ONE-LINE DIAGRAM SECTION 26 55 61 FOR REQUIREMENTS.
L20	THEATRICAL LIGHTING SYSTEM WALL CONNECTION STATION (TYP). REFER TO THEATRICAL LIGHTING ONE-LINE DIAGRAM SECTION 26 55 61 FOR REQUIREMENTS.

Order Plans @

WWW.LDMLINE.COM



SA&E PROJECT NUMBER	01-615-056					
BID PACKAGE	BP-1					
ISSUED FOR CONSTRUCTION	10/15/2019					
<b>Southern AE</b> 7951 Truon Circle Austell, Ga 30168 (770) 519-7777 architects & engineers	REVISIONS					
	<table border="1"> <thead> <tr> <th>R #</th> <th>Doc #</th> <th>Date</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>AD1</td> <td>11.4.2019</td> </tr> </tbody> </table>	R #	Doc #	Date	1	AD1
R #	Doc #	Date				
1	AD1	11.4.2019				

FACILITY CODE NUMBER: 674-0110  
 GYMNASIUM/AUDITORIUM FOR:  
**HEARD COUNTY SCHOOLS**  
 545 MAIN STREET, FRANKLIN, GA 30217  
**HEARD COUNTY SCHOOL SYSTEM**  
 FRANKLIN, GEORGIA

AUDITORIUM - LEVEL 01 - THEATRICAL PERFORMANCE LIGHTING PLAN

DRAWING NUMBER  
**E116**

1 LEVEL 01 - THEATRICAL PERFORMANCE LIGHTING PLAN  
 1/8" = 1'-0"