


POWER KEYNOTE SCHEDULE	
#	KEYNOTE DESCRIPTION
E29	DUPLEX GFCI RECEPTACLE AND/OR DISCONNECT SWITCH INSTALLED ON ROOFTOP STRUT STAND. REFER TO DETAIL FOR INSTALLATION OF ROOFTOP RECEPTACLE AND DISCONNECT SWITCH (TYPICAL)
E45	DISCONNECT SWITCH AND/OR DUPLEX RECEPTACLE INSTALLED ON UNISTRUT FRAME SUPPORTED FROM HVAC EQUIPMENT RAILS' CURB. REFER TO ROOFTOP MINI-SPLIT DETAIL ON DRAWING E501 AND COORDINATE EXACT REQUIREMENTS WITH HVAC CONTRACTOR.

SPECIAL SYSTEMS KEYNOTE SCHEDULE	
#	KEYNOTE DESCRIPTION
C2	DUCT SMOKE DETECTOR INSTALLED IN HVAC PACKAGE UNIT. PROVIDE NEW ADDRESSABLE SMOKE DETECTOR, COMPATIBLE WITH FIRE ALARM SYSTEM. (TYPICAL)



SA&E PROJECT NUMBER	01-615-056					
BID PACKAGE	BP-1					
ISSUED FOR CONSTRUCTION	10/15/2019					
Southern AE 7951 Traxon Circle Austell, Ga 30168 (770) 819-7777 architects & engineers	REVISIONS					
	<table border="1"> <thead> <tr> <th>R #</th> <th>Doc #</th> <th>Date</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>AD1</td> <td>11.4.2019</td> </tr> </tbody> </table>	R #	Doc #	Date	1	AD1
R #	Doc #	Date				
1	AD1	11.4.2019				

FACILITY CODE NUMBER: 674-0110
 GYMNASIUM/AUDITORIUM FOR:
HEARD COUNTY SCHOOLS
 545 MAIN STREET, FRANKLIN, GA 30217
HEARD COUNTY SCHOOL SYSTEM
 FRANKLIN, GEORGIA

AUDITORIUM - ROOF - ELECTRICAL PLAN

		DRAWING NUMBER
		E119

1 ROOF - AUDITORIUM - ELECTRICAL PLAN
 1/8" = 1'-0"