



ACCESS CONTROL ROUGH-IN GENERAL NOTES:

- ELECTRICAL CONTRACTOR SHALL PROVIDE CONDUIT AND OUTLET BOXES FOR EACH DOOR INDICATED ON THE FLOOR PLANS.
- COORDINATE EXACT CONDUIT SERVICE LOCATIONS AND OUTLET BOX REQUIREMENTS WITH DOOR FRAME AND HARDWARE SHOP DRAWINGS PRIOR TO ROUGH-IN.
- ALL CONDUIT TO BE INSTALLED IN DOOR FRAME FOR POWER AND CONTROL.
- WHERE HANDICAP DOOR OPENERS ARE INSTALLED ON DOORS WITH ACCESS CONTROLS, PROVIDE RELAY IN BUTTON CIRCUIT TO DISABLE OPENER WHEN DOOR IS LOCKED.

ACCESS CONTROL ROUGH-IN DETAIL NOTES:

- A - ELECTRIFIED PANIC BAR OR DOOR HANDLE.
- B - PATHWAY TO ACCESS CONTROL HEADEND EQUIPMENT.
- C - BRANCH CIRCUIT TO PANELBOARD. REFER TO PLANS.
- D - DOOR POWER SUPPLY JUNCTION BOX.
- E - 12"x12"x6" ACCESS CONTROL JUNCTION BOX.
- F - ELECTRICAL POWER TRANSFER HINGE.
- G - EXTERIOR 1-GANG OUTLET BOX FOR CARD READER. MOUNT VERTICALLY ON EXTERIOR WALL.
- H - DOOR POSITION SWITCH.
- I - EXTERIOR 1-GANG OUTLET BOX FOR HANDICAP PUSH BUTTON. MOUNT VERTICALLY ON EXTERIOR WALL.
- J - HANDICAP DOOR ASSIST / ACCESS CONTROL POWER SUPPLY (PROVIDED AND INSTALLED BY OTHERS).

SA&E PROJECT NUMBER	01-615-056
BID PACKAGE	BP-1
ISSUED FOR CONSTRUCTION	10/15/2019
Southern AE	
7951 Traxon Circle Austell, Ga 30168 (770) 519-7777	REVISIONS R # Doc # Date 1 AD1 11.4.2019
architects & engineers	
FACILITY CODE NUMBER: 674-0110	
GYMNASIUM/AUDITORIUM FOR: HEARD COUNTY SCHOOLS	
545 MAIN STREET, FRANKLIN, GA 30217	
HEARD COUNTY SCHOOL SYSTEM FRANKLIN, GEORGIA	
DETAILS	
STATE OF GEORGIA REGISTERED PROFESSIONAL ARCHITECT SOUTHERN ARCHITECTS & ENGINEERS, LLC No. 27553	DRAWING NUMBER E501