



CROSSFIELDS
 CHIROPRACTIC OFFICE DESIGN

3265 Brannan Parkway Suite 3015
 Decatur, GA 30034
 Phone: 770.434.9020
 Web: www.ChiropracticOfficeDesign.com

- GENERAL NOTES**
- A. DRAWINGS ARE DIAGRAMMATIC ONLY; FINAL ROUTING OF DUCTWORK AND EQUIPMENT LOCATION SHALL BE DETERMINED IN THE FIELD. ADDITIONAL OFFSETS, ELBOWS, ETC. SHALL BE PROVIDED AND INSTALLED WITHOUT ADDITIONAL COST TO THE OWNER.
 - B. EXHAUST DUCTWORK EXPOSED ON ROOF SHALL BE WRAPPED IN A WEATHER AND CORROSION RESISTANT COVER COMPARABLE TO 3M VENTURECLAD.
 - C. MAINTAIN 10FT SEPARATION BETWEEN OUTSIDE AIR INTAKES AND EXHAUST TERMINATIONS.
 - D. CLEAN ROOM CONSULTANT: SENSITIZATION - BRYAN PRINCE - 228-239-6841

- KEY NOTES**
- 1 LOCATE REMOTE TEMPERATURE SENSOR FOR MFCU-7 NEAR THE TOP OF THE ELEVATOR SHAFT; WIRE REMOTE TEMPERATURE SENSOR BACK TO THERMOSTAT ON LEVEL TWO.
 - 2 TRAP AND PUMP 1" CONDENSATE DRAIN LINE FROM INDOOR MINI-FAN COIL UNIT AND DAYLIGHT ONTO ROOF.
 - 3 INTAKE HOOD FOR OUTSIDE AIR.
 - 4 EXHAUST HOOD FOR BATHROOM AIR.



THIS DRAWING IS THE PROPERTY OF CROSSFIELDS, INC. AND ANY REPRODUCTION OR COPYING OF THIS DRAWING, IN WHOLE OR PART IS PROHIBITED WITH OUT WRITTEN PERMISSION.

**INNOVATION
 COMPOUNDING
 DR. SHAWN HODGES**
 6095 PINE MOUNTAIN RD., SUITE 104
 KENNESAW, GA 30152

REVISIONS:

NO.	DATE	DESCRIPTION
1	10.11.19	REVISION 1

DRAWN BY: AS CHECKED BY: PK
 DATE: 09.24.19
 PROJECT NUMBER: 17125-IC
 SHEET NO:

M1.3

ISSUED FOR PERMITTING

Order Plans @ www.LDILine.com

1 ROOF PLAN
 M1.3 1/4" = 1'-0"

