PLUMBING FIXTURE LOAD SCHEDULE

PLUMBING FIXTURE	QTY	FIXTURE UNITS				REMARKS
		DFU	TOTAL DFU	WSFU EACH	TOTAL WSFU	
WATER CLOSET	2	4	8	5	10	TANK
LAVATORY	2	1	2	2	4	
MOP BASIN	1	2	2	3	3	
SERVICE SINK	1	2	2	3	3	
FLOOR DRAIN	6	2	12	---	---	
HOSE BIBB	2	---	---	5	10	
WATER COOLER	2	1/2	1	0.25	0.5	
TOTALS			27		30.5	

NOTE:
CALCULATIONS SHOWN ARE BASED ON 2018 NORTH CAROLINA PLUMBING CODE

4"Ø SANITARY = 160 DFU @ 1/8" PER FOOT SLOPE.
27 DFU = 4"Ø PIPE

30.5 WSFU = 21 GPM = 1-1/4"Ø WATER SERVICE

PLUMBING FIXTURE AND PIPING CONNECTION SCHEDULE

TAG	DESCRIPTION	MANUFACTURER MODEL	SIZE	VALVE/ FAUCET	CONNECTIONS				REMARKS
					DRAIN	VENT	C.W.	H.W.	
WC-1	WATER CLOSET FLOOR MTD. FLUSH TANK	AMERICAN STANDARD #2467.016	ELONGATED	INTEGRAL WITH TANK	4	2	1/2		MOUNT 18" A.F.F HANDICAP
L-1	LAVATORY HANDICAP-CENTERSET	AMERICAN STANDARD #0124.024	20"x18" VITREOUS CHINA	CHICAGO FAUCET 802-V317CP	1 1/2	1 1/2	1/2	1/2	MOUNT 34" A.F.F HANDICAP 0.5 GPM AERATOR - CHICAGO FAUCET - E2805JKCP
L-2	LAVATORY HANDICAP-CENTERSET	ELKAY ELVWO2219CS	22"X19" STAINLESS STEEL	CHICAGO FAUCET 802-V317CP	1 1/2	1 1/2	1/2	1/2	MOUNT 34" A.F.F HANDICAP 0.5 GPM AERATOR - CHICAGO FAUCET - E2805JKCP
L-3	SERVICE AREA FLOOR MOUNTED SINK	FIAT #FL-1	23"x22"x14" PLASTIC	A-1 FAUCET	1 1/2	1 1/2	1/2	1/2	DECK MOUNTED FAUCET PROVIDED WITH SINK
MS-1	FLOOR MOUNTED MOP SINK	FIAT #MSB-2424	24"X24"	MODEL 830-AA FAUCET W / INTEGRAL VACUUM BREAKER	2	1 1/2	3/4	3/4	889-CC 24" MOP BRACKET, 1453-BB STRAINER
FD-1	FLOOR DRAIN	J.R. SMITH #2010CA-NB	6" ROUND TOP		3	2			CAST IRON BODY
FD-2	FLOOR DRAIN	J.R. SMITH #2350-NB	8 1/2" ROUND WITH SEDIMENT BUCKET		3	2			CAST IRON BODY
FD-3	FLOOR DRAIN	J.R. SMITH #3061	12 1/2"Ø WITH SEDIMENT BUCKET		4	2			CAST IRON BODY
WCO	WALL CLEANOUT	J.R. SMITH #4472T	STAINLESS STEEL COVER PLATE		SEE PLANS				
FCO	FLOOR CLEANOUT	J.R. SMITH #4020	5 3/4"Ø ROUND "TWIST TO FLOOR" ADJUSTABLE TOP		SEE PLANS				NICKEL BRONZE TOP
GCO	GRADE CLEANOUT	J.R. SMITH #4250	8 3/4"Ø ROUND CLEAN OUT FOR UNFINISHED AREA		SEE PLANS				CAST IRON TOP
HB	HOSE BIBB WITH INTEGRAL VACUUM BREAKER SPOUT	ARROWHEAD BRASS HOSE BIBB 361 WITH NIBCO 90° ELBOW 707-3-5-LF	3/4" MALE HOSE THREAD OUTLET				3/4		**90° ELBOW WITH 3/4" SOLDER INLET AND 3/4" THREADED OUTLET, AND INTEGRATED VACUUM BREAKER MOUNT 36" AFF - UNO**
EWC-1	BOTTLE FILLING BI-LEVEL WATER COOLER	ELKAY EZSTL8WSLK	---		1 1/2	1 1/4	3/8		38 3/8" ORIFICE HEIGHT AFF FOR HIGH FOUNTAIN; PROVIDE W/ APRON MODEL #LKAPREZL
EWC-2	WATER COOLER	ELKAY EZS8L	---		1 1/4	1 1/4	3/8		32 7/8" ORIFICE HEIGHT A.F.F.
TMV-1	THERMOSTATIC MIXING VALVE	POWERS LM492	3/4"				3/4	3/4	SET FOR 110° F HOT WATER ASSE 1070 CERTIFIED
TMV-2	THERMOSTATIC MIXING VALVE	POWERS LFS-150-10	1/2"				1/2	1/2	SET FOR 85° F HOT WATER ASSE 1071 CERTIFIED
TP-1	TRAP PRIMER	MIFAB MR-500	1/2"				1/2		MI-DU-500 DISTRIBUTION UNIT & MI-600 TRAP FITTING
RP-1	RECIRCULATION PUMP	GRUNDFOS UP10-16 PM A BN5/LC	3 FT HEAD AT 1 GPM					1/2	SINGLE PHASE, 115 V 25W WITH TIMER AND AQUASTAT

ACCEPTABLE MANUFACTURERS FOR EQUIVALENT OF SCHEDULE PRODUCT (NO OTHER SUBSTITUTIONS WILL BE ALLOWED):
* SEE SPECIFICATIONS

NOTES & REMARKS:
1. COLOR OF FIXTURES SHALL BE WHITE, UNLESS NOTED OTHERWISE.
2. ALL SINKS AND LAVATORIES SHALL HAVE MINIMUM 17 GAUGE TRAPS. WITH CLEAN OUT PLUGS AND WALL ESCUTCHEONS, CHROME PLATED, OFFSET TRAP ON DRAIN LINE, TAILPIECE WITH STRAINER, HANDI-SHIELD VINYL COVERED PIPE INSULATION WITH HOOD OVER NEW DRAIN LINE AND HOT AND COLD WATER LINES.
3. ALL FIXTURES SHALL HAVE INDIVIDUAL WALL SUPPLY STOPS, LOOSE KEY OPERATED, WITH WALL ESCUTCHEONS, CHROME PLATED.
4. TOILET SEATS: ELONGATED WITH OPEN FRONT AND CONTAINING ANTI-MICROBIAL AGENT, BEMIS MODEL #3155CT.
5. WATER COOLERS FURNISHED WITH INTEGRAL VOLUME REGULATORS, HANGERS, WALL MOUNTING PLATE AND 5 YEAR WARRANTY. PROVIDE BOTTLE FILLER ON LOW WATER COOLER
6. LAVATORIES L-1 AND L-2 SHALL BE PROVIDED WITH A VANDAL RESISTANT 0.5 GPM AERATOR - CHICAGO FAUCET MODEL E2805JKCP.
7. ALL TOILET FLUSH CONTROLS SHALL BE PROVIDED ON THE WIDE SIDE OF THE FIXTURE. (AWAY FROM WALL)
8. PROVIDE WALL MOUNTED SERVICE FAUCET, MOP HANGER BRACKET AND STAINLESS STEEL STRAINER AT MS-1 LOCATION.
9. ALL FIXTURES SHALL BE SUBMITTED AND APPROVED BY ENGINEER.
10. PROVIDE 4" DEEP-SEAL TRAP FOR ALL FLOOR DRAINS.



NOTE:
OBTAIN WRITTEN APPROVAL FROM AHJ AND OWNER FOR USE WITH A SURE SEAL #SS3000 INLINE FLOOR DRAIN TRAP SEALER.

NOTE:
ROUTE ALL PIPING TIGHT TO WALL AND OR AS HIGH AS POSSIBLE.

2 P6 DOMESTIC WATER PIPING DIAGRAM
SCALE: N.T.S.



1 P6 WASTE & VENT PIPING DIAGRAM
SCALE: N.T.S.

NOTE:
SANITARY AND DOMESTIC WATER PIPING DIAGRAMS ARE DIAGRAMMATIC ONLY. CONTRACTOR SHALL COORDINATE EXACT ROUTING OF PIPING WITH FIELD CONDITIONS.

NOTE:
ALL DOMESTIC WATER PIPING ROUTED TO PLUMBING FIXTURES LOCATED ON CMU WALLS SHALL BE INSTALLED EXPOSED AND INSULATED. COORDINATE LOCATIONS WITH PLUMBING PLAN.

SLOPE OF HORIZONTAL DRAINAGE PIPE	
SIZE	MINIMUM SLOPE
2-1/2" OR LESS	1/4 / ft OR 2%
3" TO 6"	1/8 / ft OR 1%

NOTE:
SCHEDULE BASED ON 2018 NORTH CAROLINA CODE, SECTION 704 - TABLE 704.1.

GAS FIRED WATER HEATER SCHEDULE

MARK	AREA SERVED	MANUFACTURER	MODEL NUMBER	STORAGE CAPACITY	RECOVERY CAPACITY	MBH INPUT	VOLTS/ PHASE
WH-1	BUILDING	A. O. SMITH	BTX-80	50 GAL	83 GPH @ 100° TEMP RISE	76	120/1

ACCEPTABLE MANUFACTURERS FOR EQUIVALENT OF SCHEDULE PRODUCT (NO OTHER SUBSTITUTIONS WILL BE ALLOWED):
* SEE SPECIFICATIONS

NOTES:
1. WATER HEATER FURNISHED AND INSTALLED BY CONTRACTOR.
2. PROVIDE MANUFACTURERS CONCENTRIC VENT TERMINATION KIT.
3. SET DISCHARGE TEMPERATURE OF WATER HEATER TO OPERATE AT 140 DEG F MAX. (FOR MOP SINK USE ONLY, SEE PLUMBING NOTES AND WATER PIPING DIAGRAM).
4. ROUTE T&P RELIEF DRAIN AND OTHER DRAIN PIPING TO FLOOR DRAIN. TERMINATE 2" ABOVE RIM LEVEL.

GAS PRESSURE REGULATOR SCHEDULE

MANUFACTURER	MODEL NUMBER	CFH CAPACITY	INLET PRESSURE	OUTLET PRESSURE	SPRING COLOR RANGE-ORIFICE
ACTARIS	B-31R 3/4"X3/4"	UP TO 150	2 P.S.I.G.	7 INCHES W.C.	LT.GREEN 5.5 TO 8.0 INCHES W.C.-1/8"
ACTARIS	B-31R 3/4"X1"	150 TO 400	2 P.S.I.G.	7 INCHES W.C.	LT.GREEN 5.5 TO 8.0 INCHES W.C.-1/4"
ACTARIS	B-31R 1"X1"	400 TO 800	2 P.S.I.G.	7 INCHES W.C.	LT.GREEN 5.5 TO 8.0 INCHES W.C.-3/8"

NOTES:
1. REGULATOR ARE FULL CAPACITY INTERNAL RELIEF TYPE.
2. REGULATOR TO BE INSTALLED WITH RELIEF VENT IN POSITION TO PREVENT ENTRANCE OF WATER (PROVIDE SCREENED VENT ELBOW AS REQUIRED).
3. TAG REGULATOR WITH INLET AND OUTLET SETTINGS. AFFIX WARNING 'DO NOT REMOVE'.



NOTE:
GAS PIPING IS SIZED BASED ON 7 IN. W.C PRESSURE AND A 0.5 W.C. PRESSURE DROP PER THE 2018 NORTH CAROLINA FUEL GAS CODE, TABLE 402.2.

3 P6 GAS PIPING SCHEMATIC
SCALE: N.T.S.

Order Plans @ WWW.BIDLine.com

ACERTUS CONSULTING GROUP, LLC
14917 West 95th Street ◆ Lenexa, Kansas 66215
P 913.322.5150 ◆ F 913.322.5155
www.AcertusKansas.com

Firestone COMPLETE AUTO CARE since 1988

EXPLANATION OF RELEASE
THIS DRAWING WAS PREPARED FOR USE ON A SPECIFIC SITE AT GARNER, NC CONTEMPORANEOUSLY WITH ITS ISSUE DATE ON BIDDING AND PERMIT AVAILABLE DOCUMENTS AND IS NOT SUITABLE FOR USE AT A LATER TIME. USE OF THIS DRAWING FOR REFERENCE OR EXAMPLES ON ANOTHER PROJECT REQUIRES THE SERVICES OF PROPERLY LICENSED ARCHITECTS AND ENGINEERS. ACERTUS CONSULTING GROUP DRAWING FOR REUSE ON ANOTHER PROJECT IS NOT AUTHORIZED AND MAY BE CONTRARY TO THE LAW.

THIS DRAWING IS THE PROPERTY OF BRIDGESTONE RETAIL OPERATIONS, LLC AND IS LOANED ON THE EXPRESS CONDITION THAT IT IS NOT TO BE USED IN ANY WAY DETRIMENTAL TO THE INTERESTS OF BRIDGESTONE RETAIL OPERATIONS, LLC AND THAT THE ACCEPTANCE OF THIS DRAWING SHALL BE CONSTRUED AS AN ACCEPTANCE OF THE FOREGOING CONDITION AND AS AN AGREEMENT TO THE EXCLUSIVE OWNERSHIP IN AND TO THE DRAWING BY BRIDGESTONE RETAIL OPERATIONS, LLC.

NEW FCAC STORE
2019 JANUARY -SMALL ER
5845 NC HWY 42
GARNER, NC

NORTH CAROLINA PROFESSIONAL SEAL 032801 ENGINEER ANTHONY A. MESSINA
09/26/19

ACERTUS NORTH CAROLINA CERTIFICATION NUMBER – P1514

ISSUE BLOCK

1	09/27/19	ADDENDUM #1

PROPERTY NO.:	160017
6 DIGIT NO.:	903065
4 DIGIT NO.:	015P
AOR PROJECT NUMBER:	1955B01
TO PERMIT: DATE:	07-26-19
TO BID: DATE:	## ### ##

SHEET TITLE:
PLUMBING SCHEDULES AND RISERS

SHEET NUMBER:
P6

Sep 26, 2019 – 2:46pm – USER AcronAngel
G:\Bridgestone-Firestone (Engineering)\1920230 BSRO – Garner, NC\Sheets\P6 PLUMBING SCHEDULES AND RISERS.dwg