

Order Plans

@

WWW.LDILINE.COM

PANEL NO. "H06A" NO. OF CKT SPACES 42			MAIN DEVICE			
PP VOLT: 208 AC RATING: 22,000			TYPE: MLO			
NO. PH: 3 CABINET SURFACE			SIZE: 400A			
NO.	TA	WS	COND	DESCRIPT	TL	LOAD
1	163	18	12"	WSP	C	18700
2	---	---	---	---	---	---
3	---	---	---	---	---	---
4	---	---	---	---	---	---
5	---	---	---	---	---	---
6	---	---	---	---	---	---
7	505	18	12"	WSP	C	13700
8	---	---	---	---	---	---
9	---	---	---	---	---	---
10	---	---	---	---	---	---
11	---	---	---	---	---	---
12	204	---	---	SPACE	---	---
13	204	---	---	SPACE	---	---
14	204	---	---	SPACE	---	---
15	204	---	---	SPACE	---	---
16	204	---	---	SPACE	---	---
17	204	---	---	SPACE	---	---
18	204	---	---	SPACE	---	---
19	204	---	---	SPACE	---	---
20	204	---	---	SPACE	---	---
21	204	---	---	SPACE	---	---
22	204	---	---	SPACE	---	---
23	204	---	---	SPACE	---	---
24	204	---	---	SPACE	---	---
25	204	---	---	SPACE	---	---
26	204	---	---	SPACE	---	---
27	204	---	---	SPACE	---	---
28	204	---	---	SPACE	---	---
29	204	---	---	SPACE	---	---
30	204	---	---	SPACE	---	---
31	805	4	1 1/2"	ESR-10	C	15700
32	---	---	---	---	---	---
33	---	---	---	---	---	---
34	---	---	---	---	---	---
35	---	---	---	---	---	---
36	---	---	---	---	---	---
37	805	4	1 1/2"	ESR-10	C	15700
38	---	---	---	1005 SEE RACK	PANEL 12"	P 11400
39	---	---	---	---	---	---
40	---	---	---	---	---	---
41	---	---	---	---	---	---
42	---	---	---	---	---	---
DESCRIPT.	DF	LOAD				DEMAND
OTH PNL.	1	0	VOLTAGE:	208		0
RECEPT.	0.5	0	PHASE %:	3		0
LIGHT.	1.25	0	SPARE %:	0.2		0
HEAT.	1	0				0
COOL.	1	0				0
MOTOR.	1	0				0
OTHER.	1	0				0
SPARE.	1	0				0
		CONN LOAD AMP				DEM LOAD AMP
		27884				27884

NOTES: PROVIDE FEED THROUGH LUGS TO SERVE PANEL "H06A"

PANEL NO. "H06B" NO. OF CKT SPACES 42			MAIN DEVICE			
PP VOLT: 208 AC RATING: 22,000			TYPE: MLO			
NO. PH: 3 CABINET SURFACE			SIZE: 400A			
1	163	18	12"	WSP	C	13200
2	---	---	---	---	---	---
3	---	---	---	---	---	---
4	---	---	---	---	---	---
5	---	---	---	---	---	---
6	---	---	---	---	---	---
7	205	18	12"	WSP	C	2300
8	---	---	---	---	---	---
9	---	---	---	---	---	---
10	---	---	---	---	---	---
11	---	---	---	---	---	---
12	204	---	---	SPACE	---	---
13	204	---	---	SPACE	---	---
14	204	---	---	SPACE	---	---
15	204	---	---	SPACE	---	---
16	204	---	---	SPACE	---	---
17	204	---	---	SPACE	---	---
18	204	---	---	SPACE	---	---
19	204	---	---	SPACE	---	---
20	204	---	---	SPACE	---	---
21	204	---	---	SPACE	---	---
22	204	---	---	SPACE	---	---
23	204	---	---	SPACE	---	---
24	204	---	---	SPACE	---	---
25	204	---	---	SPACE	---	---
26	204	---	---	SPACE	---	---
27	204	---	---	SPACE	---	---
28	204	---	---	SPACE	---	---
29	204	---	---	SPACE	---	---
30	204	---	---	SPACE	---	---
31	204	---	---	SPACE	---	---
32	204	---	---	SPACE	---	---
33	204	---	---	SPACE	---	---
34	204	---	---	SPACE	---	---
35	204	---	---	SPACE	---	---
36	204	---	---	SPACE	---	---
37	204	---	---	SPACE	---	---
38	204	---	---	SPACE	---	---
39	204	---	---	SPACE	---	---
40	204	---	---	SPACE	---	---
41	204	---	---	SPACE	---	---
42	204	---	---	SPACE	---	---
DESCRIPT.	DF	LOAD				DEMAND
OTH PNL.	1	0	VOLTAGE:	208		0
RECEPT.	0.5	0	PHASE %:	3		0
LIGHT.	1.25	0	SPARE %:	0.2		0
HEAT.	1	0				0
COOL.	1	0				0
MOTOR.	1	0				0
OTHER.	1	0				0
SPARE.	1	0				0
		CONN LOAD AMP				DEM LOAD AMP
		27926				27926

NOTES: PROVIDE FEED THROUGH LUGS TO SERVE PANEL "H06B"

PANEL NO. "H06C" NO. OF CKT SPACES 42			MAIN DEVICE			
PP VOLT: 208 AC RATING: 22,000			TYPE: MCB			
NO. PH: 3 CABINET SURFACE			SIZE: 325A			
1	203	12	12"	RECEPT	R	900
2	203	12	12"	RECEPT	R	900
3	203	12	12"	RECEPT	R	900
4	203	12	12"	RECEPT	R	900
5	203	12	12"	RECEPT	R	900
6	203	12	12"	RECEPT	R	900
7	203	12	12"	RECEPT	R	900
8	203	12	12"	RECEPT	R	900
9	203	12	12"	RECEPT	R	900
10	203	12	12"	RECEPT	R	900
11	203	12	12"	RECEPT	R	900
12	203	12	12"	RECEPT	R	900
13	203	12	12"	RECEPT	R	900
14	203	12	12"	RECEPT	R	900
15	203	12	12"	RECEPT	R	900
16	203	12	12"	RECEPT	R	900
17	203	12	12"	RECEPT	R	900
18	203	12	12"	RECEPT	R	900
19	203	12	12"	RECEPT	R	900
20	203	12	12"	RECEPT	R	900
21	203	12	12"	RECEPT	R	900
22	203	12	12"	RECEPT	R	900
23	203	12	12"	RECEPT	R	900
24	203	12	12"	RECEPT	R	900
25	203	12	12"	RECEPT	R	900
26	203	12	12"	RECEPT	R	900
27	203	12	12"	RECEPT	R	900
28	203	12	12"	RECEPT	R	900
29	203	12	12"	RECEPT	R	900
30	203	12	12"	RECEPT	R	900
31	203	12	12"	RECEPT	R	900
32	203	12	12"	RECEPT	R	900
33	203	12	12"	RECEPT	R	900
34	203	12	12"	RECEPT	R	900
35	203	12	12"	RECEPT	R	900
36	203	12	12"	RECEPT	R	900
37	203	12	12"	RECEPT	R	900
38	203	12	12"	RECEPT	R	900
39	203	12	12"	RECEPT	R	900
40	203	12	12"	RECEPT	R	900
41	203	12	12"	RECEPT	R	900
42	203	12	12"	RECEPT	R	900
DESCRIPT.	DF	LOAD				DEMAND
OTH PNL.	1	0	VOLTAGE:	208		0
RECEPT.	0.5	0	PHASE %:	3		0
LIGHT.	1.25	0	SPARE %:	0.2		0
HEAT.	1	0				0
COOL.	1	0				0
MOTOR.	1	0				0
OTHER.	1	0				0
SPARE.	1	0				0
		CONN LOAD AMP				DEM LOAD AMP
		28140				28140

NOTES: PROVIDE FEED THROUGH LUGS TO SERVE PANEL "H06C"

PANEL NO. "H06D" NO. OF CKT SPACES 42			MAIN DEVICE			
PP VOLT: 208 AC RATING: 22,000			TYPE: MCB			
NO. PH: 3 CABINET SURFACE			SIZE: 325A			
1	4002	5	3/4"	DRUG-4	C	1000
2	---	---	---	---	---	---
3	---	---	---	---	---	---
4	204	12	12"	DRUG-14	C	1000
5	---	---	---	---	---	---
6	---	---	---	---	---	---
7	---	---	---	---	---	---
8	204	12	12"	RECEPT	R	700
9	204	12	12"	RECEPT	R	700
10	204	12	12"	RECEPT	R	700
11	204	12	12"	RECEPT	R	700
12	204	12	12"	RECEPT	R	700
13	204	12	12"	RECEPT	R	700
14	204	12	12"	RECEPT	R	700
15	204	12	12"	RECEPT	R	700
16	204	12	12"	RECEPT	R	700
17	204	12	12"	RECEPT	R	700
18	204	12	12"	RECEPT	R	700
19	204	12	12"	RECEPT	R	700
20	204	12	12"	RECEPT	R	700
21	204	12	12"	RECEPT	R	700
22	204	12	12"	RECEPT	R	700
23	204	12	12"	RECEPT	R	700
24	204	12	12"	RECEPT	R	700
25	204	12	12"	RECEPT	R	700
26	204	12	12"	RECEPT	R	700
27	204	12	12"	RECEPT	R	700
28	204	12	12"	RECEPT	R	700
29	204	12	12"	RECEPT	R	700
30	204	12	12"	RECEPT	R	700
31	204	12	12"	RECEPT	R	700
32	204	12	12"	RECEPT	R	700
33	204	12	12"	RECEPT	R	700
34	204	12	12"	RECEPT	R	700
35	204	12	12"	RECEPT	R	700
36	204	12	12"	RECEPT	R	700
37	204	12	12"	RECEPT	R	700
38	204	12	12"	RECEPT	R	700
39	204	12	12"	RECEPT	R	700
40	204	12	12"	RECEPT	R	700
41	204	12	12"	RECEPT	R	700
42	204	12	12"	RECEPT	R	700
DESCRIPT.	DF	LOAD				DEMAND
OTH PNL.	1	0	VOLTAGE:	208		0
RECEPT.	0.5	0	PHASE %:	3		0
LIGHT.	1.25	0	SPARE %:	0.2		0
HEAT.	1	0				0
COOL.	1	0				0
MOTOR.	1	0				0
OTHER.	1	0				0
SPARE.	1	0				0
		CONN LOAD AMP				DEM LOAD AMP
		28780				28780

NOTES: PROVIDE FEED THROUGH LUGS TO SERVE PANEL "H06D"

PANEL NO. "H06E" NO. OF CKT SPACES 42			MAIN DEVICE			
PP VOLT: 208 AC RATING: 22,000			TYPE: MCB			
NO. PH: 3 CABINET SURFACE			SIZE: 325A			
1	203	12	12"	RECEPT	R	900
2	203	12	12"	RECEPT	R	900
3	203	12	12"	RECEPT	R	900
4	203	12	12"	RECEPT	R	900
5	203	12	12"	RECEPT	R	900
6	203	12	12"	RECEPT	R	900
7	203	12	12"	RECEPT	R	900
8	203	12	12"	RECEPT	R	900
9						