

Order Plans @ www.LDILine.com

GENERAL PARTITION NOTES

- 1 USE PARTITION TYPE " " UNO
- 2 FOR CLARITY, PARTITION TYPES DO NOT INDICATE BASE AND FLOOR FINISHES. REFER TO ROOM FINISH SCHEDULE.
- 3 PROVIDE THROUGH PENETRATION FIRE STOP SYSTEM AT FIRE RATED PARTITIONS, SHAFTWALLS, AND FLOOR OPENINGS. REFER TO SHEET X-XXX.
- 4 FOR FIRE RESISTANT JOINT SYSTEM HEAD-OF-WALL DETAILS, REFER TO SHEET X-XXX.
- 5 EXTEND FIRE RATED PARTITIONS TO EXTERIOR FACE OF BUILDING WALL. FOR BRICK OR CMF WALLS, THE EXTERIOR WALL IS THE BACKSIDE OF SHEATHING.
- 6 CONSTRUCT FIRE RATED MASONRY PARTITIONS WITH CMU-2, TYPICAL.
- 7 PARTITIONS WITH TYPE INDICATORS ON BOTH SIDES OF PARTITION SHALL BE CONSTRUCTED TO SATISFY BOTH CONDITIONS INDICATED.
- 8 APPLY A CONTINUOUS BEAD OF ACOUSTICAL SEALANT AROUND ALL ELECTRICAL WALL BOXES.
- 9 FOR NON-FIRE RATED PARTITIONS, APPLY ACOUSTICAL SEALANT TO PENETRATIONS ABOVE THE CEILING IN FULL-HEIGHT PARTITIONS, UNO.
- 10 PROVIDE MOISTURE RESISTANT G.W.B. ON ALL THROUGH-PENET WALLS, EXCEPT FOR CLOSET WALLS, AND MECHANICAL ROOM WALLS, UNO.
- 11 INSTALL 1/2" CEMENT BACKER BOARD IN ALL SHEETS THAT ARE TILED WITH CERAMIC TILE.
- 12 PROVIDE CONTROL JOINTS AT 30' MAX. PARTITIONS LOCATE SYMMETRICALLY OR EVENLY SPACED ON WALLS IF NOT SHOWN OTHERWISE. REVIEW PROPOSALS WITH ARCHITECT PRIOR TO INSTALLATION.

GYPSON BOARD APPLICATION


- 1 USE 5/8" GYP. BOARD (GCR-1) UNO.
- 2 USE 1/2" GYP. BOARD (GCR-M) IN TOILET ROOMS, UNO.
- 3 USE 1/2" GYP. BOARD (GCR-T) IN CERAMIC TILED APPLICATIONS, UNO.
- 4 USE 5/8" GYP. BOARD (GCR-C) AT SUSPENDED GYP. BOARD CEILING, UNO.
- 5 USE IMPACT RESISTANT GYP. BOARD (GCR-AS) FROM FLOOR LINE TO 4'-0" AFF IN CORRIDORS AND SOLLEY CLEAN WORKROOMS, UNO.

1925 Prospect Ave.
Orlando, FL 32814
P (407) 661-9100
F (407) 661-9101
www.l.dil.com









OHM
10000 N. American Blvd. Suite 300
Orlando, FL 32817
PH: 407.661.9100
FAX: 407.661.9101
www.l.dil.com

SITE KEY:



1 (30x42) NON-RATED - PERPENDICULAR TO FLUTES
1:1/2" x 1'-0"



PARTITION TYPE
PARTITION STRUCTURE
WIDTHS NOTED BELOW
INSTALL SAB

REMOVE PARTITION FRAMING TYPE IF NOT ON PROJECT

NUMERIC CHARACTER	WOOD STUD SIZE	MASONRY BLOCK SIZE
0	-	-
1	3/4"	-
2	1-1/2"	-
3	-	-
4	3-1/2"	3-6"
6	5-1/2"	5-6"
8	7-1/4"	7-6"
10	9-1/4" (VERT.)	9-6"
12	-	11-6"

CLIENT NAME
HUTTON DEVELOPMENT

PROJECT NAME
ROCKLEDGE FLATS - BUILDING B
220 Baron Boulevard
Rockledge, FL 32955

SHEET TITLE
RATED ASSEMBLIES

Revision Schedule	Date
No.	Description

PROJECT NO.	DATE	DESIGNER	CHECKED
210002	20/04/10	LDI	LDI

G-020

NOV 02, 2015
GMP PRICING SET 15 NOVEMBER 2019