

MASONRY CONSTRUCTION (IBC 1704.5)					
ITEM	FREQUENCIES		DETAIL DESCRIPTION		
REVIEW MATERIAL CERTIFICATES, MIX DESIGNS, TEST RESULTS AND CONSTRUCTION PROCEDURES	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	IT SHALL BE CONFIRMED THAT MATERIALS USED CONFORM TO THE REQUIREMENTS OF THE APPROVED CONSTRUCTION DOCUMENTS. MORTAR MIX DESIGNS SHALL SHOW COMPLIANCE WITH THE PROPORTION OR PROPERTY SPECIFICATION OF ASTM C270. GROUT SHALL COMPLY WITH THE PROPORTION OR STRENGTH REQUIREMENTS OF ASTM C476 OR BE BASED UPON COMPRESSIVE STRENGTH TESTS IN ACCORDANCE WITH ASTM C1019. MATERIAL CERTIFICATES SHALL BE PROVIDED FOR THE FOLLOWING: REINFORCEMENT; ANCHORS, TIES, FASTENERS; AND METAL ACCESSORIES. MASONRY UNITS, MORTAR AND GROUT MATERIALS CONSTRUCTION PROCEDURES FOR COLD-WEATHER OR HOT-WEATHER CONSTRUCTION SHALL BE REVIEWED.
VERIFY FM AND FAAC PRIOR TO CONSTRUCTION	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	DETERMINE THE COMPRESSIVE STRENGTH FOR EACH WYTHE BY THE "UNIT STRENGTH METHOD" OR BY THE "PRISM TEST METHOD" AS SPECIFIED IN SECTION 1.4B OF ACI 530.1-08 PRIOR TO CONSTRUCTION. FOR OCCUPANCY CATEGORY IV THIS SHOULD BE VERIFIED AT EVERY 5,000FT ² OF CONSTRUCTION.
SELF-CONSOLIDATING GROUT	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
GROUT PLACEMENT	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
PREPARATION OF REQUIRED GROUT SPECIMENS, MORTAR SPECIMENS AND/OR PRISMS SHALL BE OBSERVED	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	IF THE PRISM TEST METHOD IS USED A MINIMUM OF THREE PRISMS SHALL BE CONSTRUCTED IN ACCORDANCE WITH ASTM C1314. IF THE UNIT STRENGTH METHOD IS SELECTED THE COMPRESSIVE STRENGTH OF THE GROUT SHALL BE DETERMINED PER ASTM C476. CONTINUOUS INSPECTION REQUIRED FOR OCCUPANCY CATEGORY IV STRUCTURES.
POST-INSTALLED ANCHORS OR DOWELS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	ALL POST-INSTALLED ANCHORS/DOWELS SHALL BE SPECIALLY INSPECTED AS REQUIRED BY THE APPROVED ICC-ES REPORT.
PRIOR TO GROUTING:					
GROUT SPACE IS CLEAN	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT GROUT SPACE IS FREE OF MORTAR DROPPINGS, DEBRIS, LOOSE AGGREGATE, AND MATERIAL DELETERIOUS TO MASONRY GROUT. CONTINUOUS INSPECTION REQUIRED FOR OCCUPANCY CATEGORY IV STRUCTURES.
PLACEMENT OF REINFORCEMENT AND CONNECTORS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT REINFORCEMENT, JOINT REINFORCEMENT, WALL TIES, ANCHOR BOLTS AND VENEER ANCHORS ARE INSTALLED IN ACCORDANCE WITH SECTION 3.4 OF ACI 530.1-08.
PROPORTIONS OF SITE-PREPARED GROUT	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT GROUT IS PROPORTIONED PER ASTM C476 AND HAS A SLUMP BETWEEN 8-11 INCHES. SELF-CONSOLIDATED GROUT SHALL NOT BE PROPORTIONED ON SITE.
AS MASONRY CONSTRUCTION BEGINS:					
PROPORTIONS OF SITE-PREPARED MORTAR	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	ENSURE THAT MORTAR THAT BEGINS TO STIFFEN OR IS NOT USED WITHIN 2 1/2 HOURS IS DISCARDED. NO ADMIXTURES CONTAINING > 0.2% CHLORIDES SHALL BE USED. JOBSITE PIGMENTS SHALL MEET THE LIMITATIONS OF SECTION 2.6A OF ACI 530.1-08.
CONSTRUCTION OF MORTAR JOINTS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	UNLESS SPECIFIED OTHERWISE CONSTRUCT 3/8" BED AND HEAD JOINTS, EXCEPT AT FOUNDATION OR GLASS UNIT MASONRY. BED JOINT AT FOUNDATION SHALL BE > 1/4" AND ≤ 3/4". TOOL JOINTS WITH A ROUND JOINTER WHEN MORTAR IS THUMBPRINT HARD. REMOVE MASONRY PROTRUSIONS EXTENDING ≥ 1/2" INTO CELLS TO BE GROUTED. SOLIDLY FILL COLLAR JOINTS < 3/4" WITH MORTAR DURING CONSTRUCTION.
LOCATION OF REINFORCEMENT, CONNECTORS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY COMPLIANCE WITH APPROVED CONSTRUCTION DOCUMENTS. DO NOT PLACE DISSIMILAR METALS IN CONTACT WITH EACH OTHER. PRESTRESSING TENDON PLACEMENT SHALL CONFORM TO SECTION 3.6A OF ACI 530.1-08.
DURING CONSTRUCTION:					
SIZE AND LOCATION OF STRUCTURAL ELEMENTS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT STRUCTURAL ELEMENTS ARE PLACED IN LOCATIONS SPECIFIED ON THE APPROVED CONSTRUCTION DOCUMENTS AND TO THE TOLERANCES NOTED IN SECTION 3.3F OF ACI 530.1-08.
TYPE, SIZE AND LOCATION OF ANCHORS AND OTHER DETAILS OF MASONRY ANCHORAGES TO STRUCTURAL MEMBERS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT STRUCTURAL ELEMENTS ARE PLACED IN LOCATIONS SPECIFIED ON THE APPROVED CONSTRUCTION DOCUMENTS. HEADED OR BENT BAR ANCHOR BOLTS SHALL BE EMBEDDED IN GROUT. CONTINUOUS INSPECTION REQUIRED FOR OCCUPANCY CATEGORY IV STRUCTURES.
SIZE, GRADE AND TYPE OF REINFORCEMENT AND METAL ACCESSORIES	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT MATERIALS MEET THE REQUIREMENTS OF SECTION 2.4 OF ACI 530.1-08. ALL REINFORCEMENT SHALL BE PLACED IN GROUT WITH MINIMUM GROUT COVER OF 1/2" FOR COARSE GROUT AND 1/4" FOR FINE GROUT. VERIFY THAT REINFORCEMENT PROTECTION, STANDARD HOOKS AND MINIMUM BEND DIAMETERS COMPLY WITH SECTION 1.15 OF ACI 530.1-08.
WELDING OF REINFORCING BARS	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
PREPARATION, CONSTRUCTION AND PROTECTION OF MASONRY DURING COLD OR HOT WEATHER CONSTRUCTION	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	WHEN THE AMBIENT AIR TEMPERATURE IS < 40°F ENSURE THAT CONSTRUCTION COMPLIES WITH SECTION 1.8C OF ACI 530.1-08. WHEN THE AMBIENT AIR TEMPERATURE IS > 100°F, OR WITH A WIND VELOCITY > 8MPH, ENSURE THAT CONSTRUCTION COMPLIES WITH SECTION 1.8D OF ACI 530.1-08.
OCCUPANCY CATEGORY IV:					
INSTALLATION OF DRAG STRUT AND ROD	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	DETAIL 8/S4.5

CAST-IN-PLACE CONCRETE CONSTRUCTION (IBC 1704.4 & 1708.2)					
ITEM	FREQUENCIES		DETAIL DESCRIPTION		
REINFORCING STEEL	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY PRIOR TO PLACING CONCRETE THAT REINFORCING IS OF SPECIFIED TYPE, GRADE AND SIZE; THAT IT IS FREE OF OIL, DIRT AND RUST; THAT IT IS LOCATED AND SPACED PROPERLY; THAT HOOKS, BENDS, TIES, STIRRUPS AND SUPPLEMENTAL REINFORCEMENT ARE PLACED CORRECTLY; THAT LAP LENGTHS, STAGGER AND OFFSETS ARE PROVIDED; AND THAT ALL MECHANICAL CONNECTIONS ARE INSTALLED PER THE MANUFACTURER'S INSTRUCTIONS AND/OR EVALUATION REPORT.
WELDING OF REINFORCING STEEL	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY WELDABILITY OF REINFORCING STEEL OTHER THAN A706. CONTINUOUS INSPECTION IS REQUIRED FOR WELDING OF REINFORCING STEEL USED IN INTERMEDIATE OR SPECIAL CONCRETE MOMENT FRAMES, BOUNDARY ELEMENTS OF SPECIAL STRUCTURAL WALLS OR SHEAR REINFORCEMENT.
CAST-IN BOLTS & EMBEDS	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
POST-INSTALLED ANCHORS OR DOWELS	<input type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	ALL POST-INSTALLED ANCHORS/DOWELS SHALL BE SPECIALLY INSPECTED AS REQUIRED BY THE APPROVED ICC-ES REPORT.
USE OF REQUIRED MIX DESIGN	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT ALL MIXES USED COMPLY WITH THE APPROVED CONSTRUCTION DOCUMENTS; ACI 318: CH. 4, 5.2.5.4, AND IBC 1904.3, 1913.2, 1913.3.
CONCRETE SAMPLING FOR STRENGTH TESTS, SLUMP, AIR CONTENT, AND TEMPERATURE	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
CONCRETE & SHOTCRETE PLACEMENT	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
CURING TEMPERATURE AND TECHNIQUES	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT THE AMBIENT TEMPERATURE FOR CONCRETE IS KEPT AT > 50°F FOR AT LEAST 7 DAYS AFTER PLACEMENT. HIGH-EARLY-STRENGTH CONCRETE SHALL BE KEPT AT > 50°F FOR AT LEAST 3 DAYS. ACCELERATED CURING METHODS MAY BE USED (SEE ACI 318: 5.11.3). THE AMBIENT TEMPERATURE FOR SHOTCRETE SHALL BE > 40°F FOR THE SAME PERIOD OF TIME AS NOTED FOR CONCRETE. SHOTCRETE SHALL BE KEPT CONTINUOUSLY MOIST FOR AT LEAST 24 HOURS AFTER SHOTCRETING. ALL CONCRETE MATERIALS, REINFORCEMENT, FORMS, FILLERS, AND GROUT SHALL BE FREE FROM FROST. IN HOT WEATHER CONDITIONS ENSURE THAT APPROPRIATE MEASURES ARE TAKEN TO AVOID PLASTIC SHRINKAGE CRACKING AND THAT THE SPECIFIED WATER/CEMENT RATIO IS NOT EXCEEDED.
STRENGTH VERIFICATION	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT ADEQUATE STRENGTH HAS BEEN ACHIEVED PRIOR TO THE REMOVAL OF SHORES AND FORMS OR THE STRESSING OF POST-TENSIONED TENDONS.
FORMWORK	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT THE FORMS ARE PLACED PLUMB AND CONFORM TO THE SHAPES, LINES, AND DIMENSIONS OF THE MEMBERS AS REQUIRED BY THE APPROVED CONSTRUCTION DOCUMENTS.

STEEL CONSTRUCTION (IBC 1704.3, 1708.2 & 1708.3)					
ITEM	FREQUENCIES		DETAIL DESCRIPTION		
WELDING (1704.3.1)					
COMPLETE & PARTIAL PENETRATION GROOVE WELDS	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
MULTI-PASS FILLET WELDS	<input checked="" type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	
SINGLE-PASS FILLET WELDS > 5/16"	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
PLUG, SLOT, SEAM OR FLANGE WELDS	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
SINGLE-PASS FILLET WELDS ≤ 5/16"	<input type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	PRE-WELDING INSPECTIONS ARE TO BE PERFORMED TO ENSURE THAT PROPER MATERIALS (I.E. STRUCTURAL STEEL, WELD FILLER MATERIAL, ETC.), WELDING PROCEDURES, AND WELDING PERSONNEL QUALIFICATIONS ARE APPROPRIATE. A VISUAL INSPECTION OF ALL WELDS MUST BE PROVIDED WITH PERIODIC INSPECTIONS MADE OF WORK IN PROGRESS.
FLOOR & ROOF DECK WELDS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	
SHEAR CONNECTOR (I.E. STUD) WELDS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	
COLD-FORMED STEEL WELDS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	
WELDS OF STAIRS & RAILING SYSTEMS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	
DETAILS OF STEEL FRAME (1704.3)					
MEMBER LOCATIONS, BRACING, GUSSET PLATES, STIFFENERS, AND OTHER CONNECTION COMPONENTS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	ALL STEEL FRAMES SHALL BE INSPECTED TO VERIFY COMPLIANCE WITH THE APPROVED CONSTRUCTION DOCUMENTS, SUCH AS BRACING, STIFFENING, MEMBER SIZE AND LOCATION, AND PROPER APPLICATION OF JOINT DETAILS AT EACH CONNECTION.
HIGH-STRENGTH BOLTING (1704.3.3)					
TENSIONING & SLIP-CRITICAL NUTS	<input type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	FOR PERIODIC INSPECTIONS ONE OF THE FOLLOWING METHODS MUST BE USED: (1) TURN-OF-NUT METHOD W/ MATCH-MARKING; (2) DIRECT TENSION INDICATOR METHOD OR (3) THE ALTERNATE DESIGN FASTENER (I.E. TWIST-OFF BOLT) METHOD (SEE SECTION 9.2 OF 2009 RCSC SPECIFICATION).
SNUG-TIGHTENED JOINTS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT ALL JOINTS USE PROPER FASTENER COMPONENTS, CONNECTED ELEMENTS ARE FABRICATED PROPERLY, THE BOLTED JOINT IS DRAWN INTO FIRM CONTACT, AND THAT THE NUTS CANNOT BE REMOVED WITHOUT THE USE OF A WRENCH (SEE SECTION 9.1 OF 2009 RCSC SPECIFICATION).
STRUCTURAL STEEL (IBC 1707.2 & 1708.3)					
VISUAL INSPECTION PRIOR TO WELDING	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
VISUAL INSPECTION DURING WELDING	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
VISUAL INSPECTION AFTER WELDING	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT WELDS ARE CLEAN; WELDER IDENTIFICATION IS LEGIBLE; SIZE, LENGTH AND LOCATION OF WELDS; VERIFY THAT WELDS MEET ACCEPTANCE CRITERIA; PLACEMENT OF REINFORCEMENT FILETS; REMOVAL OF BACKING BARS AND WELD TABS AS REQUIRED; AND REPAIR ACTIVITIES (SEE SECTION Q5.1 OF AISC 341-05).
NONDESTRUCTIVE TESTING	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
INSPECTION PRIOR TO BOLTING	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
INSPECTION DURING BOLTING	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	
INSPECTION AFTER BOLTING	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	DOCUMENT ACCEPTED AND REJECTED CONNECTIONS (SEE SECTION Q5.3 OF AISC 341-05).
INSTALLATION OF DRAG STRUT AND ROD	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	DETAIL 8/S4.5
INSTALLATION OF DRAG STRUT BEAM AND WT ALONG GRID LINE 9	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	DETAIL 5/S4.6, 6/S4.6, 1/S4.7, 2/S4.7

COLD-FORMED STEEL LIGHT-FRAME CONSTRUCTION (IBC 1704.3.4, 1706.3 & 1707.4)					
ITEM	FREQUENCIES		DETAIL DESCRIPTION		
STUD WALL, RAFTER AND JOIST CONSTRUCTION AT CANOPIES	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT PROPER SCREW ATTACHMENT, BOLTING, ANCHORING AND OTHER FASTENING HAS OCCURRED AND INSTALLATION CONFORMS TO APPROVED SHOP DRAWINGS.
TRUSSES	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	VERIFY THAT TEMPORARY AND PERMANENT TRUSS BRACING IS INSTALLED IN ACCORDANCE WITH APPROVED TRUSS PACKAGE. PERFORMED BY CODE INSPECTION FIRM.

SOILS CONSTRUCTION (IBC 1704.7)					
ITEM	FREQUENCIES		DETAIL DESCRIPTION		
VERIFY SUBGRADE IS ADEQUATE TO ACHIEVE DESIGN BEARING CAPACITY	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	PRIOR TO PLACEMENT OF CONCRETE.
VERIFY EXCAVATIONS EXTEND TO PROPER DEPTH AND MATERIAL	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	PRIOR TO PLACEMENT OF COMPACTED FILL OR CONCRETE.
VERIFY THAT SUBGRADE HAS BEEN APPROPRIATELY PREPARED PRIOR TO PLACING COMPACTED FILL	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	PRIOR TO PLACEMENT OF COMPACTED FILL.
PERFORM CLASSIFICATION AND TESTING OF COMPACTED FILL MATERIALS	<input type="checkbox"/>	CONTINUOUS	<input checked="" type="checkbox"/>	PERIODIC	ALL MATERIALS SHALL BE CHECKED AT EACH LIFT FOR PROPER CLASSIFICATIONS AND GRADATIONS (NOT LESS THAN ONCE FOR EACH 10,000FT ² OF SURFACE AREA).
VERIFY PROPER MATERIALS, DENSITIES AND LIFT THICKNESSES DURING PLACEMENT AND COMPACTION	<input checked="" type="checkbox"/>	CONTINUOUS	<input type="checkbox"/>	PERIODIC	

QUALITY ASSURANCE PROGRAM NOTES:

- THE QUALITY ASSURANCE PROGRAM IS PREPARED AS A CONDITION FOR PERMIT ISSUANCE IN ACCORDANCE WITH THE FLORIDA STATE BUILDING CODE, 6TH EDITION (2017).
 - ANY DISCREPANCIES OR DEVIATION FROM THE CONSTRUCTION DOCUMENTS SHALL BE BROUGHT TO AN IMMEDIATE ATTENTION OF THE CONTRACTOR FOR CORRECTIONS. IF SUCH DISCREPANCIES OR DEVIATIONS ARE NOT CORRECTED, THEN THEY SHALL BE BROUGHT TO THE ATTENTION OF THE BUILDING OFFICIAL, STRUCTURAL ENGINEER OF RECORD AND ARCHITECT OF RECORD.
 - JOB SITE SAFETY AND MEANS AND METHODS OF CONSTRUCTION ARE SOLELY THE RESPONSIBILITY OF THE CONTRACTOR.
 - MATERIALS AND ACTIVITIES TO BE INSPECTED ARE NOT TO INCLUDE THE CONTRACTOR'S EQUIPMENTS OR METHODS USED TO ERECT OR INSTALL THE MATERIALS LISTED.
 - THE CONTRACTOR SHALL PROVIDE A QUALITY CONTROL PROGRAM FOR THE CONSTRUCTION REGULATED UNDER THE FLORIDA STATE BUILDING CODE, 5TH EDITION (2014), QUALITY ASSURANCE, AND ITS IMPLEMENTATION DOES NOT RELIEVE THE CONTRACTOR OF ITS RESPONSIBILITIES FOR QUALITY CONTROL OF THE CONSTRUCTION, FOR COMPLIANCE WITH THE PROJECT CONSTRUCTION DOCUMENTS, NOR FOR ANY DESIGN FOR WHICH IT IS RESPONSIBLE.
 - AS FABRICATION AND CONSTRUCTION PROGRESS, INSPECTION REPORTS AND RECORDS OF TESTS AND INSPECTIONS SHALL BE FORWARDED, BY THE APPROPRIATE TESTING AGENCY, TO THE REGISTERED DESIGN PROFESSIONAL (RDP) FOR REVIEW AND APPROVAL. THE ENGINEER SHALL NOTE ANY UNRESOLVED CONSTRUCTION DEFICIENCIES IN WRITING TO THE BUILDING OFFICIAL AND THE ARCHITECT.
 - INSPECTION OF FABRICATORS: WHERE FABRICATION OF STRUCTURAL COMPONENTS OR ASSEMBLIES IS BEING PERFORMED IN AN OFF-SITE FACILITY, THE INSPECTOR SHALL VERIFY THAT FABRICATORS DESIGNATED FOR THE PROJECT MAINTAIN COMPLETE AND SUFFICIENT QUALITY CONTROL PROCEDURES THAT ASSURE THE FABRICATOR'S ABILITY TO SPECIAL INSPECTIONS REQUIRED BY SECTION 1704 ARE NOT REQUIRED WHERE WORK IS DONE ON THE PREMISES OF THE FOLLOWING CERTIFIED FABRICATORS:
 - A FABRICATOR OF STRUCTURAL STEEL THAT IS CERTIFIED BY THE AMERICAN INSTITUTE OF STEEL CONSTRUCTION INC.'S FABRICATOR CERTIFICATION PROGRAM.
 - A FABRICATOR OF PRECAST CONCRETE THAT IS CERTIFIED BY THE PRECAST/PRESTRESSED CONCRETE INSTITUTE'S PLANT CERTIFICATION PROGRAM. THIS WAIVER DOES NOT ELIMINATE STRUCTURAL INSPECTION DURING FABRICATION.
- THE QUALITY ASSURANCE PROGRAM IS PREPARED AS A CONDITION FOR PERMIT ISSUANCE IN ACCORDANCE WITH THE DURING FABRICATION THE AGENT SHALL CONFIRM THAT THE FABRICATOR IS SUITABLY EXECUTING ITS QUALITY CONTROL PROCEDURES AND PRODUCING A PRODUCT THAT CONFORMS TO THE CONSTRUCTION DOCUMENTS.




STIPULATION FOR REUSE: THE DRAWING WAS PREPARED FOR THE PROJECT AND IS NOT TO BE REUSED FOR ANY OTHER PROJECT WITHOUT THE WRITTEN CONSENT OF THE ENGINEER. THE USER OF THIS DRAWING FOR ANY OTHER PROJECT SHALL BE RESPONSIBLE FOR OBTAINING THE NECESSARY PERMISSIONS FROM THE ORIGINAL ENGINEER. THE ENGINEER'S REPRODUCTION OF THIS PROJECT IS NOT AUTHORIZED AND MAY BE CONSIDERED AS A VIOLATION OF THE LAW.

Cumberland
 Store # TBD
 VSH # TBD
 Oracle # FL8312
 SUNRISE & NW 4TH AVE
 FORT LAUDERDALE, FL 33311
 JOB NUMBER: 41-17-00410

ISSUE BLOCK		
1	90% CDs	05/10/19
2	100% SET	06/14/19
3	90% AIM 4.0	08/14/19
4	100% AIM 4.0	09/11/19

CHECKED BY: GGB
 DRAWN BY: AHM



SPECIAL INSPECTION NOTES

SHEET: **S003**

9/1/2019 1:34:48 PM
 C:\Users\mcmahon\Documents\2019 Rev\Projects\FORT LAUDERDALE\117-00410_ISSUE_BLOCK_L4_S003_V19.dwg: mcmahon
 2020 SPECIAL INSPECTION NOTES (REV. 04/17)