

- J. WHERE CONDUITS PASS THROUGH A BUILDING EXPANSION JOINT, PROVIDE GALVANIZED EXPANSION FITTINGS WITH BONDING JUMPERS.
- K. MINIMUM CONDUIT SIZE SHALL BE 3/4" FOR INTERIOR WORK, 1" FOR EXTERIOR WORK.
- L. PROVIDE MINIMUM 210# TEST NYLON PULL CORD AND NYLON BUSHINGS IN ALL EMPTY RACEWAYS.
- M. LIQUID-TIGHT METAL CONDUIT SHALL ONLY BE USED FOR FINAL CONNECTIONS TO EQUIPMENT AND ALL OTHER ROTATING AND VIBRATING EQUIPMENT, MAXIMUM LENGTH OF 3'-0".
- N. FLEXIBLE METAL CONDUIT, MINIMUM SIZE 3/8", SHALL ONLY BE USED FOR FINAL CONNECTION TO LIGHTING FIXTURES, MAXIMUM LENGTH OF 6'-0".
- O. PROVIDE PULL BOXES, SUCH THAT NO SINGLE CONDUIT RUN HAS BENDS IN EXCESS OF 360°. PULL BOXES SHALL BE SUITABLE AND APPROVED FOR THE INTENDED USE. WHERE CONDUITS PASS UNDER PAVED AREAS, THEY SHALL BE RGS.
- P. ALL CONDUIT BENDS/ELBOWS EMERGING FROM UNDERGROUND SHALL BE IMC AND SHALL EXTEND A MINIMUM OF 18" BELOW GRADE.
- Q. ALL UNDERGROUND RACEWAYS SHALL BE THOROUGHLY COATED WITH TWO COATS OF ASPHALTUM BITUMASTIC.
- R. ALL CONDUITS INSTALLED UNDERGROUND OR IN CONCRETE SHALL HAVE JOINTS MADE WATERTIGHT BY USE OF POLYETRA-FLUOROETHYLENE TAPE.
- S. THE USE OF AC OR NM CABLE IS NOT PERMITTED.
- T. MC CABLE MAY ONLY BE UTILIZED WHERE PERMITTED BY CODE AND IT SHALL ONLY BE ALLOWED WHERE CONCEALED BEHIND HARD WALLS AND HARD CEILINGS. MC CABLE SHALL NOT BE EXPOSED.

- 3. **OUTLET BOXES:**
  - A. LOCATION AND PULL BOXES SHALL BE CODE GAUGE GALVANIZED STEEL. ACCEPTED MANUFACTURERS SHALL BE STEEL CITY (THOMAS & BETTS), RACO, CROUSE-HINDS, APPELTON (EMERSON), OR APPROVED EQUIVALENT.
  - B. OUTLET BOXES SHALL NOT BE MOUNTED BACK TO BACK IN COMMON WALLS.
  - C. ATTACH EMT WITH CONNECTORS HAVING INSULATED THROAT.
  - D. ATTACH BOXES TO STUD WORK USING CADDY BAR STRAPS THAT CONNECT TO TWO ADJACENT STUDS TO PREVENT TWISTING OF BOX IN WALL.
  - E. ALL OUTLET BOXES (INCLUDING TELEPHONE, CABLE TV, AND COMPUTER) SHALL HAVE COVER PLATES, BLANK IF NOT USED.
  - F. ALL EXTERIOR BOXES SHALL BE WATER-TIGHT.
  - G. ALL BOXES IN SHIELDED CONSTRUCTION (I.E. X-RAY ROOMS, ETC.) SHALL BE LEAD BACKED TYPE.

- 4. **CONDUCTORS:**
  - A. CONDUCTORS SHALL BE MANUFACTURED BY SOUTHWIRE (SIMPULL), ENCORE (SUPERSLICK), UNITED COPPER (SLK), CERRO (SLP), OR APPROVED EQUAL. "PRE-LUBRICATED" BY THE MANUFACTURER.
  - B. ALL CONDUCTORS SHALL BE COPPER, RATED 75° C WET/DRY EXCEPT WHERE OTHERWISE NOTED OR REQUIRED BY U.L. OR OTHER CODES.
  - C. ALL CONDUCTORS SHALL BE SINGLE INSULATED CONDUCTOR. THHN/THWN-2. SIZES #10 AWG AND SMALLER SHALL BE SOLID. SIZES #8 AWG AND LARGER SHALL BE STRANDED.
  - D. BRANCH CIRCUITS SHALL NOT BE SMALLER THAN #12 AWG. CONTROL WIRING MAY BE #14 AWG.
  - E. CONDUCTORS SHALL BE COLOR CODED BLACK/RED/BLUE FOR 120/208 VOLT SYSTEMS AND BROWN/ORANGE/YELLOW FOR 277/480 VOLT SYSTEMS FOR A, B, AND C PHASES, RESPECTIVELY. NEUTRAL SHALL BE WHITE FOR 120/208 VOLT SYSTEMS AND NATURAL GRAY FOR 277/480 VOLT SYSTEMS. GROUND CONDUCTOR SHALL BE GREEN ON ALL SYSTEMS. ALL CONDUCTOR SIZES SHALL HAVE COLOR-CODED INSULATION. THE USE OF COLORED TAPE ON LARGER WIRE SIZES SHALL NOT BE ALLOWED.
  - F. INSULATION SHALL BE DUAL RATED TYPE THHN/THWN-2 FOR FEEDERS AND BRANCH CIRCUITS. FIXTURE TAPS SHALL BE #12 THHN/THWN-2 IN FLEX WITH GREEN #12 AWG GROUNDING CONDUCTOR.
  - G. ALL CONDUCTORS SHALL BE IN CONDUIT.
  - H. WIRING TO LIGHTING FIXTURES SHALL BE AS REQUIRED BY UL LABEL.
  - I. MULTI-WIRE BRANCH CIRCUITS SHALL NOT BE ALLOWED.
  - J. JOINTS IN #10 AWG AND SMALLER SHALL BE MADE UP WITH CRIMPED CONNECTORS WITH INSULATING CAPS (NO TAPE) OR WIRENUTS (MAXIMUM OF 3 CONDUCTORS UNDER ANY CONNECTOR OR WIRENUT). LARGER WIRE SHALL USE SPLIT BOLTS OR BOLTED CLAMPS.
  - K. ALL WIRING LUGS THROUGHOUT THE PROJECT, INCLUDING, BUT NOT LIMITED TO, BREAKERS, PANELBOARD/SWITCHBOARD LUGS, SAFETY SWITCH LUGS, MOTOR STARTER LUGS, TRANSFORMERS LUGS, WIRING DEVICE TERMINALS, AND ALL EQUIPMENT LUGS/TERMINALS SHALL BE RATED FOR USE WITH 75 DEGREE INSULATED CONDUCTORS AT THEIR 75 DEGREE AMPACITY AND SHALL BE SIZED AND SELECTED TO MATCH THE CONDUCTOR SIZE AND MATERIAL.
  - L. CIRCUIT JOINTS SHALL NOT BE MADE ON DEVICE TERMINALS.
  - M. WIRE WITHIN PANELBOARDS SHALL BE NEATLY TRAINED, SQUARED, BUNCHED, AND TAGGED.
  - N. ALL SYSTEM FURNITURE CONNECTIONS SHALL COMPLY WITH NEC 605.
  - O. GROUND ALL EQUIPMENT PER NEC ARTICLE 250. BOND WHERE CONDUITS ENTER ENCLOSURES THROUGH CONCENTRIC KNOCKOUTS. ALL FLEX, INCLUDING FIXTURE TAPS, SHALL INCLUDE GREEN GROUNDING CONDUCTOR, #12 AWG MINIMUM. PROVIDE GREEN INSULATED EQUIPMENT GROUNDING CONDUCTOR IN EACH CONDUIT AND FOR EACH CIRCUIT, SIZED PER NEC 250-122.
  - P. ALL CONDUCTORS INSTALLED IN VERTICAL RACEWAYS SHALL BE SUPPORTED AT INTERVALS AS REQUIRED PER NEC 300-19.
  - Q. THE ELECTRICAL CONTRACTOR SHALL FOLLOW AND APPLY THE TABLE BELOW, REGARDLESS WHAT THE PANEL SCHEDULE INDICATES, FOR SIZING ALL 120V & 277V, 20 AMP BRANCH CIRCUITS (COPPER CONDUCTORS) TO ALLOW A MAXIMUM OF 3% VOLTAGE DROP FROM THE CIRCUIT BREAKER TO THE FIRST DEVICE ON THE BRANCH CIRCUIT AND ACHIEVE A MAXIMUM OF 5% VOLTAGE DROP ACROSS THE ENTIRE BRANCH CIRCUIT:

VOLTAGE	CONDUCTOR LENGTH*	BRANCH CIRCUIT
120	0' - 50'	#12
120	51' - 90'	#10
120	91' - 140'	#8
120	141' - 255'	#6
277	0' - 125'	#12
277	126' - 200'	#10
277	201' - 330'	#8
277	331' - 525'	#6

\* - THE LENGTH IS MEASURED FROM THE CIRCUIT BREAKER TO THE FIRST DEVICE WHICH THE BRANCH CIRCUIT SERVES. WHERE THE DISTANCE EXCEEDS ABOVE, CONSULT WITH THE ENGINEER.

R. ALL BRANCH CIRCUIT CONDUCTORS FROM ISOLATED POWER SOURCES SHALL BE INSTALLED IN CONDUIT AND SHALL BE TYPE XHHW-2, COLOR CODED ORANGE FOR CONDUCTOR #1, YELLOW FOR CONDUCTOR #2, AND YELLOW FOR CONDUCTOR #3.

- 5. **WIRING DEVICES:**
  - A. WIRING DEVICES SHALL BE SPECIFICATION GRADE, MINIMUM, EQUAL TO COOPER QUALITY INSTALLED BELOW OR AS MANUFACTURED BY HUBBELL, LEGRAND-PASS & SEYMOUR, TITAN, OR APPROVED EQUAL, UNLESS OTHERWISE NOTED.

SWITCHES (120/277V) SHALL BE AS FOLLOWS:

SINGLE-POLE 20 AMP	COOPER AH11
DOUBLE-POLE 20 AMP	COOPER AH21
THREE-WAY 20 AMP	COOPER AH12
FOUR-WAY 20 AMP	COOPER AH22

DUPLEX RECEPTACLES SHALL HAVE NYLON COVER AND SHALL BE AS FOLLOWS:

15 AMP DUPLEX	COOPER S252
20 AMP DUPLEX	COOPER S352
15 AMP DUPLEX GFCI	COOPER SGF15F
20 AMP DUPLEX GFCI	COOPER SGF20F

THE PART NUMBER ABOVE ARE FOR WIRING DEVICE TYPE ONLY. SEE BELOW FOR WIRING DEVICE COLOR AND PLATE MATERIAL/COLOR.

- B. SEE MOUNTING HEIGHT ELEVATION DETAIL FOR STANDARD MOUNTING HEIGHTS OF ALL DEVICES, UNLESS OTHERWISE NOTED.
- C. ALL WIRING DEVICES (SWITCHES AND RECEPTACLES) SHALL BE GRAY, UNLESS OTHERWISE NOTED. ALL COVER PLATES SHALL BE 302 STAINLESS STEEL. COVER PLATES IN MASONRY WALLS SHALL BE OVERSIZE TYPE. OR ALL WIRING DEVICES (SWITCHES AND RECEPTACLES) AND PLATES SHALL MATCH EXISTING IN MATERIAL AND COLOR, UNLESS OTHERWISE NOTED. COVER PLATES IN MASONRY WALLS SHALL BE JUMBO SIZE. OR THE COLOR OF ALL WIRING DEVICES (SWITCHES AND RECEPTACLES) SHALL BE AS DIRECTED BY THE ARCHITECT, UNLESS OTHERWISE NOTED. ALL COVER PLATES SHALL BE 302 STAINLESS STEEL. COVER PLATES IN MASONRY WALLS SHALL BE JUMBO SIZE.
- D. ALL WIRING DEVICES FED FROM THE EMERGENCY POWER SYSTEM SHALL BE RED.

- E. ALL WIRING DEVICES FED FROM A UPS SOURCE SHALL BE BLUE.
- F. EACH DUPLEX RECEPTACLE INDICATED TO BE ON A DEDICATED CIRCUIT SHALL BE 20 AMP TYPE.
- G. ADJACENT DEVICES SHALL HAVE A COMMON WALL PLATE.
- H. WEATHERPROOF COVERS SHALL BE "WHILE-IN-USE" SO PLUGS MAY BE INSTALLED WITHOUT CONDUIT SHALL ONLY BE USED FOR FINAL CONNECTIONS TO EQUIPMENT AND ALL OTHER ROTATING AND VIBRATING EQUIPMENT, MAXIMUM LENGTH OF 3'-0".
- I. A MAXIMUM OF 10 GENERAL PURPOSE RECEPTACLES SHALL BE ON EACH BRANCH CIRCUIT.
- J. DIMMERS SHALL BE LINEAR SLIDE, PRESENT ON/OFF, SQUARE LAW DIMMING, W/RFI FILTERING AND VOLTAGE COMPENSATION CIRCUITING.
- K. ALL WALL MOUNTED OCCUPANCY/VACANCY SENSORS/SWITCHES SHALL BE INSTALLED WITH AN EQUIPMENT GROUNDING CONDUCTOR.
- L. GROUND-FAULT CIRCUIT INTERRUPTER (GFCI) PROTECTION FOR PERSONNEL SHALL BE PROVIDED FOR ALL LOCATIONS PER NEC 210.8. INSTALLED IN A READILY ACCESSIBLE LOCATION. WHERE A DEVICE LOCATION IS NOT ACCESSIBLE, THE GFCI PROTECTION SHALL BE PROVIDED WITH THE BREAKER SERVING THE DEVICE.
- M. ALL GFCI RECEPTACLES SHALL HAVE AUTO-MONITORING / SELF-TEST FUNCTION AND REVERSE LINE-LOAD MISFIRE FUNCTION AND MEET ALL REQUIREMENTS OF UL 943 (LATEST EDITION).

- 6. **SUPPORTS:**
  - A. ALL EQUIPMENT SHALL BE ADEQUATELY SUPPORTED FROM STRUCTURE.
  - B. INSERTS IN MASONRY SHALL BE LEAD OR FIBER IN DRILLED HOLES, OR CAST IN PLACE.
  - C. NAILS OR POWDER ACTUATED FASTENERS SHALL NOT BE USED.
  - D. EMT/CB/CBGS SUPPORTS SHALL BE A MAXIMUM OF 8'-0" APART AND A MAXIMUM OF 3'-0" FROM BOXES.
  - E. LIGHTING FIXTURES MOUNTED IN OR ON CEILING SHALL BE SUPPORTED FROM STRUCTURE VIA 12 GAUGE STEEL WIRE. PROVIDE A MINIMUM OF FOUR WIRES, ONE ATTACHED TO EACH CORNER OF LAY-IN FIXTURES. RECESSED DOWNLIGHT FIXTURES SHALL BE SUPPORTED THE SAME. DO NOT SUPPORT RACEWAY OR FIXTURES FROM CEILING GRID OR DUCT WORK. USE U.L. LISTED GRID CLIPS ON ALL LAY-IN FIXTURES.

- 7. **PAINTING:**
  - A. SUITABLE FINISH COAT SHALL BE PROVIDED FOR ALL EQUIPMENT, PANEL TUBS, COVERS, ETC. SHALL BE PRIMED AND ENAMELED TO BLEND WITH ADJACENT SURFACES, OR SHALL BE MANUFACTURER'S STANDARD COLOR BAKED ENAMEL FINISH, OR AS DIRECTED BY THE ARCHITECT.
  - B. CONTRACTOR TO PAINT WHERE EXISTING EXPOSED PANELBOARDS, SURFACE RACEWAY, SURFACE BOXES, ETC. HAVE BEEN REMOVED DURING THE DEMOLITION PHASE, EITHER FOR TEMPORARY WORK OR PERMANENTLY.

- 8. **TELECOMMUNICATIONS:**
  - A. FURNISH A COMPLETE TELEPHONE CONDUIT SYSTEM AS INDICATED ON THE DRAWINGS.
  - B. TELECOMMUNICATION OUTLETS SHALL CONSIST OF A 4" SQUARE DEEP BOX WITH SINGLE GANG PLASTER RING. PROVIDE BLANK PLATE WITH KNOCKOUTS FOR OUTLETS, AS PERMANENT COVERS WILL BE PROVIDED BY A SEPARATE INSTALLER.
  - C. PROVIDE MINIMUM 1" RACEWAY, UNLESS OTHERWISE NOTED, FROM EACH BOX TO ABOVE NEAREST ACCESSIBLE CEILING SPACE FOR J-HOOK SYSTEM OR TO CABLE TRAY AS APPLICABLE. PROVIDE MINIMUM 210# TEST NYLON PULL CORD AND NYLON BUSHINGS IN ALL EMPTY RACEWAYS.
  - D. PROVIDE RACEWAYS FOR ALL EXTERIOR AND/OR EXPOSED LOCATIONS.
  - E. PROVIDE GROUNDING FOR ALL TELEPHONE/DATA SYSTEMS AND EQUIPMENT PER REQUIREMENTS AND SPECIFICATIONS PROVIDED BY THE OWNERS DESIGNATED VENDOR.
  - F. ALL LOW-VOLTAGE CABLING SHALL BE PLENUM RATED.
  - G. CONTRACTOR SHALL FURNISH AND INSTALL A #6 AWG GREEN INSULATED COPPER WIRE IN CONDUIT FROM THE MAIN ELECTRICAL GROUNDING BAR TO TELECOMMUNICATIONS GROUNDING BUS BAR.
  - H. PROVIDE MOUNTING BACKBOARDS FOR COMMUNICATIONS EQUIPMENT. BACKBOARDS SHALL BE OF 3/4" TYPE AC EXTERIOR PLYWOOD, PAINTED BOTH SIDES AND ALL EDGES WITH 2 COATS OF GRAY FLAME RETARDANT PAINT.
  - I. VERIFY SITE LOCATION OF TELEPHONE SERVICES WITH APPROPRIATE VENDOR, PRIOR TO SUBMITTING BID. TELEPHONE SERVICE CONDUITS SHALL BE PROVIDED TO THE PROPERTY LINE OR POINT AS DIRECTED BY THE LOCAL UTILITY.
  - J. ALL CABLE TRAYS SHALL BE 12" WIDE X 4" DEEP, BASKET TYPE.
  - K. CABLE TRAY SHALL SUPPORT TELE/DATA, INTERCOM, CATV, CCTV AND SECURITY CABLING.
  - L. THE SCOPE OF TELECOMMUNICATIONS DESIGN SHOWN ON THESE DRAWINGS INCLUDES ALL DEVICES, CABLES, AND PATHWAYS IN THE HORIZONTAL DISTRIBUTION SYSTEM. PATHWAYS ONLY, ARE SHOWN FOR THE BACKBONE DISTRIBUTION SYSTEMS TO ALL TELECOMMUNICATION ROOMS, AND/OR ENCLOSURES. BACKBONE MEDIA, CONNECTIONS BETWEEN THE BACKBONE AND HORIZONTAL DISTRIBUTION SYSTEMS AND TELECOMMUNICATIONS EQUIPMENT ARE NOT WITHIN THE SCOPE OF THESE DOCUMENTS. IT IS THE RESPONSIBILITY OF THE TELECOMMUNICATIONS CONTRACTOR TO PROVIDE A "TURN-KEY" SYSTEM BASED ON THE INTENT OF THE DRAWINGS AND SPECIFICATIONS. THIS INCLUDES, BUT IS NOT LIMITED TO: END-BOX, BACKBONE CABLES, STRUCTURAL TAGGING, TELEPHONE/SWITCH, ETC. TERMINATIONS, CROSS CABLING, PATCHING, PUNCH-DOWN TERMINALS, PUNCH-DOWN TERMINATIONS, SURGE PROTECTION, AND WIRELESS ACCESS POINTS WITH MAXIMIZED CONNECTIVITY BASED ON THE CONSTRUCTION MATERIALS USED IN THE BUILDING.

- 9. **LIGHTING FIXTURES:**
  - A. TYPES AND MANUFACTURERS ARE SCHEDULED ON THE PLANS. EQUIVALENT FIXTURES BY OTHERS MAY BE SUBMITTED ONLY AS INDICATED ON THE PLANS AND ARE SUBJECT TO THE APPROVAL OF THE OWNER AND ENGINEER.
  - B. ALL FIXTURES SHALL BE U.L. LISTED AND LABELED FOR USE.
  - C. LAMPS SHALL BE GENERAL ELECTRIC (GE) OR SYLVANIA UNLESS OTHERWISE NOTED IN THE LIGHTING FIXTURE SCHEDULE OR OTHERWISE NOTED. ALL FIXTURES SHALL BE EQUIPPED WITH LAMPS.
  - D. BALLASTS SHALL BE AS INDICATED IN THE LIGHTING FIXTURE SCHEDULE OR AS OTHERWISE NOTED.
  - E. ALL FIXTURES SHALL BE PROVIDED FOR PROPER VOLTAGE BASED ON THE CIRCUIT ASSIGNMENT INDICATED ON THE PLANS.
  - F. CATALOG NUMBER - GENERAL IDENTIFICATION OF FIXTURES ONLY: ALL RELATED PARTS, SUCH AS POWER RINGS, JUNCTION BOXES, LOUVERS, SHIELDS, MOUNTING STEMS, CANOPIES, COVERS, HARBORWARE, ACCESSORIES, ETC., TO FIT THEM PROPERLY TO THE CONSTRUCTION SHALL BE FURNISHED AND INSTALLED BY THIS CONTRACTOR. CONTRACTOR SHALL PROVIDE SUITABLE DIM AND APPURTENANCES TO MOUNT FIXTURES IN TYPE OF CEILING OR WALL AS SPECIFIED IN ARCHITECTURAL FINISH SCHEDULES REGARDLESS OF CATALOG NUMBER GIVEN.
  - G. ALL FIXTURES SHALL BE GROUNDED PER THE NEC.
  - H. FIXTURES CONNECTED WITH FLEX TO THE RIGID RACEWAY PORTION OF THE WIRING SYSTEM SHALL CARRY A GREEN BONDING JUMPER WITHIN THE FLEX. THE JUMPER SHALL BE FASTENED TO BOTH THE FIXTURE AND THE RACEWAY SYSTEM WITH A STEEL CITY "G" CLIP OR APPROVED EQUIVALENT. PHASE AND GROUND CONDUCTORS RUN IN FLEX SHALL BE #12 AWG MINIMUM. MAXIMUM FLEX LENGTH SHALL BE 6'-0".
  - I. SURFACE-MOUNTED FLUORESCENT FIXTURES INSTALLED ON COMBUSTIBLE MATERIAL SHALL BE MOUNTED AT LEAST 1/4" FROM THE SURFACE OF THE MATERIAL, EXCEPT FOR FIXTURES WHICH ARE PLAINLY MARKED AS U.L. APPROVED FOR MOUNTING DIRECTLY TO SUCH SURFACES.
  - J. MOUNT ALL FIXTURES PLUMB AND SQUARE WITH ROWS ALIGNED.
  - K. FLUORESCENT LUMINAIRES THAT UTILIZE DOUBLE-ENDED LAMPS AND CONTAIN BALLAST(S) THAT CAN BE SERVICED IN PLACE SHALL HAVE A DISCONNECTING MEANS, WHETHER INTEGRAL OR EXTERNAL, TO EACH LUMINAIRE PER NEC 410.130(G).
  - L. SEE ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATION OF FIXTURES.
  - M. CONTRACTOR SHALL COORDINATE FIXTURE TYPE AND TRIM WITH CEILING CONSTRUCTION AND ADJUST ACCORDINGLY WITHOUT ADDITIONAL EXPENSE.
  - N. ALL LIGHTING FIXTURES SHALL BE THERMALLY PROTECTED PER THE NEC.
  - O. FIXTURES IN CONTACT WITH INSULATION SHALL BE IC RATED.
  - P. FOR RECESSED LIGHTING FIXTURES IN FIRE RATED CEILINGS, PROVIDE A MANUFACTURER APPROVED AND LISTED FIRE RATED COVER/ASSEMBLY OVER THE FIXTURE TO MAINTAIN THE INTEGRITY OF THE CEILING FIRE RATING. ANY LIGHTING FIXTURES INSTALLED UNDER THE FIRE RATED CAP SHALL BE SUITABLE FOR THE INSTALLATION.

- 10. **LIGHTING CONTROLS:**
  - A. FURNISH AND INSTALL WHERE SHOWN AN ELECTRONIC TIME CONTROLLER AS MANUFACTURED BY TORK (NSI), PARAGON, INTERMATIC, OR APPROVED EQUAL. CONTACTS SHALL BE SPST OR AS INDICATED, RATED 120/277V AT 20A BALLAST LOAD, AND MINIMUM 30,000 SWITCHING CYCLES. PROVIDE WITH THE NUMBER OF CHANNELS INDICATED (MINIMUM 2 CHANNELS) OR AS REQUIRED TO MEET THE INTENT OF THE DRAWINGS. EACH CHANNEL SHALL BE INDIVIDUALLY PROGRAMMABLE WITH 128 ON-OFF OPERATIONS PER WEEK PLUS FOUR SEASONAL SCHEDULES TO MODIFY THE BASIC PROGRAM AND A HOLIDAY SCHEDULE THAT OVERIDES THE WEEKLY OPERATION. THE CONTROLLER SHALL BE PROVIDED WITH A PHOTOELECTRIC SENSOR, ASTRONOMIC DIAL, AND A BATTERY BACKED-UP, NON-VOLTAILE MEMORY FOR SCHEDULES AND TIME CLOCK.
  - B. LIGHTING CONTACTORS SHALL SWITCH LOADS AT THE VOLTAGE AND AMPERE RATING INDICATED AND SHALL HAVE THE NUMBER OF POLES INDICATED ON THE DRAWINGS OR AS REQUIRED. THE CONTACTOR AND CONTACTS SHALL BE CONTINUOUSLY RATED FOR THE LOAD SERVED, INCLUDING TUNGSTEN FILAMENT, INDUCTIVE, AND HIGH-INRUSH BALLAST LOADS.
  - C. ALL LIGHTING CONTACTORS SHALL BE ELECTRICALLY HELD AND BE INSTALLED IN A NEMA 1 ENCLOSURE, UNLESS OTHERWISE NOTED.

- 11. **EQUIPMENT IDENTIFICATION:**
  - A. PROVIDE ENGRAVED PHENOLIC NAMEPLATES FOR ALL ELECTRICAL EQUIPMENT SUPPLIED FOR THE PROJECT, INCLUDING BUT NOT LIMITED TO, WIRING TROUGHS, SAFETY SWITCHES, DISCONNECTS, TRANSFORMERS, PANELBOARDS, SWITCHBOARDS, SWITCHGEARS, MOTOR CONTROL CENTERS (MCC), BUSWAYS, GENERATORS, AUTOMATIC TRANSFER SWITCHES (ATS), UNINTERRUPTIBLE POWER SUPPLY (UPS), POWER DISTRIBUTION UNITS (PDU), FLOOR/REMOTE DISTRIBUTION CABINETS (FDC/RDC), STATIC TRANSFER SWITCHES (STS), ETC. NAMEPLATE SHALL INDICATE THE DEVICE NAME, SYSTEM VOLTAGE (VOLTAGE/PHASE/WIRE), AND UPSTREAM DEVICE AND CIRCUIT. PROVIDE NAMEPLATES FOR CIRCUIT BREAKERS IN SWITCHGEARS, SWITCHBOARDS AND DISTRIBUTION PANELS.
  - B. NAMEPLATE COLORS SHALL BE AS FOLLOWS:

120/208V EQUIPMENT	BLUE SURFACE WITH WHITE CORE
277/480V EQUIPMENT	BLACK SURFACE WITH WHITE CORE
EMERGENCY SYSTEMS	GREEN SURFACE WITH WHITE CORE
FIRE ALARM SYSTEMS	BRIGHT RED SURFACE WITH WHITE CORE
SECURITY SYSTEMS	BURGUNDY SURFACE WITH WHITE CORE
TELEPHONE SYSTEMS	ORANGE SURFACE WITH WHITE CORE
DATA SYSTEMS	BROWN SURFACE WITH WHITE CORE
TV SYSTEMS	PURPLE SURFACE WITH WHITE CORE
PAGING SYSTEMS	WHITE SURFACE WITH BLACK CORE

- C. NAMEPLATES UP TO 8 SQUARE INCHES SHALL NOT BE LESS THAN 1/16" THICK. NAMEPLATES LARGER THAN 8 SQUARE INCHES SHALL NOT BE LESS THAN 1/8" THICK.
- D. LETTERING HEIGHT SHALL BE 1/2" MINIMUM.
- E. NAMEPLATES SHALL BE ATTACHED WITH SELF-DRILLING/SELF-TAPPING SCREWS. EXCEPT RIVETS SHALL BE USED WHERE END OF SCREW IS NOT PROTECTED. QUANTITY AS FOLLOWS:

UP TO 5 SQUARE INCHES:	2 SCREWS
5 TO 12 SQUARE INCHES:	4 SCREWS
ABOVE 12 SQUARE INCHES:	6 SCREWS

- 12. **DISCONNECTS:**
  - A. DISCONNECT SWITCHES SHALL BE HEAVY-DUTY TYPE IN NEMA 1 ENCLOSURES, UNLESS OTHERWISE NOTED, FUSED OR NON-FUSED AS INDICATED. SWITCHES SHALL HAVE REJECTION-TYPE FUSE CLIPS. SWITCHES SHALL BE BY Eaton, SQUARE-D, GENERAL ELECTRIC, OR APPROVED EQUAL. WHERE FED FROM A LOAD CENTER, GENERAL-DUTY SWITCHES SHALL BE PERMITTED.
  - B. FUSES LESS THAN 60A SHALL BE CLASS RK5, DUAL-ELEMENT, TIME-DELAY WITH INDICATED.
  - C. FUSES GREATER THAN 60A SHALL BE CLASS J, DUAL-ELEMENT, TIME-DELAY WITH INDICATED.
  - D. A SET OF 3 SPARE FUSES OF EACH SIZE AND TYPE SHALL BE FURNISHED TO THE OWNER.

- 13. **PANELBOARDS:**
  - A. PANELBOARDS SHALL BE PROVIDED AS MANUFACTURED BY Eaton, SQUARE-D, GENERAL ELECTRIC, OR APPROVED EQUAL. ALL NEW EQUIPMENT FOR THE PROJECT SHALL COMPLY WITH THE SAME MANUFACTURER. LOAD CENTER TYPE PANELBOARDS SHALL BE USED WHERE THE PANELBOARD SERVES A DWELLING UNIT.
  - B. ALL BUSSING, INCLUDING NEUTRAL AND GROUND, SHALL BE COPPER.
  - C. ALL BREAKERS SHALL BE AUTOMATIC THERMAL-MAGNETIC, MOLDED CASE, BOLT-ON TYPE, CALIBRATED FOR 40 DEGREE C, OR AMBIENT COMPENSATION, UNLESS OTHERWISE NOTED.
  - D. PANELS SHALL BE FULLY RATED (SEE SERIES AIC RATINGS ALLOWED).
  - E. PANELS SHALL HAVE FULL SIZE EQUIPMENT GROUNDING BARS AND TERMINAL BARS, EXCEPT WHERE INDICATED TO BE 200%.
  - F. ALL PANELBOARD AIR BREAKER LUGS SHALL BE SIZED AND RATED PER THE CONDUCTOR SIZE AND MATERIAL.
  - G. LIGHTING APPLIANCE PANELS (100A-600A) SHALL HAVE FRONT ACCESSIBLE HINGED DOOR-IN-DOOR COVER WITH DEAD FRONT, SHALL BE 20" WIDE MINIMUM WITH MINIMUM 4" WIDE WIRING CUTTERS.
  - H. DISTRIBUTION PANELS (100A-1200A) SHALL HAVE FRONT ACCESSIBLE DEAD FRONT COVERS.
  - I. PROVIDE HANDLE LOCKED DEVICES FOR ALL CIRCUIT BREAKERS CONNECTED TO EMERGENCY, EXIT, NIGHTTIME SAFETY, FIRE ALARM, TELEPHONE BOARDS, AND SECURITY SYSTEMS.
  - J. BREAKERS FOR SWITCHING SHALL BE SWITCHING DUTY (SWD) RATED.
  - K. BREAKERS USED FOR HEATING, AIR-CONDITIONING AND/OR REFRIGERATION SHALL BE HACR RATED.
  - L. GROUND-FAULT CIRCUIT INTERRUPTER (GFCI) PROTECTION FOR PERSONNEL SHALL BE PROVIDED FOR ALL LOCATIONS PER NEC 210.8. INSTALLED IN A READILY ACCESSIBLE LOCATION. WHERE A DEVICE LOCATION IS NOT ACCESSIBLE, THE GFCI PROTECTION SHALL BE PROVIDED WITH THE BREAKER SERVING THE DEVICE.
  - M. ARC-FAULT CIRCUIT INTERRUPTER (AFCI) PROTECTION SHALL BE PROVIDED FOR ALL LOCATIONS PER NEC 210.12, INSTALLED IN A READILY ACCESSIBLE LOCATION. THIS INCLUDES ALL 120V, 15A AND 20A BRANCH CIRCUITS IN DWELLING UNITS, DOORWAYS/STUDENT HOUSING UNITS AND HOTEL/MOTEL GUEST ROOMS/SUITES AS DEMAND BY THE NEC.
  - N. ALL OCCURRENT DEVICES WHICH COMPRISE THE EMERGENCY SYSTEM OR LEGALLY REQUIRED STANDBY SYSTEM SHALL BE SELECTIVELY COORDINATED. THE ELECTRICAL CONTRACTOR SHALL PROVIDE MANUFACTURER DOCUMENTATION INDICATING COMPLIANCE WITH THE SELECTIVE COORDINATION REQUIREMENTS PER THE NEC.
  - O. ALL PANELBOARDS SHALL HAVE METAL DIRECTORY FRAME. FOR EACH PANELBOARD, PROVIDE TYPED CIRCUIT DIRECTORY PER NEC 408.4. SPARE CIRCUIT BREAKERS SHALL BE LABELED SPARE AND IN THE OFF POSITION.

- 14. **FIRE STOPPING:**
  - A. ALL PENETRATIONS OF RATED ASSEMBLIES SHALL BE SEALED WITH RATED MATERIALS MEETING ASTM E-84.
  - B. PROVIDE FIRESTOPPING DEVICE(S) OR SYSTEM(S) WHICH HAVE BEEN TESTED AND LISTED AS COMPLYING WITH ASTM E-84. INSTALL THE DEVICE(S) OR SYSTEM(S) IN ACCORDANCE WITH THE CONDITIONS OF THEIR LISTING. PROVIDE THE APPROPRIATE DEVICE(S) OR SYSTEM(S) WITH AN 'F' RATING EQUAL TO THE RATING OF THE ASSEMBLY BEING PENETRATED.
  - C. DEVICES(S) AND/OR SYSTEM(S) SHALL BE BY HILTI, 3M OR EQUIVALENT.

- 18. **ELECTRICAL COORDINATION WITH OTHER TRADES:**
  - A. THE ELECTRICAL CONTRACTOR SHALL CONNECT AND/OR PROVIDE FINAL CONNECTIONS TO ALL EQUIPMENT SUPPLIED BY OTHERS APPLICABLE TO THE PROJECT, INCLUDING BUT NOT LIMITED TO, MECHANICAL, PLUMBING, FIRE PROTECTION AND SUPPRESSION, OWNER FURNISHED, KITCHEN, LABORATORY, ETC. UNLESS OTHERWISE NOTED.
  - B. THE ELECTRICAL CONTRACTOR SHALL COORDINATE ALL CONNECTIONS PRIOR TO ROUGH-IN USING APPROVED CATALOG SHEETS AND SHOP DRAWINGS.
  - C. THE ELECTRICAL CONTRACTOR SHALL PROVIDE AND INSTALL ALL MANUAL MOTOR STARTER SWITCHES, DISCONNECT SWITCHES, RECEPTACLES, ETC. TO MECHANICAL AND PLUMBING EQUIPMENT. ALL STARTERS, OTHER THAN MANUAL STARTER SWITCHES, SHALL BE PROVIDED BY OTHERS, BUT INSTALLED BY THE ELECTRICAL CONTRACTOR.
  - D. ALL DISCONNECT SWITCHES AND FUSE SIZES SHALL BE COORDINATED WITH SHOP DRAWINGS PRIOR TO ORDERING OR INSTALLING. ANY EQUIPMENT INSTALLED INCORRECTLY BECAUSE OF LACK OF COORDINATION WILL BE REMOVED AND INSTALLED CORRECTLY AT THE EXPENSE OF THE ELECTRICAL CONTRACTOR.
  - E. THE ELECTRICAL CONTRACTOR SHALL COORDINATE ALL CONDUIT RUNS AND LIGHT FIXTURE LOCATIONS ABOVE THE CEILING WITH OTHER TRADES PRIOR TO INSTALLATION.
  - F. ALL DUCT SMOKE DETECTORS SHALL BE PROVIDED AND CONNECTED BY THE ELECTRICAL CONTRACTOR, BUT INSTALLED BY THE MECHANICAL CONTRACTOR.
  - G. THE ELECTRICAL CONTRACTOR SHALL PROVIDE ALL NECESSARY OUTLETS FOR HEAT TAPE CONNECTIONS FOR MECHANICAL SYSTEMS. PROVIDE CLASS 30mA GFI PROTECTION ON THE BREAKER SERVING THE HEAT TAPE.
  - H. THE ELECTRICAL CONTRACTOR SHALL PROVIDE 120V POWER AT EACH HVAC UNIT HAVING A CONTROLS POWER SUPPLY. CIRCUITS SHALL BE DEDICATED 2P SERVING A MAXIMUM OF 10 HVAC UNITS PER CIRCUIT. COORDINATE ALL LOCATIONS WITH THE MECHANICAL CONTRACTOR.

- 19. **DEMOLITION NOTES:**
  - A. PARTIAL AND TOTAL DEMOLITION OF PORTIONS SHALL BE PERFORMED ALONG WITH ALL NECESSARY MODIFICATION TO THAT PORTION OF THE EXISTING BUILDING WHICH SHALL REMAIN SO THAT IT CONTINUES TO FUNCTION UNAFFECTED BY THE DEMOLITION AND ASSOCIATED NEW CONSTRUCTION.
  - B. WHERE IS REQUIRED AS PART OF THE CONTRACT DOCUMENTS, THE DRAWINGS INDICATE THE GENERAL SCOPE OF WORK INVOLVED. HOWEVER, THE ELECTRICAL CONTRACTOR SHALL PERFORM WORK OUTSIDE THE AREA SHOWN AS IS NECESSARY TO COMPLY WITH THE INTENT OF THIS SECTION. THE ELECTRICAL CONTRACTOR SHALL FAMILIARIZE THEMSELVES WITH THE EXISTING BUILDING AND WITH THE WORK OF ALL OTHER TRADES AND INCLUDE ALL WORK NECESSARY TO COMPLY WITH THE INTENT OF THE DEMOLITION.
  - C. IT SHALL BE UNDERSTOOD THAT FIELD CONDITIONS MAY BE ENCOUNTERED DURING THE EXECUTION OF THIS CONTRACT WHICH WILL REQUIRE EXTENSION OR RELOCATION OF EXISTING SYSTEMS OR EQUIPMENT WHICH ARE NOT SPECIFICALLY SHOWN ON THE DRAWINGS, BUT WHICH ARE REQUIRED TO MEET THE STATED INTENT THAT THE BUILDING CONTINUE TO FUNCTION UNAFFECTED BY THE DEMOLITION AND ASSOCIATED NEW CONSTRUCTION. THE ELECTRICAL CONTRACTOR SHALL INCLUDE SUCH WORK AS WOULD NORMALLY BE EXPECTED IN AN EXISTING BUILDING OF THIS AGE AND TYPE.
  - E. THE ELECTRICAL CONTRACTOR SHALL PROVIDE ALL TOOLS, EQUIPMENT, LABOR, ETC. IN ORDER TO ACCOMPLISH THE DEMOLITION PORTION OF THE PROJECT.
  - F. THE DEMOLITION OF CERTAIN AREAS OF THE EXISTING BUILDING SHALL BE PERFORMED BY THE GENERAL CONTRACTOR. IT SHALL BE THE ELECTRICAL CONTRACTOR'S RESPONSIBILITY TO COORDINATE WITH THE GENERAL CONTRACTOR TO DIFFERENTIATE THE SCOPE OF WORK BETWEEN SEPARATE TRADES.
  - G. THE ELECTRICAL CONTRACTOR SHALL INCLUDE COORDINATION WITH THE GENERAL CONTRACTOR AND SUCH DEMOLITION OF THE EXISTING ELECTRICAL SYSTEMS AS IS NECESSARY SO THAT THE DEMOLITION WORK OF THE GENERAL CONTRACTOR SHALL NOT DAMAGE THOSE PORTIONS OF THE ELECTRICAL SYSTEMS WHICH ARE TO REMAIN IN SERVICE, ARE TO BE REUSED, OR ARE TO BECOME THE PROPERTY OF THE OWNER.
  - H. TURN OVER TO OWNER, UPON REQUEST OR AS NOTED, ITEMS SHOWN AS BEING REMOVED AND NOT REINSTALLED. ITEMS NOT DIRECTED OR REQUESTED TO BE TURNED OVER TO THE OWNER SHALL BE DISPOSED OF BY THE ELECTRICAL CONTRACTOR.
  - I. EQUIPMENT OR MATERIALS WHICH ARE TO BE REUSED OR TURNED OVER TO THE OWNER SHALL BE CAREFULLY REMOVED, CLEANED, AND STORED IN A CLEAN AND DRY AREA. SHOULD THE ELECTRICAL CONTRACTOR ENCOUNTER SUCH EQUIPMENT WHICH IS NOT IN SATISFACTORY CONDITION FOR REUSE AND NOT IN WORKING ORDER, THE ELECTRICAL CONTRACTOR SHALL NOTIFY THE ARCHITECT/ENGINEER IMMEDIATELY.
  - J. DISCONNECT ELECTRICAL SERVICES TO ALL EQUIPMENT REQUIRING REMOVAL. CONDUIT SHALL BE REMOVED BACK TO THE POINT WHERE IT WILL BE CONCEALED AT THE COMPLETION OF THIS CONTRACT. WIRE AND CABLE SHALL BE REMOVED BACK TO THE FIRST OUTLET BOX, CABINET, OR TERMINATION POINT WHICH IS TO REMAIN. CIRCUITS WHICH ARE NOT REUSED SHALL BE REMOVED BACK TO THE SOURCE IN THEIR ENTIRETY.
  - K. REMOVE AND REINSTALL CEILING IN THE EXISTING BUILDINGS AS REQUIRED FOR THE WORK. COORDINATE WITH THE GENERAL CONTRACTOR. IN SUCH AREAS, REMOVE AND REINSTALL ALL ELECTRICAL DEVICES WHICH ARE TO REMAIN IN OR ON THE CEILING.
  - L. WHERE NEW CEILINGS CONFLICT WITH EXISTING ELECTRICAL WORK WHICH IS TO REMAIN, RELOCATE THE ELECTRICAL WORK INVOLVED TO CLEAR THE NEW CONSTRUCTION.
  - M. WHERE NEW WALL OR FLOOR FINISHES CONFLICT WITH EXISTING ELECTRICAL WORK WHICH IS TO REMAIN, RELOCATE THE ELECTRICAL WORK INVOLVED OR PROVIDE BOX EXTENSIONS OR SIMILAR DEVICES AND REINSTALL ON THE NEW FINISH.
  - N. WHERE EXISTING BRANCH CIRCUITS AND SYSTEMS ARE INTERRUPTED BY NEW WORK OR SYSTEMS (ELECTRICAL, MECHANICAL, PLUMBING, FIRE PROTECTION, ETC.), EXTEND AND RECONNECT THOSE EXECUTION OF THIS CONTRACT, PROVIDE TEMPORARY CONNECTIONS UNTIL FINAL CONNECTIONS ARE COMPLETE.

- 20. **TESTING AND DOCUMENTATION:**
  - A. THE ELECTRICAL CONTRACTOR SHALL ENGAGE THE GEAR MANUFACTURER OR ANOTHER INDEPENDENT 3RD PARTY TO PROVIDE A COMPLETE FAULT CURRENT, COORDINATION, AND ARC-FLASH HAZARD ANALYSIS STUDY AND REPORT, COMPLETE WITH ARC-FLASH HAZARD LABELS FOR ALL EQUIPMENT.
  - B. TESTING AND DOCUMENTATION SHALL BE PROVIDED AS FOLLOWS:
    - a. ALL CONDUCTORS SHALL BE MEASURED BEFORE FINAL CONNECTIONS.
    - b. THE GROUND SYSTEM SHALL BE TESTED AND VERIFIED TO BE 25 OHMS OR LESS RESISTANCE-TO-GROUND.
    - c. A PRIMARY INJECTION TEST SHALL BE PERFORMED ON ALL CIRCUIT BREAKERS RATED 225A OR HIGHER.
    - d. GFCI EQUIPPED BREAKERS SHALL BE PERFORMANCE TESTED.
    - e. LIGHTING CONTROL SYSTEMS SHALL BE TESTED FOR PROPER OPERATION OF SETPOINTS.
    - f. GENERATOR TESTING SHALL INCLUDE AN 8-HOUR, 100% LOAD BANK AND TRANSIENT TESTING. POWER QUALITY ANALYZERS SHALL BE USED FOR WAVEFORM CAPTURE AND TRANSIENT RESPONSE DOCUMENTATION.
    - g. UPS TESTING SHALL INCLUDE AN 8-HOUR, 100% LOAD BANK, TRANSIENT TESTING, AND BATTERY DISCHARGE TESTING. POWER QUALITY ANALYZERS SHALL BE USED FOR WAVEFORM CAPTURE AND TRANSIENT RESPONSE DOCUMENTATION.
    - h. ATS TESTING SHALL INCLUDE TRANSFER FUNCTIONS, VERIFICATION OF TIMER/PICKUP/DROP-OUT SETPOINTS AND LOAD/NO-LOAD TEST OPERATION.




**INNOVATIVE DESIGN**  
850 W. MORGAN STREET  
RALEIGH, NORTH CAROLINA 27603  
919-832-6303  
919-832-3339 FAX



**optima engineering**  
150 Fayetteville St., Suite 520, Raleigh, NC 27601  
1927 South Tryon St., Suite 300, Charlotte, NC 28203  
Phone: 919-331-2200 www.optimaengineering.com  
North Carolina License Number: C-0914

PERMIT/BID SET



SEAL 28103  
11/19/19

Union Station Mezzanine Office Fit Up  
City of Raleigh Transit Division  
510 W Martin St, Raleigh, NC 27601

NO.	SUBMISSION	DATE
1	PERMIT/BID SET	11/08/19
CHECKED BY: MKG		
DRAWN BY: RDH		
PROJECT NUMBER: 1908		
SHEET NAME: ELECTRICAL SPECIFICATIONS		
SHEET NUMBER: E002		