



1 FLOOR PLAN - SECOND FLOOR - LIGHTING PLAN - EAST
3/16" = 1'-0"

Order Plans @ WWW.IDLINE.COM

KEYNOTES	
1	CONNECT UP AND DOWN LIGHTING TO BE DIMMED SEPARATELY.

GENERAL LIGHTING NOTES	
A	ALL RECESSED LIGHTING FIXTURES IN LAY-IN CEILINGS SHALL BE INSTALLED WITH 6' LONG FLEXIBLE METAL CONDUIT.
B	ALL MOUNTING HEIGHTS FOR LIGHTING FIXTURES ARE TO THE BOTTOM OF THE FIXTURES UNLESS INDICATED OTHERWISE.
C	SEE ARCHITECTURAL EXTERIOR ELEVATIONS FOR MOUNTING HEIGHTS OF EXTERIOR LIGHTING FIXTURES.
D	REFER TO SPECIFICATIONS FOR MINIMUM CONDUCTOR SIZE ADJUSTMENTS FOR VOLTAGE DROP.
E	WIRE COUNTS FOR CIRCUIT CONDUCTORS ARE NOT SHOWN. PROVIDE PROPER NUMBER OF CONDUCTORS TO ACHIEVE CIRCUIT AND SWITCHING CONNECTIONS SHOWN.
F	MODIFICATIONS TO NUMBER OF CONDUCTORS IN HOME RUNS IN ADDITION TO CIRCUITS INDICATED ON THIS DRAWING ARE PROHIBITED.
G	CONNECT ALL EMERGENCY LIGHT CIRCUITS FROM TRANSFER RELAYS AND EXIT LIGHTS TO LSPM-9

BUY AMERICA PROGRAM REQUIREMENTS
ALL PRODUCTS PROVIDED ON THIS PROJECT MUST BE MANUFACTURED IN COMPLIANCE WITH THE BUY AMERICA PROGRAM FOR FEDERALLY FUNDED TRANSPORTATION PROJECTS PER CODE OF FEDERAL REGULATIONS 49 DFR 661. THESE REQUIREMENTS ARE DISTINCT AND DIFFERENT FROM THOSE OF THE BUY AMERICAN ACT OF 1933.

1	PERMIT/BID SET	11/08/19
NO.	SUBMISSION	DATE
CHECKED BY:	MKG	
DRAWN BY:	RDH	
PROJECT NUMBER:	1908	
SHEET NAME:	ENLARGED LIGHTING FLOOR PLAN - EAST	
SHEET NUMBER:	E101	