



1 FLOOR PLAN - SECOND FLOOR - LIGHTING PLAN - WEST  
3/16" = 1'-0"

Order Plans @ WWW.LDIDLine.com

GENERAL LIGHTING NOTES	
A	ALL RECESSED LIGHTING FIXTURES IN LAY-IN CEILINGS SHALL BE INSTALLED WITH 6' LONG FLEXIBLE METAL CONDUIT.
B	ALL MOUNTING HEIGHTS FOR LIGHTING FIXTURES ARE TO THE BOTTOM OF THE FIXTURES UNLESS INDICATED OTHERWISE.
C	SEE ARCHITECTURAL EXTERIOR ELEVATIONS FOR MOUNTING HEIGHTS OF EXTERIOR LIGHTING FIXTURES.
D	REFER TO SPECIFICATIONS FOR MINIMUM CONDUCTOR SIZE ADJUSTMENTS FOR VOLTAGE DROP.
E	WIRE COUNTS FOR CIRCUIT CONDUCTORS ARE NOT SHOWN. PROVIDE PROPER NUMBER OF CONDUCTORS TO ACHIEVE CIRCUIT AND SWITCHING CONNECTIONS SHOWN.
F	MODIFICATIONS TO NUMBER OF CONDUCTORS IN HOME RUNS IN ADDITION TO CIRCUITS INDICATED ON THIS DRAWING ARE PROHIBITED.
G	CONNECT ALL EMERGENCY LIGHT CIRCUITS FROM TRANSFER RELAYS AND EXIT LIGHTS TO LSPM-9

**BUY AMERICA PROGRAM REQUIREMENTS**  
ALL PRODUCTS PROVIDED ON THIS PROJECT MUST BE MANUFACTURED IN COMPLIANCE WITH THE BUY AMERICA PROGRAM FOR FEDERALLY FUNDED TRANSPORTATION PROJECTS PER CODE OF FEDERAL REGULATIONS 49 DFR 661. THESE REQUIREMENTS ARE DISTINCT AND DIFFERENT FROM THOSE OF THE BUY AMERICAN ACT OF 1933.

**INNOVATIVE DESIGN**  
850 W. MORGAN STREET  
RALEIGH, NORTH CAROLINA 27603  
919-832-6303  
919-832-3339 FAX

**optima engineering**  
150 Fayetteville St., Suite 530, Raleigh, NC 27601  
1927 South Tryon St., Suite 300, Charlotte, NC 28203  
Phone: 919-333-2700 - www.optima-engineering.com  
North Carolina License Number: C-0914

PERMIT/BID SET  
SEAL  
11.01.2019

Union Station Mezzanine Office Fit Up  
City of Raleigh Transit Division  
510 W Martin St, Raleigh, NC 27601

1	PERMIT/BID SET	11/08/19
NO.	SUBMISSION	DATE

CHECKED BY: MKG  
DRAWN BY: RDH  
PROJECT NUMBER: 1908

SHEET NAME:  
ENLARGED LIGHTING FLOOR PLAN - WEST

SHEET NUMBER:  
**E102**