


PANEL "BL1-2"		PANEL TYPE: NQ0D		MCB or MLO:		150 AMP MCB						
EXISTING - MODIFIED (ALTERNATE)		BUS SIZE: 225A		MOUNTING:		SURFACE						
		VOLTAGE: 208Y/120		MINIMUM AIC:		10,000						
CKT	LOAD SERVED	TRIP	POLE	WIRE SIZE	CONDUIT SIZE	kVA PER PHASE	CONDUIT SIZE	WIRE SIZE	POLE	TRIP	LOAD SERVED	CKT
						A B C						
1	RECEPTACLE	20	1	EX	EX	0.18	0.18					2
3	BOTTLE FILL STATION	20*	1	EX	EX	0.6		0.60			PANEL BL1A	4
5	TRACK LIGHTS	20	1	EX	EX	0.60		0.60				6
7	TRACK LIGHTS	20	1	EX	EX	0.60	0.96		0.36	EX	RECEPTACLE 123A	8
9	TRACK LIGHTS	20	1	EX	EX	0.60		0.60	0.36	EX	RECEPTACLE 123A	10
11	TRACK LIGHTS	20	1	EX	EX	0.60		1.10	0.50	EX	MICROWAVE RECEPTACLE 123A	12
13	TRACK LIGHTS	20	1	EX	EX	0.60	0.90		0.30	EX	BLEACHERS EAST	14
15	TRACK LIGHTS	20	1	EX	EX	0.60	0.90		0.30	EX	BLEACHERS EAST	16
17	TRACK LIGHTS	20	1	EX	EX	0.60		0.90	0.30	EX	BLEACHERS EAST	18
19	TRACK LIGHTS	20	1	EX	EX	0.60	0.80		0.30	EX	BLEACHERS WEST	20
21	TRIUM LIGHTS	20	1	EX	EX	0.75		1.05	0.30	EX	BLEACHERS WEST	22
23	FANS, RECP #123	20	1	EX	EX	0.35			0.65	EX	BLEACHERS WEST	24
25	RECEPTACLE	20*	1	EX	EX	0.72	0.87		0.25	EX	POWER BOX	26
27	RECP #123	20	1	EX	EX	0.18		0.43	0.25	EX	POWER BOX	28
29	RECP #123	20	1	EX	EX	0.54			0.79	EX	POWER BOX	30
31	SPARE	20*	1	EX	EX		0.50		0.50	EX	REFRIGERATOR 123A	32
33	GOAL WINCH	20	1	EX	EX			0.50	0.50	EX	GOAL WINCH	34
35	GOAL WINCH	20	1	EX	EX			0.50	0.50	EX	GOAL WINCH	36
37	RECEPTACLE	20*	1	EX	EX	0.54	1.04		0.50	EX	DISHWASHER 123A	38
39	SPARE	20	1	EX	EX					EX	SPARE	40
41	BLANK	20	1	EX	EX				0.18	EX	RECEPTACLE PRESS BOX	42
						TOTALS:	6.45	4.44	4.72			

* DENOTES NEW CIRCUIT TO EXISTING BREAKER.
 L DENOTES LOCK-ON DEVICE

Order Plans @ www.LDILine.com



**UNCG ATHLETICS
 COLEMAN BUILDING
 WEIGHT ROOM**
 SCO ID No. 19-20597-01A | Code: 41825 | Item: 304
 1408 Walker Ave., Greensboro, NC 27402

SEALS



10-18-19

DKA JOB NUMBER

REVISIONS

These drawings are the property of Davis Kone Architects, P.A. They may not be used for any purpose without written permission. Copyright © 2019 by Davis Kone Architects, P.A. All rights reserved.

PE: RDA
 PM: PJR
 Drawn By: SDR
 Plot Date: 10/18/2019 10:00:00 PM

DATE ISSUED

BID DOCUMENTS
 10/22/2019

SHEET TITLE
 ELECTRICAL SCHEDULES

E-5.2