


- SPECIFIC PLUMBING PLAN NOTES:**
- 1 EXISTING MEDIUM PRESSURE (5 PSI) GAS LINE BELOW GRADE TO REMAIN--FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING GAS LINE.
  - 2 EXISTING LOW PRESSURE (7" WC) GAS LINE BELOW GRADE TO REMAIN--FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING GAS LINE.
  - 3 REMOVE EXISTING LOW PRESSURE (7" WC) GAS LINE FROM EXISTING PADMOUNTED UNIT TO THIS POINT FOR CONNECTION OF NEW LOW PRESSURE (7" WC) GAS LINE--FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING GAS LINE.
  - 4 REMOVE EXISTING 1" LOW PRESSURE (7" WC) GAS LINE AND CAP BELOW GRADE--FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING.
  - 5 REMOVE EXISTING GAS LINE AS INDICATED--FIELD VERIFY EXACT LOCATION.
  - 6 REMOVE EXISTING GAS CONNECTION TO GAS FIRED UNIT --FIELD VERIFY EXACT LOCATION. RE: H.V.A.C. DRAWING FOR REMOVAL OF H.V.A.C. UNITS.
  - 7 REMOVE EXISTING GAS CONNECTION TO PADMOUNTED UNIT --FIELD VERIFY EXACT LOCATION. RE: H.V.A.C. DRAWING FOR REMOVAL OF H.V.A.C. UNITS.
  - 8 CONNECT NEW 1" LOW PRESSURE (7" WC) GAS LINE TO EXISTING GAS 1" LOW PRESSURE (7" WC) GAS LINE BELOW GRADE--FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING.
  - 9 RISE NEW 1" LOW PRESSURE (7" WC) GAS LINE UP FROM BELOW GRADE AND CONNECT TO PADMOUNTED UNIT--RE: DETAIL 112/PB01.
  - 10 REMOVE AND REPLACE EXISTING GAS PRESSURE REGULATOR WITH NEW GAS PRESSURE REGULATOR (GPR-1)--RE: SPEC'S.. SCHEDULE AND DETAIL 119/PB01. FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING MEDIUM PRESSURE GAS LINE BELOW GRADE. REPAIR EXISTING EXTERIOR GAS PIPING.
  - 11 RISE NEW 2" LOW PRESSURE (7" WC) GAS LINE UP FROM BELOW GRADE AND CONNECT TO PADMOUNTED UNIT--RE: DETAIL 112/PB01.
  - 12 REMOVE AND REPLACE EXISTING GAS PRESSURE REGULATOR WITH NEW GAS PRESSURE REGULATOR (GPR-2)--RE: SPEC'S.. SCHEDULE AND DETAIL 119/PB01. FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING MEDIUM PRESSURE GAS LINE BELOW GRADE. REPAIR EXISTING EXTERIOR GAS PIPING.
  - 13 RECONNECT EXISTING LOW PRESSURE (7" WC) GAS LINE TO NEW GAS FURNACE--RE: DETAIL K5/PB01. FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING LOW PRESSURE (7" WC) GAS LINE.
  - 14 REMOVE EXISTING GAS PRESSURE REGULATOR AND CAP EXISTING GAS PIPING BELOW GRADE. FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING GAS LINE BELOW GRADE.
  - 15 REMOVE AND REPLACE EXISTING GAS PRESSURE REGULATOR WITH NEW GAS PRESSURE REGULATOR (GPR-3)--RE: SPEC'S.. SCHEDULE AND DETAIL N13/PB01. FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING MEDIUM PRESSURE GAS LINE BELOW GRADE. REPAIR EXISTING EXTERIOR GAS PIPING.
  - 16 REMOVE AND REPLACE EXISTING GAS PRESSURE REGULATOR WITH NEW GAS PRESSURE REGULATOR (GPR-4)--RE: SPEC'S.. SCHEDULE AND DETAIL N13/PB01. FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING MEDIUM PRESSURE GAS LINE BELOW GRADE. REPAIR EXISTING EXTERIOR GAS PIPING.

PLUMBING FLOOR PLAN - GYMNASIUM J10  
 SCALE: 1/8" = 1'-0" P101

Order Plans @

WWW.LDILine.com

**CAUTION**  
 THE UTILITIES SHOWN ARE FOR THE CONTRACTOR'S CONVENIENCE ONLY. OTHER UTILITIES MAY BE PRESENT BUT NOT SHOWN ON THESE DRAWINGS. THE ARCHITECT AND ENGINEER ASSUME NO RESPONSIBILITY FOR THE UTILITY LOCATIONS SHOWN, AND IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE EXACT LOCATIONS OF ALL UTILITIES WITHIN THE LIMITS OF THE WORK. ALL DAMAGE MADE TO THE EXISTING UTILITIES BY THE CONTRACTOR SHALL BE REPAIRED TO A "LIKE NEW" CONDITION. THE CONTRACTOR SHALL BEAR THE SOLE RESPONSIBILITY OF ANY LOSSES THAT OCCUR FROM DAMAGES TO THE EXISTING UTILITIES.



<b>Southern A&amp;E</b> REVISION 7951 Iron Circle Austell, Ga. 30168 (770) 819-7777 architects & engineers		DATE December 10 2019
<small>© COPYRIGHT 2019 BY SOUTHERN A&amp;E, LLC. ALL RIGHTS RESERVED. THIS DOCUMENT IS THE PROPERTY OF SOUTHERN A&amp;E, LLC AND SHALL NOT BE COPIED OR REPRODUCED IN WHOLE OR IN PART WITHOUT EXPRESSED WRITTEN CONSENT FROM SOUTHERN A&amp;E, LLC.</small>		JOB NUMBER 01 610 296
HVAC RENOVATIONS FOR: <b>ARNALL MIDDLE SCHOOL GYMNASIUM</b> COWETA COUNTY SCHOOL SYSTEM NEWNAN, GEORGIA		
STATE OF GEORGIA GREGORY SCHILIN REGISTERED ARCHITECT		DRAWING NUMBER <b>P101</b>