

Order Plans @

WWW.LDILine.com

- SPECIFIC PLUMBING PLAN NOTES:**
- 1 EXISTING LOW PRESSURE (7" WC) GAS LINE BELOW GRADE TO REMAIN--FIELD VERIFY EXACT SIZE AND LOCATION OF EXISTING GAS LINE.
 - 2 EXISTING MED. PRESSURE GAS LINE BELOW GRADE TO REMAIN--FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING GAS LINE.
 - 3 REMOVE EXISTING ABOVE GRADE LOW PRESSURE (7" WC) GAS LINE AND EXISTING PAD MOUNTED UNIT. CAP AND ABANDON EXISTING LOW PRESSURE (7" WC) GAS LINE LOCATED BELOW GRADE.--FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING GAS LINE.
 - 4 CAP EXISTING LOW PRESSURE (7" WC) GAS LINE--FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING.
 - 5 REMOVE EXISTING GAS LINE AS INDICATED--FIELD VERIFY EXACT LOCATION.
 - 6 REMOVE EXISTING GAS CONNECTION AND GAS FIRED UNIT --FIELD VERIFY EXACT LOCATION. RE: MECHANICAL DRAWINGS FOR REMOVAL OF HVAC UNITS.
 - 7 EXISTING LOW PRESSURE (7" WC) GAS LINE TO REMAIN IN PLACE AND FULLY FUNCTIONAL--FIELD VERIFY EXACT SIZE AND LOCATION OF EXISTING GAS LINE.
 - 8 REMOVE EXISTING DUCT FURNANCE AND REPLACE WITH NEW. RE: DETAIL E12/P501. RE: MECHANICAL DRAWINGS FOR REMOVAL AND REPLACEMENT HVAC DUCT FURNANCE.
 - 9 RISE NEW 2" LOW PRESSURE (7" WC) GAS LINE UP FROM BELOW GRADE AND CONNECT TO PAD MOUNTED UNIT--RE: DETAIL E12/P501.
 - 10 CONNECT NEW 3" LOW PRESSURE (7" WC) GAS LINE TO EXISTING 4" LOW PRESSURE (7" WC) GAS LINE BELOW GRADE--FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING.
 - 11 CUT AND PATCH ANY EXISTING SIDEWALK DISTURBED DURING INSTALLATION OF NEW LOW PRESSURE GAS LINE BELOW GRADE.
 - 12 CONNECT NEW 1 1/2" LOW PRESSURE (7" WC) GAS LINE TO EXISTING LOW PRESSURE (7" WC) GAS LINE. RISE UP FROM BELOW GRADE AND CONNECT TO PAD MOUNTED UNIT--RE: DETAIL E12/P501.
 - 13 REMOVE AND REPLACE EXISTING GAS PRESSURE REGULATOR WITH NEW GAS PRESSURE REGULATOR (GPR-1)--RE: SPEC'S., SCHEDULE AND DETAIL E19/P501. FIELD VERIFY EXACT LOCATION AND SIZE OF EXISTING MEDIUM PRESSURE GAS LINE BELOW GRADE.
 - 14 PIPE SUPPORT--RE: SPEC'S AND DETAIL I19/P501.


**HVAC GAS RENOVATION PLAN
- WING "F" - GYMNASIUM**

SCALE: 1/8" = 1'-0"

M6
P101

CAUTION

THE UTILITIES SHOWN ARE FOR THE CONTRACTOR'S CONVENIENCE ONLY. OTHER UTILITIES MAY BE PRESENT BUT NOT SHOWN ON THESE DRAWINGS. THE ARCHITECT AND ENGINEER ASSUME NO RESPONSIBILITY FOR THE UTILITY LOCATIONS SHOWN, AND IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE EXACT LOCATIONS OF ALL UTILITIES WITHIN THE LIMITS OF THE WORK. ALL DAMAGE MADE TO THE EXISTING UTILITIES BY THE CONTRACTOR SHALL BE REPAIRED TO A "LIKE NEW" CONDITION. THE CONTRACTOR SHALL BEAR THE SOLE RESPONSIBILITY OF ANY LOSSES THAT OCCUR FROM DAMAGES TO THE EXISTING UTILITIES.



<p>Southern A&E 7951 Iron Circle Austell, Ga. 30168 (770) 819-7777 architects & engineers</p>	<p>REVISED DATE December 10 2019 JOB NUMBER 01 610 292</p>
	<p>HVAC RENOVATIONS FOR: LEE MIDDLE SCHOOL GYMNASIUM COWETA COUNTY SCHOOL SYSTEM NEWNAN, GEORGIA</p>
<p>STATE OF GEORGIA REGISTERED ARCHITECT MICHAEL C. WALDRUP</p>	<p>DRAWING NUMBER P101</p>