



- NOTES: PMU
1. WEATHERPROOF ALL EXPOSED DUCTING IN COMPLIANCE WITH SPECIFICATION SECTION 230713 AS APPLICABLE. COVER DUCT WITH VINYL BACKED RIGID BOARD INSULATION AND SEAL.
  2. SEE ARCHITECTURAL FOR FLASHING OF DUCT PENETRATION AT WALL.
  3. DUCT TRANSITIONS SHALL NOT BLOCK OUTSIDE AIR HOOD AND SHALL BE AS GENTLE AS POSSIBLE.
  4. REUSE WALL OPENING WHERE EXISTING LOUVER IS REMOVED. STACK DUCTWORK WITH SUPPLY ABOVE RETURN. FIELD VERIFY SITE CONDITIONS PRIOR TO DUCT FABRICATION.

**Order Plans @**

**Southern A&E** REGISTERED ARCHITECTS & ENGINEERS  
7951 Troon Circle, Austell, Ga. 30168  
(770) 819-7777

REVISION: December 20 2019  
DATE: December 10 2019  
JOB NUMBER: 01 610 292

HVAC RENOVATIONS FOR:  
**LEE MIDDLE SCHOOL GYMNASIUM**  
COWETA COUNTY SCHOOL SYSTEM  
NEWNAN, GEORGIA

STATE OF GEORGIA REGISTERED ARCHITECT  
GREGORY SCHUMBERG  
STATE OF GEORGIA REGISTERED ENGINEER  
MICHAEL C. WALDRON

DRAWING NUMBER: **M502**