GENERAL NOTES:

1. CONTRACTOR SHALL FIELD VERIFY EXACT CIRCUITS SERVING EXISTING MECHANICAL EQUIPMENT.
2. COORDINATE SAFETY SWITCH, MANUAL MOTOR STARTER AND OTHER WIRING DEVICES WITH FIELD CONDITIONS. INSTALL DISCONNECTING MEANS AS CLOSE TO EQUIPMENT AS POSSIBLE. DISCONNECTS SERVING ABOVE CEILING EQUIPMENT SHALL BE INSTALLED ABOVE CEILING.

DRAWING NOTES:

1. NOT USED
2. NOT USED
3. PROVIDE NEW CIRCUIT TO NEW RTU. LOCAL DISCONNECT SHALL BE PROVIDED BY DIVISION 23.
4. PROVIDE SERVICE RECEPTACLE MOUNTED ON ROOF ON PEDESTAL AND CONNECT TO ADJACENT EXISTING UNSWITCHED, NON-LOCATED POWER CIRCUIT.

E103B

E103C

RTU-A3
3
4
B-21,23,25

E103B

E103C

ELECTRICAL POWER PLAN – ROOF
SCALE: 1/8" = 1' 0"

GRAPHIC SCALE
8 4 0 8 16
SCALE: 1/8"=1'-0"
UNIT OF MEASURE: FEET

KEY PLAN

Order Plans @ www.LDILine.com

CDH ARCHITECTURE
675 Tower Road
Marietta, GA 30060-6958
770.423.0616
www.cdhpartners.com

COPYRIGHT © 2019 by CDH PARTNERS INC.
All rights reserved.

FULTON COUNTY SCHOOL SYSTEM

EVOLINE C. WEST ELEMENTARY SCHOOL - RENOVATIONS

7040 RIVERTOWN RD
FAIRBURN, GA 30213

PROJECT NO: 18048.00

01	50% CD	08/07/2018
02	50% CD - re-submittal	11/20/2018
03	90% CD	10/04/2019
04	PERMIT SET	11/15/2019
05	BID SET	12/20/2019

GEORGIA REGISTERED No. PE037930 PROFESSIONAL ENGINEER BETH ANN CRUTCHFIELD

SHEET TITLE
ELECTRICAL POWER PLAN - ROOF

SHEET NUMBER
E103B