


These drawings are instruments of service and as such remain the property of the architect. No copies or reproductions of these drawings are permitted without the consent of the architect. Upon completion of the work all the drawings (except the contract copies) are to be returned to the architect.
 Copyright © 2019



1920 Hwy. 54, Suite 700, Durham, NC 27713
 Ph. 919-544-1936 - Fax 919-544-2540 - License: C-1813

RENOVATIONS TO:

ABC STORE

HOLLOWAY ST.
 DURHAM, NC

PROJECT NUMBER
 19-063

Electrical Site
 Renovation Plan

DTW
 Architects &
 Planners, Ltd.

229 North Gregson Street
 Durham, NC 27701
 919.317.4020

CONSTRUCTION DOCUMENTS

Revisions

Drawn	ANR
Checked	JDH
Date	12/18/2019
Sheet	ES1.1

of

P:\PROJECTS\19-063-ABC STORE - HOLLOWAY ST.\19-063 ELECTRICAL\19-063 ES1.1.dwg 12/18/2019 12:30 PM BY: BRUCE NEWMAN

Order Plans @ www.LDILine.com

NEW 25' POLE AND LIGHT PROVIDED BY DUKE ENERGY. ELECTRICAL CONTRACTOR SHALL ROUTE UNDERGROUND CONDUIT AS DIRECTED BY SITE/CIVIL CONSULTANT AND DUKE ENERGY FIELD ENGINEER.

ELECTRICAL NOTES:

- ALL EXTERIOR CONDUIT SHALL HAVE A MINIMUM OF 24" COVER.
- PROVIDE NEW 1-1/2" CONDUIT SLEEVES TO CONNECT ALL NEW AND EXISTING DUKE ENERGY LIGHT POLES. COORDINATE WITH DUKE ENERGY AND CIVIL ENGINEER.

NEW 25' POLE AND LIGHT PROVIDED BY DUKE ENERGY. ELECTRICAL CONTRACTOR SHALL ROUTE UNDERGROUND CONDUIT AS DIRECTED BY SITE/CIVIL CONSULTANT AND DUKE ENERGY FIELD ENGINEER.

NEW 25' POLE AND LIGHT PROVIDED BY DUKE ENERGY. ELECTRICAL CONTRACTOR SHALL ROUTE UNDERGROUND CONDUIT AS DIRECTED BY SITE/CIVIL CONSULTANT AND DUKE ENERGY FIELD ENGINEER.

NEW 25' POLE AND LIGHT PROVIDED BY DUKE ENERGY. ELECTRICAL CONTRACTOR SHALL ROUTE UNDERGROUND CONDUIT AS DIRECTED BY SITE/CIVIL CONSULTANT AND DUKE ENERGY FIELD ENGINEER.

EXISTING 'ABC LIQUORS' SIGN TO REMAIN. ELECTRICAL CONTRACTOR SHALL PROVIDE NEW UNDERGROUND CIRCUIT FROM RENOVATED BUILDING AS REQUIRED FROM LIGHTING CONTROL SYSTEM FOR ZONE 18, CIRCUIT A-19.

LOCATION OF NEW 24" X 28" LIGHTING CONTROL SYSTEM RELAY PANEL.

LOCATION OF NEW PANEL 'A'.

APPROXIMATE LOCATION OF NEW SERVICE ENTRANCE METER AND BASE.

ADA VAN

ADA VAN

MAINTAIN 12" SEPARATION BETWEEN POWER AND TELECOM.

3" CONDUIT FOR NEW POWER SERVICE ENTRANCE. COORDINATE WITH POWER COMPANY.

(2) 2" CONDUITS TO UTILITY POLE FOR TELECOM. COORDINATE WITH OWNER'S SERVICE PROVIDER.

STUB TELECOM CONDUITS INTO ELECTRICAL ROOM.



1 Electrical Site Renovation Plan
 ES1.1 SCALE: 1/8" = 1'-0"

UTILITY COMPANY POWER POLE



NORTH