

Order Plans @

EQUIPMENT LIST						
EQUIP NO.	MAKE	MODEL	DESCRIPTION	QTY	SUPPLIED BY	INSTALLED BY
FL001	XERXES	EWS FIBERGLASS	20,000 GAL. DOUBLE WALL FRP UNDERGROUND TANK WITH BRINE FILLED RESERVOIR, 42" ATTACHED COLLAR, 22" I.D. MANWAY WITH (4) 4" NPT OPENINGS IN MANWAY COVER, (4) 4" THREADED OPENINGS	2	OWNER	GC
FL002	XERXES	EWS FIBERGLASS	20,000 GAL. DOUBLE WALL FRP UNDERGROUND TANK CONTAINING (1) 12,000 AND (1) 8,000 GAL. COMPARTMENT WITH BRINE FILLED RESERVOIR, (2) 42" ATTACHED COLLARS, (2) 22" I.D. MANWAY WITH (4) 4" NPT OPENINGS IN MANWAY COVER, (2) 4" THREADED OPENINGS	1	OWNER	GC
FL003	XERXES	---	DEADMAN WITH EYEBOLTS	12	OWNER	GC
FL004	XERXES	---	FIBERGLASS ANCHOR STRAPS FOR 10' DIA TANK	20	OWNER	GC
FL006	SOURCE INC	755101	TRASH RECEPTACLE W/ WINDOW WASHING UNIT CONTACT: 1-800-556-3312 (BRYAN JONES)	3	OWNER	GC
FL006	XERXES	---	TURNBUCKLES	40	OWNER	GC
FL007	OPW	106U-0125	PRODUCT MARKER SET IN CONCRETE - LEADED	2	OWNER	GC
FL008	OPW	100P-0150	PRODUCT MARKER SET IN CONCRETE - PREMIUM UNLEADED	1	OWNER	GC
FL009	OPW	109DL-0085	PRODUCT MARKER SET IN CONCRETE - DIESEL	1	OWNER	GC
FL010	OPW	100R-1100	PRODUCT MARKER SET IN CONCRETE #1	1	OWNER	GC
FL011	OPW	100R-2200	PRODUCT MARKER SET IN CONCRETE #2	1	OWNER	GC
FL012	OPW	100R-3300	PRODUCT MARKER SET IN CONCRETE #3	1	OWNER	GC
FL013	OPW	100R-4400	PRODUCT MARKER SET IN CONCRETE #4	1	OWNER	GC
FL014	OPW	11AG-7000	PRODUCT MARKER FOR MANHOLE COVER - VAPOR	3	OWNER	GC
FL015	OPW	11AG-1050	PRODUCT MARKER FOR MANHOLE COVER - UNLEADED	2	OWNER	GC
FL016	OPW	11AG-3000	PRODUCT MARKER FOR MANHOLE COVER - PREMIUM UNLEADED	1	OWNER	GC
FL017	OPW	11AG-4050	PRODUCT MARKER FOR MANHOLE COVER - DIESEL	1	OWNER	GC
FL018	OPW	15C-3132D	EDGE DOUBLE WALL SPILL CONTAINER W/ SENSOR, SEALABLE COVER & DRAIN VALVE	4	OWNER	GC
FL019	OPW	6341T-7085-EVR	4" TOP-SEAL CAP, PRODUCT FILL	4	OWNER	GC
FL020	OPW	61SALP-1020-EVR	4" SWIVEL ADAPTER, PRODUCT FILL	4	OWNER	GC
FL021	OPW	7180-010C	4" EVR ALUMINUM DROP TUBE WITH OVERFLOW PREVENTION VALVE	4	OWNER	GC
FL022	OPW	15C-3101P	EDGE SINGLE WALL SPILL CONTAINER W/ FILL AND SEALABLE COVER	3	OWNER	GC
FL023	OPW	01VSA-1020-EVR	ROTATABLE VAPOR SWIVEL ADAPTER	3	OWNER	GC
FL024	OPW	1711T-7085-EVR	3" VAPOR RECOVERY CAP	4	OWNER	GC
FL025	OPW	233-4430	EXTRACTOR VENT FITTINGS - 4x4.5	4	OWNER	GC
FL026	HUSKY	5885 5041	2.5" x 8" W/C PRESSURE, 10" W/C VACUUM 2" THREADED ON VENT VALVE W/ 3" ADAPTOR PETROLEUM MARKETERS EQUIPMENT (CONTACT: MIKE WILSON 1-800-364-9037)	1	OWNER	GC
FL027	OPW	23-0055	OPW DISPENSER	1	OWNER	GC
FL028	OPW	107-0300	NAMPTER HOLDER EXTRACTOR TO 10" DIA TANK CAPACITANCE DISPENSER	4	OWNER	GC
FL029	OPW	10AA-1500	18" DIA WHOLE WITH 12" DIA STEEL COVER	6	OWNER	GC
FL030	NOT USED	---	---	---	---	---
FL031	OPW	FLEXWORKS	1 1/2" CONDUIT ENTRY FITTING ASSEMBLY AND FLEXWORKS EXTENSION AND (2) RESIN KITS FOR BLIND DEPTHS GREATER THAN 48" RESIN KIT - TANK SUMP	4	OWNER	GC
FL032	OPW	FLEXWORKS	1 1/2" CONDUIT ENTRY FITTING ASSEMBLY AND FLEXWORKS EXTENSION AND (2) RESIN KITS FOR BLIND DEPTHS GREATER THAN 48" RESIN KIT - TANK SUMP	6	OWNER	GC
FL033	OPW	61US-04CB	JACOBS CREW ASSEMBLY - DROP TUBE LOCKDOWN	4	OWNER	GC
FL034	NOT USED	---	---	---	---	---
FL035	OPW	62-1110	4" DIAMETER WELL CAP	2	OWNER	GC
FL036	OPW	10AA-1819	18" DIA MONITOR WELL MANHOLE WITH 19" 1/4" SKIRT AND WATER TIGHT BOLTED COVER	2	OWNER	GC
FL037	OPW	61SPVC-4000	4" DIA 920' SLOTTED SCHEDULE 40 PVC MONITOR/OBSERVATION WELL PIPING - 13' LENGTH WITH BOTTOM FLG	2	OWNER	GC
FL038	OPW	38CD-WY10	30 1/2" DIA POMEROO CONDUSTADOR COMPOSITE MANHOLE WITH 11" STEEL SKIRT, RECESSED HANDLE - BOLT DOWN - WATER TIGHT	4	OWNER	GC
FL039	NOT USED	---	---	---	---	---
FL040	OPW	218V-0150	1 1/2" BRONZE BALL VALVE - FULL PORT	8	OWNER	GC
FL041	NOT USED	---	---	---	---	---
FL042	NOT USED	---	---	---	---	---
FL043	OPW	REF-0100C REF-4015 SL-1100	1" CONDUIT ENTRY FITTING ASSEMBLY 1 1/2" OPW FLEXWORKS PIPE ENTRY FITTING ASSEMBLY URETHANE SEALANT	8 8 3	OWNER	GC
FL044	OPW	601SS-SFRH06.5WM	3'-0" x 5'-0" STAINLESS STEEL ISLAND FORM END SEAMS WITH 12" SKIRT	6	OWNER	GC
FL045	OPW	FC30-MM24	3" STAINLESS STEEL BRAIDED TEFLON FLEX CONNECTOR - FOR USE ONLY IN UNDERGROUND VENT/VAPOR LINES	2	OWNER	GC
FL046	OPW	FC15-MM12	1 1/2" STAINLESS STEEL BRAIDED FLEX CONNECTOR	1	OWNER	GC
FL047	OPW	88L-0400	"FILLGARD" SPLASH GUARD (BLACK)	12	OWNER	GC
FL048	OPW	241-TPS-0241	BALL SWIVEL	18	OWNER	GC
FL049	NOT USED	---	---	---	---	---
FL050	NOT USED	---	---	---	---	---
FL051	NOT USED	---	---	---	---	---
FL052	OPW	11BP-0410	NOZZLE WITH HOLD OPEN CLIPS	12	OWNER	GC
FL053	OPW	66H-04075 66H-04075 66REC-1000	3/4" 4 FT DISP HOSE W/ FITTINGS BLACK 3/4" 4 FT DISP HOSE W/ FITTINGS GREEN (DIESEL) 3/4" RECONNECTABLE BREAKAWAY	4 4 16	OWNER	GC
FL055	OPW	66H-08075 66H-08075 11B-0100	3/4" 8 FT DISP HOSE W/ FITTINGS BLACK 3/4" 8 FT DISP HOSE W/ FITTINGS GREEN (DIESEL) STANDARD FLOW DIESEL NOZZLE WITH HOLD OPEN CLIP (GREEN)	4 4 4	OWNER	GC
FL057	OPW	8G-0100	"FILLGARD" SPLASH GUARD (GREEN)	4	OWNER	GC
FL058	OPW	DSLR-15-1543-12507	DISPENSER SUMP FOR WAYNE OVATION DISPENSER - VERIFY EXACT MODEL NUMBERS OF SUMP - PROVIDE ALL HARDWARE FOR SHEAR VALVES, STABILIZER BARS, PIPE ENTRY FITTINGS, AND DISPENSER MOUNTING	2	OWNER	GC
FL059	OPW	DSLR-15-1543-1256	DISPENSER SUMP FOR WAYNE OVATION DISPENSER - VERIFY EXACT MODEL NUMBERS OF SUMP - PROVIDE ALL HARDWARE FOR SHEAR VALVES, STABILIZER BARS, PIPE ENTRY FITTINGS, AND DISPENSER MOUNTING	2	OWNER	GC
FL059	OPW	DSLR-15-1543-56	DISPENSER SUMP FOR WAYNE OVATION DISPENSER - VERIFY EXACT MODEL NUMBERS OF SUMP - PROVIDE ALL HARDWARE FOR SHEAR VALVES, STABILIZER BARS, PIPE ENTRY FITTINGS, AND DISPENSER MOUNTING	2	OWNER	GC
FL059	OPW	7180-TOOL	7180 INSTALL TOOL	1	OWNER	GC
FL060	OPW	FLEXWORKS	1 1/2" FLEXIBLE DOUBLE WALL PRIMARY PIPING	750	OWNER	GC
FL060	OPW	FLEXWORKS	DPC-2150A	30	OWNER	GC
FL060	OPW	FLEXWORKS	SMA-1515	8	OWNER	GC
FL061	OPW	FLEXWORKS	AXP40	750	OWNER	GC
FL061	OPW	FLEXWORKS	AXP40	750	OWNER	GC

INSTALLATION NOTE: SEE NOTES ON P518 AND P519 FOR SPECIFIC SETTINGS FOR EQUIPMENT ITEM #FL021 - OVERFILL PREVENTION DEVICE.

NOTE: ITEMS FL047, FL048, FL052, FL054, FL055 ARE FURNISHED AS A PRE-ASSEMBLED DISPENSER HARDWARE KIT (OPW PART NUMBER: PK-WM-UNL). ITEMS FL049, FL053, FL056, FL058, FL059 ARE FURNISHED AS A PRE-ASSEMBLED DISPENSER HARDWARE KIT (OPW PART NUMBER: PK-WM-DIESEL).

EQUIPMENT LIST						
EQUIP NO.	MAKE	MODEL	DESCRIPTION	QTY	SUPPLIED BY	INSTALLED BY
FL062	VEEDER-ROOT	330020-282	PROBE CAP AND ADAPTER	3	OWNER	GC
FL063	OPW	FSA-400	FACE SEAL ADAPTOR	4	OWNER	GC
FL064	OPW	TCT-2509	TEST JUMPER FOR COUPLING TO COUPLING	12	OWNER	GC
FL064	OPW	TTT-2536	TEST TUBE TERMINATION KIT	14	OWNER	GC
FL065	VEEDER-ROOT	849390-109 888100-000	TANK LEVEL MONITOR 10 FEET LENGTH 4" PHASE TWO GASOLINE PROBE INSTALLATION KIT	2	OWNER	GC
FL066	VEEDER-ROOT	849390-111 888100-000	TANK LEVEL MONITOR 11 FEET LENGTH 4" PHASE TWO GASOLINE PROBE INSTALLATION KIT	2	OWNER	GC
FL067	VEEDER-ROOT	849390-001 690001-001 333645-001	4" DIESEL PROBE INSTALLATION KIT, 5' CABLE TLS-450 PLUS W/ INTEGRAL PRINTER TLS-450 PLUS OPERATING SYSTEM AND ATG FUNCTIONALITY SOFTWARE ACCURATE 9999 EGM (16) UNIVERSAL SENSOR/PROBE INTERFACE MODULE	1 1 1	OWNER	GC
FL068	VEEDER-ROOT	794380-208	NON DISCRIMINATING 5TUDC SUMP SENSOR 12" CABLE	1	OWNER	GC
FL069	NGT USED	---	---	---	---	---
FL070	VEEDER-ROOT	794380-303	DUAL-POINT HYDROSTATIC SENSOR (VENTED LOCKING RISER) 12" HOSE	3	OWNER	GC
FL071	NGT USED	---	---	---	---	---
FL072	VEEDER-ROOT	330020-012	UNIVERSAL SENSOR MOUNTING KIT	10	OWNER	GC
FL073	WAYNE	8122Z200D 2ELKUN9THRS-SCB OVATION 2	TWO POINT, ONE HOSE DISPENSER WITH FACTORY INSTALLED INTERCOM, CUSTOM GRAPHICS, STAGE 1 COLOR VAPOR SCREEN, SPM DISPENSER CARD READER, UNLIGHTED VALANCE AND OWNER CUSTOM GRAPHICS, STAGE 1 (DIESEL) TWO HOSE, IDPOS DISPENSER WITH FACTORY INSTALLED INTERCOM, COLOR VAPOR SCREEN, SPM DISPENSER CARD READER, UNLIGHTED VALANCE, AND OWNER CUSTOM GRAPHICS, STAGE 1 (NO VAPOR RECOVERY REQUIRED), (OVATION)	4	OWNER	GC
FL074	WAYNE	823X2200 2ELKUN9THRS-SCB OVATION 2	TWO POINT, ONE HOSE DISPENSER WITH FACTORY INSTALLED INTERCOM, CUSTOM GRAPHICS, STAGE 1 (DIESEL) TWO HOSE, IDPOS DISPENSER WITH FACTORY INSTALLED INTERCOM, COLOR VAPOR SCREEN, SPM DISPENSER CARD READER, UNLIGHTED VALANCE, AND OWNER CUSTOM GRAPHICS, STAGE 1 (NO VAPOR RECOVERY REQUIRED), (OVATION)	2	OWNER	GC
FL075	NOT USED	---	---	---	---	---
FL076	ASHROCK	4CFJ5	3 1/2" DIAL STAINLESS STEEL SOCKET, LIQUID FILLED VACUUM GAUGE, 30 TO 0" HG VAC. PETROLEUM MARKETERS EQUIPMENT (CONTACT: MIKE WILSON 1-800-364-9037)	1	OWNER	GC
FL077	BRADY	8BV25	1/4" BRASS BALL VALVE, INCLUDES FITTINGS AND COPPER TUBING PETROLEUM MARKETERS EQUIPMENT (CONTACT: MIKE WILSON 1-800-364-9037)	2	OWNER	GC
FL078	VEEDER-ROOT	312000-952	TANK PROBE WELL CAP AND RING KIT	4	OWNER	GC
FL078	NATIONAL OILWELL VARCO (NOV)	RED THREAD 8A OR DUALOY 3000L	FIBERGLASS VENT RETURN PIPING AND ALL FITTINGS FOR INSTALLATION AND TESTING (CONTACT: FRED THREED 1-800-868-6010 (CONTACT: DUALOY 1-800-569-8645)	AS REQ'D	GC	GC
FL080	MISC	---	MISCELLANEOUS STEEL PIPE AND FITTINGS PETROLEUM MARKETERS EQUIPMENT (CONTACT: MIKE WILSON 1-800-364-9037)	AS REQ'D	OWNER	GC
FL081	HARRIS INDUSTRIES	DU-02-06	8" BLK/YELLOW DETECTABLE UNDERGROUND TAPE IMPRINTED WITH "CAUTION BURIED GAS LINE"	AS REQ'D	GC	GC
FL082	RED JACKET	P200U-3RJ2	SUBMERGED TURBINE PUMP - 2 HP 208-230V 60 HZ SINGLE PHASE - SUITABLE FOR BLEND CONCENTRATIONS OF FUEL SIPHON CARTRIDGE KIT	3	OWNER	GC
FL083	RED JACKET	410151-001	SUBMERGED TURBINE PUMP - 1 1/2 HP 208-230V 60 HZ SINGLE PHASE - SUITABLE FOR BLEND CONCENTRATIONS OF FUEL (DIESEL TANK ONLY)	1	OWNER	GC
FL084	RED JACKET	110958 6 110958 5	MECHANICAL LINE LEAK DETECTOR FKHV - UNLEADED MECHANICAL LINE LEAK DETECTOR FKHV - DIESEL	3 1	OWNER	GC
FL085	RED JACKET	P150U-RJ2	SUBMERGED TURBINE PUMP - 1 1/2 HP 208-230V 60 HZ SINGLE PHASE - SUITABLE FOR BLEND CONCENTRATIONS OF FUEL (DIESEL TANK ONLY)	1	OWNER	GC
FL086	NOT USED	---	---	---	---	---
FL087	NOT USED	---	---	---	---	---
FL088	POWER INTEGRITY	CPS-SAMS	COMPLETE POWER DISTRIBUTION CENTER WITH SURGE PROTECTION (INSTALLED BY BUILDING MFR), AND MAIN DISCONNECT (INSTALLED BY GC) 1-800-237-6290	1	OWNER	---
FL088	POWER INTEGRITY	IA-60ESORLSD	TOP MOUNT E-STOP PANEL	1	OWNER	OWNER
FL089	POWER INTEGRITY	IA-ESOCA	EMERGENCY FUEL STOP OPERATOR, SINGLE PUSH BUTTON OPERATOR WITH COVER, NONIC CONTACTS	2	OWNER	OWNER
FL091	POWER INTEGRITY	DOS-ERR80	ETHERNET LOW VOLTAGE DISCONNECT	1	OWNER	GC
FL092	POWER INTEGRITY	DOS-80B4C	INTERCOM DISCONNECT	1	OWNER	GC
FL093	---	---	SINGLE LINE WALL MOUNTED CORDLESS PHONE	1	OWNER	OWNER
FL094	NOT USED	---	---	---	---	---
FL095	SOURCE INC	TMK-3006	ESCO 2-WAY INTERCOM SYSTEM (PART #0841-0065) CONTACT: 1-800-556-3312 (BRYAN JONES)	1	OWNER	GC
FL096	SOURCE INC.	116288	EYE WASH STATION CONTACT: 1-800-556-3312 (BRYAN JONES)	1	OWNER	GC
FL097	SOURCE INC.	K340-102	FIRE BLANKET CONTACT: 1-800-556-3312 (BRYAN JONES)	1	OWNER	GC
FL098	SOURCE INC.	1850	"3" CRANCKE COCKS" CONTACT: 1-800-556-3312 (BRYAN JONES)	12	OWNER	GC
FL099	VIKING	VE-8X12-R-1	EMERGENCY PHONE ENCLOSURE (RED) WWW.VIKINGELECTRONICS.COM - (715)388-8861	1	GC	GC
FL100	VIKING	K-1900W-2	EMERGENCY PHONE WWW.VIKINGELECTRONICS.COM - (715)388-8861	1	GC	GC
FL101	DAKTRONICS	GA-1611-0865	PRICE SIGN CONTROL, POS KIT W/ SERIAL SERVER CONTACT: 1-605-462-0200 X31009 (JEREMAH NELSON)	1	OWNER	VENDOR
FL102	VIKING	---	IDPOS GAS SWITCH	1	OWNER	CABLING
FL103	---	---	LIU BOX	1	OWNER	CABLING
FL104	---	---	SECURITY MONITOR AND VIDEO RECORDER	1 EACH	OWNER	SECURITY SERVICES
FL105	NOT USED	---	---	---	---	---

GC = GENERAL CONTRACTOR 072718

IT PLANNING FOR RELEASE
 THIS DOCUMENT IS UNCLASSIFIED
 DATE 05/03/2011 BY 60322 UCBAW/BJS/STP

CONSULTANTS
 David P. Kimball
 PROJECT MANAGER
 414-444-0444
 200 N. BRIDGE ST.
 SUITE 1200
 MILWAUKEE, WI 53202
 PHONE: 414-444-0444
 FAX: 414-444-0444
 EMAIL: DPK@DPM.COM

Sam's CLUB
 CHARLOTTE, NC
 CLUB#: 6540
 USB NUMBER: S449-102
 PHOTO

ISSUE BLOCK

CHECKED BY: JMS
 DRAWN BY: DAD
 FILE NAME: FST6
 PHOTO CYCLE: 102616
 DOCUMENT DATE: 08/20/18

NOT FOR CONSTRUCTION

EQUIPMENT SCHEDULES

SHEET
 FST6