



FIRE ALARM SYSTEM MATRIX

	BUILDING SYSTEM OUTPUTS										CENTRAL COMM	
	ACTIVATE COMMON ALARM SIGNAL INDICATOR	ACTIVATE ALARM ALARM SIGNAL	ACTIVATE COMMON SUPERVISORY SIGNAL	ACTIVATE ALARM SUPERVISORY SIGNAL	ACTIVATE ALARM TROUBLE SIGNAL	ACTIVATE ALARM TROUBLE SIGNAL	ACTIVATE ALARM TROUBLE SIGNAL	ACTIVATE ALARM TROUBLE SIGNAL	ACTIVATE ALARM TROUBLE SIGNAL	ACTIVATE ALARM TROUBLE SIGNAL	ACTIVATE ALARM TROUBLE SIGNAL	
MANUAL FIRE ALARM PULL BOXES	X	X										X
BUILDING SMOKE DETECTOR	X	X										X
DUCT SMOKE DETECTOR		X	X	X								X
FIRE ALARM AC POWER FAILURE			X	X	X							X
FIRE ALARM SYSTEM LOW BATTERY			X	X	X							X
OPEN CIRCUIT			X	X	X							X
GROUND FAULT			X	X	X							X
NOTIFICATION APPLIANCE CIRCUIT SHORT			X	X	X							X
SPRINKLER WATERFLOW	X	X										X
SPRINKLER TAMPER			X	X	X							X
TEMPERATURE SUPERVISORY SIGNAL		X	X									X

WLA
WATTS LEAF ARCHITECTS, PA
101 North McDowell Street, Suite 112
Charlotte, North Carolina 28204
PH 704 376 1200 FX 704 376 5111

ENGINEERING

14301 SOUTH LAKES DRIVE, SUITE E
CHARLOTTE NC 28217
W: 704-688-9320 C: 704-968-8143
CONSULTING - DESIGN-BUILD
NC LICENSE #P-1248

CRABTREE NORTH APTS.
2251 Charles Drive
Raleigh, North Carolina
EYC COMPANIES

PROJECT 1915
DATE 01OCT19
DRAWN BY CME
CHECKED BY CME

ELECTRICAL
DETAILS

E1.04