



D2 Lighting Plan
SCALE: 1/8" = 1'-0"

D1 Gondola Lighting Receptacle Plan
SCALE: 1/8" = 1'-0"



Order Plans @ WWW.LDILine.com

WWW.LDILine.com

GENERAL LIGHTING NOTES:

1. ALL HEIGHT DIMENSIONS (e.g. +8'-6") ARE FROM THE FINISHED FLOOR TO THE CENTERLINE OF THE DEVICE.
2. REFER TO ARCHITECTURAL REFLECTED CEILING PLAN FOR COORDINATION OF LUMINAIRES WITH CEILING GRID.
3. REFER TO SHEET E-001 FOR THE ELECTRICAL MATERIAL LIST AND GENERAL INSTALLATION NOTES.
4. REFER TO DETAIL D1/E-102 FOR LIGHTING LUMINAIRE SCHEDULE, LIGHTING CONTROL AND WIRING DIAGRAM.
5. REFER TO SHEET E-401 FOR SCHEDULE OF CIRCUITS.
6. IN AREAS WHERE NO CEILING IS INSTALLED, CONDUIT SHALL BE RUN JUST BELOW ROOF DECK AT BOTTOM OF UPPER CHORD OF ROOF JOISTS.
7. EXIT LIGHTING FIXTURES SHALL BE CONNECTED TO THE NIGHT LIGHTING BRANCH CIRCUIT L1-1. FIXTURES SHALL NOT BE SWITCHED.
8. EMERGENCY FIXTURES (EM) HAVE EMERGENCY BATTERY BALLAST FACTORY INSTALLED. VERIFY FIXTURE COUNTS AND PLACEMENT OF EMERGENCY FIXTURES PRIOR TO INSTALLATION. NOTIFY ALDI REP OF ANY DISCREPANCIES.
9. CONTRACTOR SHALL ADJUST PLACEMENT OF FIXTURES IN TRUNK SYSTEM. SPOT LIGHTING TYPE N7 FIXTURES SHALL BE CENTERED ON FINAL WALL GRAPHIC LOCATIONS. SPOTS SHOULD THEN BE ADJUSTED TO FULLY ILLUMINATE GRAPHIC FACE.
10. EMERGENCY FIXTURES SHALL BE SERVED WITH ADDITIONAL HOT CONDUCTOR TO EMERGENCY BATTERY SUCH THAT EMERGENCY BATTERY REMAINS ENERGIZED WHEN LIGHTS ARE SWITCHED OFF. FIXTURE SHALL BE NORMALLY CONTROLLED VIA LOCAL CONTROL. FOR CODE REQUIRED EMERGENCY OPERATION THE FIXTURES SHALL BE WIRED SUCH THAT THE LOSS OF POWER INITIATES EMERGENCY OPERATION.

LIGHTING PLAN KEYNOTES:

SEE SHEET E-501 FOR KEYNOTES

Issued:	Date:
A Client Review Set	05/07/19
B Permit Set	06/12/19
C Client Review Set	02/07/20
D Bid Set	02/10/20
Revisions:	Date:

DO NOT SCALE PLANS
Copying, Printing, Software and other processes required to produce these prints can stretch or shrink the actual paper or layout. Therefore, scaling of this drawing may be inaccurate. Contact ms consultants with any need for additional dimensions or clarifications.



ms consultants, inc.
engineers, architects, planners
5444 Wade Park Blvd.
Suite 160
Raleigh, NC 27607-4299
phone 919.772.5565
fax 919.779.2308

DRAWN BY: MEM
REVIEWED BY: KFF

Seal

PROFESSIONAL OF RECORD:
JASON E. CHRISTOFF No. 039391
EXP. DATE: 12/31/2020



ALDI Inc.
1985 Old Union Church Road
Salisbury, NC 28146
(704) 442-0022
(704) 642-0078 fax

ALDI Inc. Store #: 154
Cornelius, NC
20101 West Catawba Avenue
Cornelius, NC 28031
Mecklenburg County
Project Name & Location:

Lighting Plan Drawing Name:	Project No. 40452-07
Prototype Rls. 12/10/18	
Type: LHSD-V8ER	
	E-101
Scale: As Noted	Drawing No.