


GENERAL NOTES

- A. COORDINATE ALL LOCATIONS AND ELEVATIONS WITH ARCHITECTURAL DRAWINGS ARCHITECTURAL SKETCHES AND EQUIPMENT SUPPLIERS. AVOID CONFLICTS BETWEEN EXIT SIGNS AND TV'S, NEON SIGNS, DRAPERIES, ETC.
- B. BATTERY PACKS ARE TO BE DIRECT WIRED. NO EXPOSED WIRING IS PERMITTED.
- C. ELECTRICAL CONTRACTOR TO PROVIDE STEEL ANGLES AND HARDWARE REQUIRED FOR SUSPENDING ALL HANGING LIGHT FIXTURES, CEILING FANS ETC.. ALL EXPOSED CONDUIT, JUNCTION BOXES, MOUNTING HARDWARE ETC.. TO BE RUN AS NEAT AS POSSIBLE AT UNDERSIDE OF ROOF DECK AND IS TO BE PAINTED.
- D. ALL WIRING, DEVICES AND FIXTURES INSIDE THE WALK-IN FREEZER, WALK-IN COOLER AND BEER COOLER ARE TO BE VAPOR PROOF. SEAL ALL CONDUIT PENETRATIONS WITH SILICONE.
- E. USE FLEXIBLE METAL CONDUIT (GREENFIELD) FOR CONNECTION OF LAY-IN FIXTURES.
- F. PROVIDE GROUND CONDUCTOR IN ALL CONDUIT RUNS (NOT ILLUSTRATED).
- G. THROUGH WIRING OF FIXTURES SHALL NOT BE PERMITTED UNLESS SPECIFICALLY ILLUSTRATED.
- H. EACH LIGHTING FIXTURE SHALL HAVE ITS OWN BOX UNLESS OTHERWISE ILLUSTRATED.
- I. VERIFY LOCATION OF WALL MOUNTED EMERGENCY LIGHT FIXTURES TO AVOID CONFLICT WITH WOOD TRIM.
- J. REFER TO ARCHITECTURAL DRAWINGS FOR LOCATION OF LIGHTING FIXTURES. COORDINATE WITH ARCHITECT FOR LOCATION OF LIGHTING FIXTURES AND DEVICES IN ROOMS WITH WALK-IN.
- K. SEE KITCHEN EQUIPMENT DRAWINGS FOR KITCHEN FIXTURES ELECTRICAL SCHEDULE AND ROUTING DIRECTIONS.
- L. SEE SHEET E3.3 FOR ADDITIONAL ROOF MOUNTED, GROUND MOUNTED, AND POLE MOUNTED LIGHT FIXTURES.
- M. WIRING OF EMERGENCY LIGHT FIXTURES SHALL CONFORM TO THE CITY OF FIRE MARSHAL'S OFFICE EMERGENCY WIRING CRITERIA.

KEYED NOTES

- 1. INTERLOCK HOOD LIGHT WITH HOOD ON/OFF SWITCH. CIRCUIT TO SHUT OFF THRU SHUNT OF PANEL 'B' CIRCUIT B-58.
- 2. LOCATE FIXTURE 'IN INTERIOR SOFFIT. REFER TO ARCHITECTURAL SECTIONS FOR MOUNTING.
- 3. HOOD LIGHTS FURNISHED AND INSTALLED WITH HOOD.
- 4. SWITCHBANK DETAIL. REFER TO DETAIL 2/E3.2.
- 5. SEE SHEET E1.2 FOR POWER CONNECTION AND SWITCHING.
- 6. CONNECT TO UNSWITCHED LEG OF CIRCUIT FOR EMERGENCY, EXIT AND NIGHT LIGHTING.
- 7. VIA PHOTOCELL THROUGH CONTACTOR.
- 8. DASHED LINE INDICATES DAYLIGHT ZONED AREA REQUIRING SEPARATE SWITCHING.
- 9. CONTRACTOR SHALL COORDINATE LOCATION OF WEATHERPROOF JUNCTION BOX WITH OWNER AND SIGN MANUFACTURER. CONTRACTOR SHALL COORDINATE REQUIREMENTS FOR LED RIBBON LIGHTING, I.E. QUANTITY, POWER SUPPLY, LOW VOLTAGE XFORM. AND ALL REQUIRED APPURTENANCES. WITH LED RIBBON MANUFACTURER PRIOR TO ROUGH-IN AND PROVIDE AS NECESSARY.

LOBBY AND ENTRY LOBBY HAVE MOVED TO BEST ELEVATION REFER TO SHEET A12 FOR UPDATED LAYOUT



BELL & ASSOCIATES ARCHITECTS
 ALAN BELL, DOUG ELKINS, MARK SHULTZ, & TROY BELL
 alanbell@architect.com
 128 LOYDEN ROAD
 CARROLLTON, GEORGIA 30117
 PHONE (770) 850-6866 FAX (770) 850-6066

REVISIONS	BY

NEW RESTAURANT FOR:

 VILLA RICA, GEORGIA

CONTRACTOR SHALL VERIFY ALL CONDITIONS AND DIMENSIONS BEFORE EXECUTING ANY WORK. THIS DOCUMENT IS THE SOLE PROPERTY OF ALAN BELL ARCHITECT AND SHALL NOT BE COPIED IN WHOLE OR IN PART WITHOUT EXPRESSED WRITTEN CONSENT FROM ALAN BELL ARCHITECT.



DATE: 1/28/2010
 SCALE: AS NOTED
 JOB NO.: 18-015-D01
 SHEET
 E11
 OF 3 SHEETS