



NOTE:
 1. FINAL RTU LOCATION PER TENANT DRAWINGS. RTUS TO NOT BE LOCATED WITHIN THE CAFE AREA.
 2. EXHAUST FAN NOT TO BE LOCATED WITHIN THE CAFE AREA. MATCH LOCATION PER FINAL TENANT DRAWINGS.

NOTE: ALL ANCHORS OR FASTENERS TO CONFORM TO LOCAL BUILDING CODE REQUIREMENTS TO RESIST WIND UPLIFT FORCES.
 FASTEN CURB TO BLOCKING OR STEEL FRAMING AT 12" O.C.
 CONTINUOUS GASKET
 18" ROOF CURB MIN.
 1 1/2" RIGID INSULATION
 SOUND AND AIR Baffle
 1" INSULATION
 PLYWOOD DECK (MATCH EXISTING)
 NOTE: PROVIDE WOMINIZED BLOCKING ON TOP OF 6"x6" ANGLE IF REQUIRED WHEN LEVELING ANGLE IS NOT SUFFICIENT TO MAINTAIN HEIGHT FROM TOP OF CURB TO TOP OF ROOF A FULL 1'-0" BOLT BLOCKING TO 6"x6" STEEL FRAME WITH MINIMUM 3/8" NON-CORROSIVE BOLTS AT 12" O.C.
 MINIMUM SIZE* HVAC LEVELING ANGLE 6"x6" C5/16" ANGLE TRIM ANGLE AS REQUIRED UNLESS STRUCTURAL ENGINEER INDICATES A LARGER SIZE. WELD PERIMETER ANGLE.
 HVAC SUPPORT STEEL FRAMING TO BE SECURED TO ROOF STEEL PER STRUCTURAL ENGINEERS REQUIREMENTS.

Order plans @

WWW.LDILINE.COM