

## 5700 Building: Interior Renovation

#19161 (Permit No. 20-10581)

24 March 2020

### Addendum No. 1

The following changes and clarifications were made to the Contract Documents in response to comments from the City of Chattanooga. These items are specifically listed below per discipline:

#### Item 1: Sheet A002 – CODE SUMMARY

- \* Total occupancy count adjusted from 137 occupants to 126 occupants based on:
  - o #103 Hall and #140 Hall were previously listing 8 occupants each but have been changed to 0 since these are exit corridors.
  - o Exam Rooms #112, #113, #114, #121, #122, #123, #124, #125, and #126 were previously listing 1 occupant each and has been updated for 2 occupants each.
  - o #120 Resources was listing 1 occupant but has been changed to 0 since this is a storage closet.
  - o #132 Lobby changed to #132 Entry since this is a staff entry/exit only and occupancy changed from 3 to 0.
- \* Sheet reissued

#### Item 2: Sheet A010 – LIFE SAFETY PLAN

- \* Exit paths and counts have been revised and clarified based on the information above.
- \* Sheet reissued.

#### Item 3: Sheet A111 – FLOOR PLAN – WEST SIDE

- \* An ADA clear floor space for parallel approach designated at #128 Breakroom sink.
- \* Sheet reissued.

#### Item 4: Sheet A701 – INTERIOR ELEVATIONS

- \* Millwork at #128 Breakroom sink lowered for ADA access.
- \* Sheet reissued.

End of Addendum No. 1

