


Order Plans @ WWW.LDILINE.COM

1 REFRIGERATION ELECTRICAL POWER PLAN

3/32" = 1'-0"

NOTE: ALL WORK RELATED TO REFRIGERANT LEAK DETECTION SYSTEM TO BE PROVIDED AS ADD ALTERNATE #.




ASSOCIATE MEZZANINE

REFRIGERATION KEYNOTE LEGEND

Key Value	Keynote Text
R1	PROVIDE (1) SET OF BELDON #8751 #22 3 SHIELDED CABLE FOR EACH TEMPERATURE SENSOR AND DEFROST TERMINATION SENSOR SHOWN. PROVIDE 3/4" CONDUIT UNLESS NOTED OTHERWISE TO THE REFRIGERATION UNIT NOTED ON DRAWING. PROVIDE LENGTH OF CABLE AS REQUIRED. SEE REFRIGERATION PLANS FOR MORE INFORMATION.
R4	CONTRACTOR TO PROVIDE ALL ELECTRICAL DEVICES (WIRING, CONDUIT, BREAKERS, ETC.) AS REQUIRED FOR NEW REFRIGERATION UNITS AS INDICATED ON REFRIGERATION PLANS. PROVIDE NEW BREAKERS AND WIRING AS REQUIRED FOR ALL REFRIGERATION RACKS WITH MODIFIED LOADS. COORDINATE EXACT REQUIREMENTS WITH REFRIGERATION INSTALLER PRIOR TO BEGINNING. SEE REFRIGERATION PLANS AND DASH ISN ALL INFORMATION SPECIFICATIONS SECTION 114146-00 FOR MORE INFORMATION.
R5	LEAK DETECTION CONTROL PANEL TO BE MOUNTED ON COMPRESSOR MEZZANINE. COORDINATE EXACT LOCATION WITH KROGER PROJECT MANAGER. CONTRACTOR TO PROVIDE 50W CIRCUIT FROM NEAREST ELECTRICAL PANEL WITH AVAILABLE CAPACITY. PROVIDE ALL ELECTRICAL DEVICES AS REQUIRED. SEE SHEET EM-3 AND SPECIFICATION SECTION 114146 FOR MORE INFORMATION. MAKE ALL FINAL CONNECTIONS.
R7	FIELD LOCATE LEAK DETECTION SENSORS IN RETURN DUCT PER SPECIFICATION SECTION 114146. COORDINATE WITH MECHANICAL CONTRACTOR AS REQUIRED.
R8	LEAK DETECTION SENSOR TO BE MOUNTED ON COLUMN NEAR DELI AREA REFRIGERATED CASES PER SPECIFICATION SECTION 114146. COORDINATE EXACT LOCATION WITH KROGER PROJECT MANAGER. MAKE ALL FINAL CONNECTIONS.
R9	LEAK DETECTION SENSOR TO BE MOUNTED ON COLUMN NEAR FROZEN GLASS DOOR CASES PER SPECIFICATION SECTION 114146. COORDINATE EXACT LOCATION WITH KROGER PROJECT MANAGER. MAKE ALL FINAL CONNECTIONS.
R9	HORN AND STROBE TO BE LOCATED IN THE MANAGER'S OFFICE OR CUSTOMER SERVICE PER SPECIFICATION SECTION 114146. COORDINATE WITH KROGER PROJECT MANAGER.

2 REFRIGERATION ELECTRICAL POWER PLAN - REAR MEZZANINE

3/32" = 1'-0"



2 REFRIGERATION ELECTRICAL POWER PLAN - FRONT MEZZANINE

3/32" = 1'-0"

SEE SHEET E01 FOR REFRIGERANT LEAK DETECTION SYMBOL LEGEND AND ZONE SCHEDULE.



REVISIONS

NO.	DESCRIPTION

REFRIGERATION ELECTRICAL POWER PLAN

03-06-20

20-108

E1.3.1