

Order Plans

EXISTING B
LOCATION: 120208 Wye
PHASES: 3
WIRES: 4
A.I.C. RATING:
MAINS TYPE:
MAINS RATING: 400 A
MCB RATING: 1 A

EXISTING LN
LOCATION: 120208 Wye
PHASES: 3
WIRES: 4
A.I.C. RATING:
MAINS TYPE:
MAINS RATING: 100 A
MCB RATING: 1 A

EXISTING LR
LOCATION: 120208 Wye
PHASES: 3
WIRES: 4
A.I.C. RATING:
MAINS TYPE:
MAINS RATING: 100 A
MCB RATING: 1 A

EXISTING L1-2
LOCATION: 120208 Wye
PHASES: 3
WIRES: 4
A.I.C. RATING:
MAINS TYPE:
MAINS RATING: 225 A
MCB RATING: 1 A

EXISTING LO
LOCATION: 120208 Wye
PHASES: 3
WIRES: 4
A.I.C. RATING:
MAINS TYPE:
MAINS RATING: 100 A
MCB RATING: 1 A

EXISTING LW
LOCATION: 120208 Wye
PHASES: 3
WIRES: 4
A.I.C. RATING:
MAINS TYPE:
MAINS RATING: 100 A
MCB RATING: 1 A

EXISTING LEE
LOCATION: 120208 Wye
PHASES: 3
WIRES: 4
A.I.C. RATING:
MAINS TYPE:
MAINS RATING: 100 A
MCB RATING: 1 A

EXISTING LQ
LOCATION: 120208 Wye
PHASES: 3
WIRES: 4
A.I.C. RATING:
MAINS TYPE:
MAINS RATING: 100 A
MCB RATING: 1 A

EXISTING PD2
LOCATION: 120208 Wye
PHASES: 3
WIRES: 4
A.I.C. RATING:
MAINS TYPE:
MAINS RATING: 100 A
MCB RATING: 1 A

ALL ELECTRICAL PANELS ARE EXISTING
ALL ELECTRICAL PANELS TO BE LABELED IN ACCORDANCE WITH NATIONAL ELECTRIC CODE (NEC) ARTICLE 408.4
CIRCUIT DESIGNATIONS SHOWN IN ELECTRICAL PANELS IS BASED ON EXISTING DRAWINGS AND SITE SURVEY AND MAY NOT BE ACCURATE. CONTRACTOR TO VERIFY ALL INFORMATION IN FIELD.

ROBERTSON LOIA ROOF ARCHITECTS & ENGINEERS
3460 Peachtree Ridge Road - Suite 275 - Alpharetta, GA, 30005
770.974.2607 / www.rliar.com



Kroger GA-291
2175 Park Lake Drive, Atlanta, GA

REVISIONS

Table with 3 columns: No., Description, Date. Contains revision information.

PANEL SCHEDULES
03-06-20
20-108
E6.2.1