



DEKALB PEACHTREE AIRPORT
DEKALB COUNTY, GEORGIA

Michael Baker INTERNATIONAL

Designer:
GHL/RES
Technician:
GHL/RES
Checked by:
GHL
Project Number:
174297





Notes:



MAKE UP CABLE:
1/C #8, 5KV, L-824C MAKE-UP SLACK CABLE SHALL BE 5' PER CABLE AT EACH LIGHT BASE. IT ALLOWS FOR 2' IN THE BASE AND 3' ABOVE THE BASE. A 10' TOTAL OF MAKE UP CABLE FOR BOTH CABLES.

NOTES:
1. ALL BOLTS SHALL BE STAINLESS STEEL.
2. APPLY ANTI-SEIZE TO ALL MALE THREADS.



SECTION
BASE MOUNTED MEDIUM INTENSITY TAXIWAY LIGHT IN TURF SHOULDER DETAIL
N.T.S.

NOTE: AIRPORT WILL NOT ALLOW L-861(L) LED MEDIUM INTENSITY TAXIWAY LIGHTS.

PLAN
BASE MOUNTED MEDIUM INTENSITY TAXIWAY LIGHT IN TURF SHOULDER DETAIL
N.T.S.

REVISIONS			
No.	Description	Date	By

Project Name:
RUNWAY INCURSION MITIGATION IMPROVEMENTS (PDK 11)

Drawing Name:
LIGHTING DETAILS PLAN NO. 1

ITB# 20-101257
Date: **FEBRUARY, 2020** Sheet Number: **60** of **72**
Scale: **NTS** Drawing Number: **LD-1**