



1627 S. NORTON RD  
 GRAND ISLAND, NE 68602  
 402.388.7782  
 www.chiefs.com


April 9, 2020

Re: Chief Order No. 83018991  
 Description: 55'-0" x 85'-0" x 14'-10 1/2"  
 Builders Name: O'Reilly AutoCenter  
 Building Owners Name: O'Reilly Store 16R71815  
 Address City, State: Ocala, FL



To Whom It May Concern:

With reference to the above mentioned building, please accept this letter as certifying that the construction of the roof curb and the roof beams has been analyzed and designed for the design, overloading, and uplift forces using the applicable wind loads based on the 2017 Florida Building Code (FBC2017) with an ultimate wind speed of 121 mph and exposure category C. See attached RCS details.

Christopher D. Larson, P.E., S.E.  
 Engineering Supervisor  
 Chief Buildings




Trusted. Tested. True.



Abby L  
 Thurman

Digitally signed by Abby L Thurman  
 DN: c=US, o=Unaffiliated, ou=A01410D000016DD, 534378000003578, cn=Abby L Thurman  
 Date: 2020.04.21 10:21:18 -05'00'

Order Plans @ www.LDILiving.com



ABBY L. THURMAN  
 FL Lic #86329  
 Firm Lic #27905

SHEETS BEARING THIS SEAL ARE AUTHENTICATED. RESPONSIBILITY FOR ALL OTHER PLANS, SPECIFICATIONS OR INSTRUMENTS ARE DISCLAIMED.

04/10/2020


**O'Reilly AUTO PARTS**

CORPORATE OFFICES  
 233 SOUTH PATTERSON  
 SPRINGFIELD, MISSOURI 65802  
 (417) 862-2674 TELEPHONE

PROJECT:  
 NEW O'REILLY AUTO PARTS STORE  
 2425 COUNTY HIGHWAY 484  
 OCALA, FLORIDA

HVAC WIND LOAD DETAILS

3885 S. JEFFERSON AVE.  
 SPRINGFIELD, MO 65807  
 P: 417-882-2200  
 F: 417-882-1188  
 www.smithcloth.com



DRAWN BY: LHT  
 CHECKED BY: ALT/BLC

DATE: 04/01/2020

REVISION:

PROJECT NUMBER: OF7

SHEET NUMBER

**M4**

REPRODUCTION PROHIBITED WITHOUT THE EXPRESSED WRITTEN CONSENT OF THE DESIGN PROFESSIONAL. © COPYRIGHT 2020-2021