



A TREE PROTECTION FENCE - ELEVATION
SCALE: NOT TO SCALE




C TREE PROTECTION FENCE - LEVEL 2
SCALE: NOT TO SCALE




B TREE PROTECTION FENCE
SCALE: NOT TO SCALE

TREES THAT ARE MARKED TO BE PRESERVED ON A SITE PLAN AND FOR WHICH UTILITIES MUST PASS THROUGH THEIR ROOT PROTECTION ZONES MAY REQUIRE TUNNELING AS OPPOSED TO OPEN TRENCHES. THE DECISION TO TUNNEL WILL BE DETERMINED ON A CASE BY CASE BASIS BY THE ENGINEER.

TUNNELS SHALL BE DUG THROUGH THE ROOT PROTECTION ZONE IN ORDER TO MINIMIZE ROOT DAMAGE.



TUNNEL TO MINIMIZE ROOT DAMAGE (TOP) AS OPPOSED TO SURFACE-DUG TRENCHES IN ROOT PROTECTION ZONE WHEN THE 5' MINIMUM DISTANCE FROM TRUNK CAN NOT BE ACHIEVED.



D BORING THROUGH ROOT PROTECTION ZONE
SCALE: NOT TO SCALE

- NOTES:
1. THE FENCING LOCATION SHOWN ABOVE IS DIAGRAMATIC ONLY AND WILL CONFORM TO THE DRIP LINE AND BE LIMITED TO PROJECT BOUNDARY. WHERE MULTIPLE ADJACENT TREES WILL BE ENCLOSED BY FENCING, THE FENCING SHALL BE CONTINUOUS AROUND ALL TREES.
 2. FOR ACCEPTABLE FENCING MATERIALS SEE SPECIFICATIONS.

TREE PROTECTION SPECIFICATIONS

MATERIALS

1. FABRIC: 4 FOOT HIGH ORANGE PLASTIC FENCING AS SHOWN ON THE PLANS AND SHALL BE WOVEN WITH 2 INCH MESH OPENINGS SUCH THAT IN A VERTICAL DIMENSION OF 23 INCHES ALONG THE DIAGONALS OF THE OPENINGS THERE SHALL BE AT LEAST 7 MESHERS.
2. POSTS: POSTS SHALL BE A MINIMUM OF 72 INCHES LONG AND STEEL 'T' SHAPED WITH A MINIMUM WEIGHT OF 1.3 POUNDS PER LINEAR FOOT.
3. TIE WIRE: WIRE FOR ATTACHING THE FABRIC TO THE T-POSTS SHALL BE NOT LESS THAN NO. 12 GAUGE GALVANIZED WIRE.
4. USED MATERIALS: PREVIOUSLY USED MATERIALS, MEETING THE ABOVE REQUIREMENTS AND WHEN APPROVED BY THE OWNER, MAY BE USED.

CONSTRUCTION METHODS

1. ALL TREES AND SHRUBS SHOWN TO REMAIN WITHIN THE PROXIMITY OF THE CONSTRUCTION SITE SHALL BE PROTECTED PRIOR TO BEGINNING ANY DEVELOPMENT ACTIVITY.
2. EMPLOY THE SERVICES OF AN ISA (INTERNATIONAL SOCIETY OF ARBORICULTURE) CERTIFIED ARBORIST AND OBTAIN ALL REQUIRED PERMITS TO PRUNE, THE EXISTING TREES FOR CLEANING, RAISING AND THINNING, AS MAY BE REQUIRED.
3. PROTECTIVE FENCING SHALL BE ERECTED OUTSIDE THE CRITICAL ROOT ZONE (CRZ, EQUAL TO 1' FROM THE TRUNK FOR EVERY 1" OF DBH) AT LOCATIONS SHOWN IN THE PLANS OR AS DIRECTED BY THE LANDSCAPE CONSULTANT AND/OR CITY ARBORIST, AND IN ACCORDANCE WITH THE DETAILS SHOWN ON THE PLANS. FENCING SHALL BE MAINTAINED AND REPAIRED BY THE CONTRACTOR DURING SITE CONSTRUCTION. TREES IN CLOSE PROXIMITY SHALL BE FENCED TOGETHER, RATHER THAN INDIVIDUALLY.
4. PROTECTIVE FENCE LOCATIONS IN CLOSE PROXIMITY TO STREET INTERSECTIONS OR DRIVES SHALL ADHERE TO THE APPLICABLE JURISDICTION'S SIGHT DISTANCE CRITERIA.
5. THE PROTECTIVE FENCING SHALL BE ERECTED BEFORE SITE WORK COMMENCES AND SHALL REMAIN IN PLACE DURING THE ENTIRE CONSTRUCTION PHASE.
6. THE INSTALLATION POSTS SHALL BE PLACED EVERY 6 FEET ON CENTER AND EMBEDDED TO 18 INCHES DEEP. MESH FABRIC SHALL BE ATTACHED TO THE INSTALLATION POSTS BY THE USE OF SUFFICIENT WIRE TIES TO SECURELY FASTEN THE FABRIC TO THE T-POSTS TO HOLD THE FABRIC IN A STABLE AND UPRIGHT POSITION.
7. WITHIN THE CRZ:
 - a. DO NOT CLEAR, FILL OR GRADE IN THE CRZ OF ANY TREE.
 - b. DO NOT STORE, STOCKPILE OR DUMP ANY JOB MATERIAL, SOIL OR RUBBISH UNDER THE SPREAD OF THE TREE BRANCHES.
 - c. DO NOT PARK OR STORE ANY EQUIPMENT OR SUPPLIES UNDER THE TREE CANOPY.
 - d. DO NOT SET UP ANY CONSTRUCTION OPERATIONS UNDER THE TREE CANOPY (SUCH AS PIPE CUTTING AND THREADING, MORTAR MIXING, PAINTING OR LUMBER CUTTING).
 - e. DO NOT NAIL OR ATTACH TEMPORARY SIGNS, METERS, SWITCHES, WIRES, BRACING OR ANY OTHER ITEM TO THE TREES.
 - f. DO NOT PERMIT RUNOFF FROM WASTE MATERIALS INCLUDING SOLVENTS, CONCRETE WASHOUTS, ASPHALT TACK COATS (MC-30 OIL), ETC. TO ENTER THE CRZ. BARRIERS ARE TO BE PROVIDED TO PREVENT SUCH RUNOFF SUBSTANCE FROM ENTERING THE CRZ WHENEVER POSSIBLE, INCLUDING IN AN AREA WHERE RAIN OR SURFACE WATER COULD CARRY SUCH MATERIALS TO THE ROOT SYSTEM OF THE TREE.
8. ROUTE UNDERGROUND UTILITIES TO AVOID THE CRZ. IF DIGGING IS UNAVOIDABLE, BORE UNDER THE ROOTS, OR HAND DIG TO AVOID SEVERING THEM.
9. WHERE EXCAVATION IN THE VICINITY OF TREES MUST OCCUR, SUCH AS FOR IRRIGATION INSTALLATION, PROCEED WITH CAUTION, AND USING HAND TOOLS ONLY.
10. THE CONTRACTOR SHALL NOT CUT ROOTS LARGER THAN ONE INCH IN DIAMETER WHEN EXCAVATION OCCURS NEAR EXISTING TREES. ALL ROOTS LARGER THAN ONE INCH IN DIAMETER ARE TO BE CUT CLEANLY FOR OAKS ONLY, ALL WOUNDS SHALL BE PAINTED WITH WOUND SEALER WITHIN 30 MINUTES.
11. REMOVE ALL TREES, SHRUBS OR BUSHES TO BE CLEARED FROM PROTECTED ROOT ZONE AREAS BY HAND.
12. TREES DAMAGED OR KILLED DUE TO CONTRACTOR'S NEGLIGENCE DURING CONSTRUCTION SHALL BE MITIGATED AT THE CONTRACTOR'S EXPENSE AND TO THE PROJECT OWNER'S AND LOCAL JURISDICTION'S SATISFACTION.
13. ANY TREE REMOVAL SHALL BE APPROVED BY THE OWNER AND LOCAL JURISDICTION PRIOR TO ITS REMOVAL AND THE CONTRACTOR SHALL HAVE ALL REQUIRED PERMITS FOR SUCH ACTIVITIES.
14. COVER EXPOSED ROOTS AT THE END OF EACH DAY WITH SOFT MULCH OR WET BURLAP.
15. IN CRITICAL ROOT ZONE AREAS THAT CANNOT BE PROTECTED DURING CONSTRUCTION AND WHERE HEAVY TRAFFIC IS ANTICIPATED, COVER THE SOIL WITH EIGHT INCHES OF ORGANIC MULCH TO MINIMIZE SOIL COMPACTION. THIS EIGHT INCH DEPTH OF MULCH SHALL BE MAINTAINED THROUGHOUT CONSTRUCTION.
16. WATER ALL TREES IMPACTED BY CONSTRUCTION ACTIVITY DAILY ONCE A WEEK DURING PERIODS OF HOT DRY WEATHER. SPRAY TREE TRUNKS WITH WATER DAILY TO REDUCE DUST ACCUMULATION ON THE LEAVES.
17. WHEN INSTALLING CONCRETE ADJACENT TO THE CRZ OF A TREE, USE A PLASTIC VAPOR BARRIER BEHIND THE CONCRETE TO PREVENT LEACHING OF SALTS TO THE SOIL.
18. CONTRACTOR SHALL REMOVE AND DISPOSE OF ALL TREE PROTECTION FENCING WHEN ALL THREATS TO THE EXISTING TREES FROM CONSTRUCTION RELATED ACTIVITIES HAVE BEEN REMOVED.

TREE INVENTORY

TREE NO.	COMMON NAME	DBH (in inches)	DISPOSITION	DESIGNATION	REQUIRED REPLACEMENT
1	OAK	36	REMAIN	SPECIMEN	--
2	OAK	30	REMOVE	SPECIMEN	10" DBH
3	OAK	38	REMOVE	SPECIMEN	13" DBH
4	OAK	19	REMAIN	PROTECTED	NOT REQUIRED
5	PINE	10	REMAIN	--	--
6	PINE	10	REMAIN	--	--
7	PINE	9	REMAIN	--	--
8	PINE	8	REMAIN	--	--
9	OAK	16	REMAIN	PROTECTED	NOT REQUIRED
10	PINE	8	REMAIN	--	--
11	PINE	10	REMAIN	OFF SITE	--
12	PINE	11	REMAIN	OFF SITE	--
13	OAK	16	REMAIN	OFF SITE	--
14	PINE	11	REMAIN	OFF SITE	--
15	PINE		REMAIN	OFF SITE	--
16	PINE		REMAIN	OFF SITE	--
17	OAK		REMAIN	OFF SITE	--
18	PINE		REMAIN	OFF SITE	--
19	PINE		REMAIN	OFF SITE	--
20	PINE		REMAIN	OFF SITE	--
21	OAK	16	REMOVE	PROTECTED	4" DBH
22	PINE		REMOVE	--	--
23	PINE		REMOVE	--	--
24	PINE		REMOVE	--	--
25	OAK	20	REMOVE	PROTECTED	5" DBH
26	PINE		REMOVE	--	--
27	PINE		REMOVE	--	--
28	PINE		REMOVE	--	--
29	OAK		REMAIN	OFF SITE	--
30	PINE		REMAIN	OFF SITE	--
31	PINE		REMAIN	OFF SITE	--
32	PINE		REMAIN	OFF SITE	--
TOTAL REPLACEMENT:					32" DBH
TOTAL 4" CAL. TREES					8 TREES

CANOPY COVERAGE CALCULATIONS

EXISTING CANOPY COVERAGE REMOVED:

TREE ID	DIAMETER (FT)	COVERAGE (SF)
TREE #21	40	1,256
TREE #22	10	79
TREE #23	10	79
TREE #24	10	79
TREE #25	40	1,256
TREE #26	10	79
TREE #27	10	79
TREE #28	10	79
TOTAL REMOVED COVERAGE:		2,986 SF

REPLACEMENT CANOPY COVERAGE:

- (2) LIVE OAKS @ 4" CALIPER = 3,180 COVERAGE
(25% OF PROJECTED CANOPY COVERAGE @ MATURITY = 1,590 SF)

NO.	REVISIONS	DATE
1	CITY COMMENTS	4/7/2020
2	COMMENTS	XX-XX-XXXX

JOB NO.	DESIGNED	DRAWN	DATE	CHECKED	DATE ISSUED
19-1045	KB	KB	NOVEMBER 2019	KB/RM	11/11/2019

MBV ENGINEERING, INC.
 1550 W. EAU CALLEE BLVD.
 MELBOURNE, FLORIDA 32935
 P-321-253-1510 F-321-253-0811
 VERO 772-592-0025 FT PIERCE 772-488-8095

TREE DISPOSITION TABLE, SPECIFICATIONS, & DETAILS

CHRISTIAN BROTHERS AUTOMOTIVE REPAIRS



SHEET

TD-2

19-1045



EVERGREEN DESIGN GROUP
 (800) 688-6630
 2255 Glades Road, Suite 334A
 Boca Raton, FL 33431
 www.EvergreenDesignGroup.com
 LC #26000612

Order Plans @