SYMBOLS LEGEND

	DUPLEX RECEPTACLE; 18" AFF UNLESS NOTED OTHERWISE		LIGHT FIXTURE; SURFACE
	SIMPLEX RECEPTACLE; 18" AFF UNLESS NOTED OTHERWISE		LIGHT FIXTURE; RECESSED
	QUARDUPLEX RECEPTACLE; 18" AFF UNLESS NOTED OTHERWISE		LIGHT FIXTURE; SURFACE EMERGENCY
	SPECIAL OCCASION RECEPTACLE; 18" AFF UNLESS NOTED OTHERWISE		LIGHT FIXTURE; RECESSED EMERGENCY
	SWITCHED RECEPTACLE; 18" AFF UNLESS NOTED OTHERWISE		LIGHT FIXTURE; SURFACE CAN
	DUPLEX FLOOR RECEPTACLE; FLUSH		LIGHT FIXTURE; RECESSED CAN
	SIMPLEX FLOOR RECEPTACLE; FLUSH		LIGHT FIXTURE; WALL SCONCE
	QUADRUPLEX FLOOR RECEPTACLE; FLUSH		LIGHT FIXTURE; WALL WASH
	SPECIAL OCCASION FLOOR RECEPTACLE; FLUSH		LIGHT FIXTURE; PENDANT
	SWITCHED FLOOR RECEPTACLE; FLUSH		EXIT SIGN; SINGLE
	DATA JACK; SINGLE OR DOUBLE		EXIT SIGN; DOUBLE
	VOICE JACK; SINGLE OR DOUBLE		EXIT SIGN; SINGLE WALL MOUNTED
H	HOUSE PHONE JACK; 46" AFF		EXIT SIGN; DOUBLE WALL MOUNTED
	DATA/VOICE JACK; SINGLE OR DOUBLE		EXIT SIGN; FLOOR LEVEL
	DATA JACK; SINGLE OR DOUBLE; FLUSH		CEILING FAN
	VOICE JACK; SINGLE OR DOUBLE; FLUSH		SPEAKER LOCATION FOR OFOI MUSIC/PAGING SYSTEM; ELECTRICAL CONTRACTOR SHALL PROVIDE JUNCTION BOX AND EMPTY 3/4" CONDUIT WITH PULLSTRING PER PLANS
	DATA/VOICE JACK; SINGLE OR DOUBLE; FLUSH	V	EMPTY JUNCTION BOX WITH CONDUIT AND PULLSTRING TO ACCESSIBLE CEILING FOR OFOI VOLUME CONTROLLER
	NON-FUSED DISCONNECT		CIRCUIT; CONCEALED IN WALLS OR CEILINGS
	FUSED DISCONNECT		CIRCUIT; CONCEALED IN SLAB FLOORS
	JUNCTION BOX	EF	EXHAUST FAN
	FLOOR JUNCTION BOX	GFI	GROUND FAULT INTERRUPTER
	MOTOR	AFCI	ARC FAULT CIRCUIT INTERRUPTER
	MOTOR STARTER	IG	ISOLATED GROUND
R	DOOR RELEASE RELAY AND PUSH BUTTON	CTR	COUNTERTOP; LOCATE AT 6" ABOVE TABLE, COUNTER TOP OR BACK SPLASH
T	TRANSFORMER	WH	WATER HEATER
IC	INTERCOM	WP	WEATHER PROOF
K	CARD KEY READER	OFOI	OWNER FURNISHED, OWNER INSTALLED
TV	TELEVISION	USB	2 INTEGRATED USB PORTS - RECEPTACLES
	VISUAL DOORBELL	FIRE ALARM SYMBOLS LEGEND	
	DOORBELL CHIME AND LIGHT	FH	HORN STROBE; 80" AFF TO BOTTOM OR 6" BELOW CEILING TO TOP (WHICHEVER IS LOWER)
	ELECTRICAL PANEL; FLUSH	FH	FIRE HORN; 80" AFF TO BOTTOM OR 6" BELOW CEILING TO TOP (WHICHEVER IS LOWER)
	ELECTRICAL PANEL; RECESSED	FV	GUESTROOM MINI HORN; 80" AFF TO BOTTOM OR 6" BELOW CEILING TO TOP (WHICHEVER IS LOWER)
	WALL HEATER		GUESTROOM MINI HORN STROBE; 80" AFF TO BOTTOM OR 6" BELOW CEILING TO TOP (WHICHEVER IS LOWER)
$	SWITCH; SINGLE POLE	F	FIRE ALARM PULL STATION; MANUAL; 48" TO TOP
$2	SWITCH; TWO POLE	S	SMOKE DETECTOR; BETWEEN 4" AND 12" DOWN FROM CEILING TO TOP OF DETECTOR
$3	SWITCH; THREE WAY	SCO	SMOKE DETECTOR; WITH SOUNDER BASE; BETWEEN 4" AND 12" DOWN FROM CEILING TO TOP OF DETECTOR
$4	SWITCH; FOUR WAY	H	HEAT DETECTOR; BETWEEN 4" AND 12" DOWN FROM CEILING TO TOP OF DETECTOR
$K	SWITCH; KEYED	CO	CARBON MONOXIDE DETECTOR; TIED INTO FIRE ALARM SYSTEM
$D	SWITCH; DIMMABLE		DUCT MOUNTED SMOKE DETECTOR
$T	SWITCH; TIMMED; DIGITAL 15 MINUTE WATTSTOPPER TS-200 OR EQUAL		STROBE LIGHT; 80" AFF TO BOTTOM OR 6" BELOW CEILING TO TOP (WHICHEVER IS LOWER)
$M	SWITCH; MOMENTARY; SINGLE POLE; DOUBLE THROW; CENTER OFF	TS	TAMPER SWITCH
$OS	CEILING SWITCH; FLUSH; X = ANY TYPE LISTED ABOVE	FS	FLOW SWITCH
PC	SWITCH; PHOTOELECTRIC	PS	PRESSURE SWITCH
OS	SWITCH; OCCUPANCY SENSOR	MI	MAGNETIC DOOR HOLD OPEN TIED INTO FIRE ALARM SYSTEM
		FACP	FIRE ALARM CONTROL PANEL

GENERAL NOTES:
1. ALL LIGHT FIXTURES AND EQUIPMENT PROVIDED BY THE ELECTRICAL CONTRACTOR SHALL INCLUDE ALL REQUISITE LAMPS AND BALLASTS.
2. SOLID FILL DENOTES FIXTURE PROVIDED WITH ONE LAMP EMERGENCY BACK UP BALLAST. SEE ELECTRICAL LIGHTING PLANS FOR TYPE AND COUNT.

LIGHT FIXTURE SCHEDULE

TAG	DESCRIPTION	MANUFACTURER	LAMPS	LOCATION	MOUNTING	MOUNTING HEIGHT	VOLTS	GFCI	OFCI
A	2' X 2' FLUORESCENT 9 CELL PARABOLIC	DAY-BRITE #2LP3GS3331U633AL-120	3-31WU6-SP35	NEW MEETING ROOM #01, ADDITION TO CHILDREN'S #05	LAY-IN		120		
A2	2' X 2' FLUORESCENT 9 CELL PARABOLIC WITH 1400 LUMEN EMERGENCY BATTERY INVERTER ON CENTER LAMP OF FIXTURE	DAY-BRITE #2LP3GS3331U633AL-120-1/3 GEB-CHLORIDE C1400	3-31WU6-SP35	NEW MEETING ROOM #01, ADDITION TO CHILDREN'S #05	LAY-IN		120		
B	2' X 4' FLUORESCENT 18 CELL PARABOLIC	DAY-BRITE #2LP3GS332136AL-120-1/3	3-F32WT8-SP35	MEETING ROOM STORAGE #08, NEW WORK ROOM #07, NEW OFFICE #06, EMPLOYEE BREAKROOM #04	LAY-IN		120		
B2	2' X 4' FLUORESCENT 18 CELL PARABOLIC WITH 1400 LUMEN EMERGENCY BATTERY INVERTER ON CENTER LAMP OF FIXTURE	DAY-BRITE #2LP3GS332136AL-120-1/3 GEB-CHLORIDE C1400	2-U316T8-SP35	NEW STUDY ROOM 1 #02, NEW STUDY ROOM 2 #03, NEW STUDY ROOM 3 #04, NEW STUDY ROOM 4 #10, NEW STUDY ROOM 5 #11	LAY-IN		120		
X	BACK WALL MOUNTED LED EXIT FIXTURE WITH (2) 10 WATT EMERGENCY EGRESS HEADS	MCPHILBEN #CCHX201RW	2-10W MR16	NEW MEETING ROOM #01	WALL	2" ABOVE DOOR	120		
Y	EMERGENCY EGRESS LIGHT FIXTURE	MCPHILEN #CTX9L2-NWCSWF	2-12W HALOGEN (INCLUDED)	NEW WORKROOM #07, EMPLOYEE BREAKROOM #04	WALL		120		

LIGHTING CLASS PANELBOARD 'LA' — 42,000 AIC
MAIN LUGS — 225 AMP BUS — MOUNTING: SURFACE
120/208 V, 3 PHASE, 4 WIRE