



KEY NOTES	
1	PROVIDE FOUR (4) 2" CONDUIT WITH PULLSTRINGS TO NEAREST EXISTING IT ROOM.
2	ATTIC VENTILATOR CONNECTION LOCATED ABOVE CEILING IN ATTIC. PROVIDE CIRCUITING AS INDICATED AND TOGGLE DISCONNECT SWITCH AT UNIT.

Order Plans @

A POWER PLAN - AREA A
 E2.0 SCALE: 1/8" = 1'-0"

ARCHITECT
 TIMOTHY
 KURMASKIE
 AIA, NCARB

1030 Washington St
 Raleigh, NC 27605
 Phone: 919-846-1600
 Fax: 919-846-9404
 ARCHITECT@TKST.COM

THE DRAWINGS AND DESIGN SHOWN ARE THE PROPERTY OF ARCHITECT TIMOTHY KURMASKIE, AIA, NCARB. THE REPRODUCTION OR USE OF THIS PROPERTY WITHOUT THE WRITTEN CONSENT FROM THE ARCHITECT IS PROHIBITED AND ANY INFRINGEMENT OF THESE RIGHTS IS SUBJECT TO LEGAL ACTION.
 COPYRIGHT 2019
 ARCHITECT TIMOTHY KURMASKIE, AIA, NCARB



DSA
 ENGINEERING

DAVID SIMS &
 ASSOCIATES, P.C.
 CONSULTING ENGINEERS
 ARBORETUM CENTRE
 108 GILES AVE., SUITE 100
 WILMINGTON, NC 28403
 910.791.8016
 www.dsaepp.com

ALTERATION & ADDITION TO:
PruittHealth
Savannah
 12825 WHITE BLUFF ROAD
 SAVANNAH, GA 31419

Project Reference Numbers
 Architect's Project No. 180017

Drawn By:

REVISIONS	
1	6/11/20 FLOOR PLAN CHANGES

DATES	
PHASE	ISSUED
PERMIT SET	05/22/19

POWER PLAN
 AREA A
 SHEET NUMBER

E2.0