

Special Inspection General Notes

SPECIAL INSPECTIONS

- SI.1 ALL SPECIAL INSPECTIONS SHALL BE PERFORMED IN CONFORMANCE WITH THE APPLICABLE INTERNATIONAL BUILDING CODE AND ITS REFERENCED SPECIFICATIONS.
- SI.2 THE SPECIAL INSPECTOR SHALL BE EMPLOYED BY THE OWNER OR THE OWNER'S AGENT AND NOT BY THE CONTRACTOR OR SUBCONTRACTOR WHOSE WORK IS TO BE INSPECTED OR TESTED. ANY CONFLICT OF INTEREST MUST BE DISCLOSED TO THE BUILDING OFFICIAL PRIOR TO COMMENCING WORK.
- SI.3 THE SPECIAL INSPECTOR SHALL BE QUALIFIED PER THE INTERNATIONAL BUILDING CODE AND SHALL BE EDUCATED IN THE TASKS REQUIRED TO CONDUCT, SUPERVISE, AND EVALUATE THE INSPECTIONS. THE SPECIAL INSPECTOR MUST ALSO BE OBJECTIVE, COMPETENT, AND HAVE ACCESS TO THE APPROPRIATE TESTING EQUIPMENT WHICH SHALL BE MAINTAINED AND PERIODICALLY CALIBRATED. THE QUALIFICATIONS OF THE SPECIAL INSPECTOR MAY BE SUBJECT TO THE APPROVAL OF THE BUILDING OFFICIAL.
- SI.4 SPECIAL INSPECTION AGENTS:
1. APPROVED TESTING AGENCY
 2. GEOTECHNICAL ENGINEER OF RECORD: TBD
FIRM
STREET ADDRESS
CITY, STATE, AND ZIP
- EOR: ENGINEER OF RECORD:
LBYD INC.
880 MONTCLAIR ROAD, SUITE 600
BIRMINGHAM, AL 35213
- SI.5 THE SPECIAL INSPECTIONS SHALL BE PERFORMED IN ADDITION TO ANY OBSERVATIONS PERFORMED BY THE ENGINEER OF RECORD AND ANY INSPECTIONS PERFORMED BY THE BUILDING OFFICIAL.
- SI.6 THE SPECIAL INSPECTOR SHALL MAINTAIN RECORDS AND PROVIDE THE REQUIRED DOCUMENTATION AS PRESCRIBED IN THE INTERNATIONAL BUILDING CODE, INCLUDING THE SUBMITTAL OF REPORTS TO THE BUILDING OFFICIAL AND THE DESIGNER OF RECORD.
- SI.7 THE CONTRACTOR SHALL COORDINATE THE CONSTRUCTION SCHEDULE WITH THE SPECIAL INSPECTOR TO ALLOW FOR SPECIAL INSPECTIONS.
- SI.8 CONSTRUCTION WHICH REQUIRES SPECIAL INSPECTIONS SHALL BE MAINTAINED IN SUCH A STATE AS TO ALLOW ACCESS FOR THE SPECIAL INSPECTOR UNTIL THE REQUIRED INSPECTIONS OR TESTS HAVE BEEN COMPLETED.
- SI.9 ANY DEVIATIONS FOUND DURING THE SPECIAL INSPECTION PROCESS SHALL IMMEDIATELY BE BROUGHT TO THE ATTENTION OF THE DESIGNER OF RECORD. ALL DEVIATIONS MUST BE ADDRESSED PRIOR TO COMPLETION OF THE WORK.
- SI.10 INSPECTION FREQUENCY:
- A. CONTINUOUS – SPECIAL INSPECTION BY THE SPECIAL INSPECTOR WHO IS PRESENT WHEN AND WHERE THE WORK TO BE INSPECTED IS BEING PERFORMED.
 - B. PERIODIC – SPECIAL INSPECTION BY THE SPECIAL INSPECTOR WHO IS INTERMITTENTLY PRESENT WHERE THE WORK TO BE INSPECTED HAS BEEN OR IS BEING PERFORMED.
 - C. OBSERVE – OBSERVE ITEMS ON A RANDOM BASIS. OPERATIONS NEED NOT BE DELAYED PENDING THESE INSPECTIONS.
 - D. PERFORM – PERFORM TASKS FOR EACH JOINT, MEMBER, AND CONNECTION
- SI.11 SPECIAL INSPECTIONS FOR STRUCTURAL, LOAD-BEARING, OR LATERAL LOAD BEARING FABRICATED ITEMS SHALL BE PERFORMED FOR THE FABRICATED ITEMS AT THE FABRICATOR'S SHOP. SPECIAL INSPECTIONS FOR FABRICATED ITEMS MAY BE WAIVED WHEN THE FABRICATOR IS REGISTERED AND HAS APPROVAL TO PERFORM THE WORK WITHOUT SPECIAL INSPECTIONS. IF THE INSPECTIONS ARE WAIVED, THE FABRICATOR MUST SUBMIT A CERTIFICATE OF COMPLIANCE TO THE BUILDING OFFICIAL SHOWING COMPLIANCE WITH THE APPROVED STRUCTURAL DRAWINGS.
- SI.12 LATERAL SYSTEM NOTES
- A. THE MAIN WIND FORCE RESISTING SYSTEM SUBJECT TO SPECIAL INSPECTIONS IS COMPRISED OF:
 1. ROOF DIAPHRAGM: **WOOD SHEATHING**
 2. FLOOR DIAPHRAGM: **N/A**
 3. COLLIER ELEMENTS/DIAG STRUTS: **WOOD TRUSSES**
 4. LATERAL FORCE RESISTING SYSTEM: **LIGHT-GAGE METAL STUD WALLS WITH WOOD PANEL SHEATHING**

Order Plans @

Structural Steel

NO.	INSPECTION TASK	FREQUENCY	REFERENCE FOR CRITERIA	AGENT
1.00	INSPECTOR SHALL BE ON THE PREMISES FOR INSPECTION DURING THE PLACEMENT OF ANCHOR RODS AND OTHER EMBEDMENTS SUPPORTING STRUCTURAL STEEL		AISC 360 SEC. N5.7	ATA
1.01	DIAMETER, GRADE, TYPE, LENGTH, AND EMBEDMENT DEPTH OF ANCHOR RODS AND OTHER EMBEDDED ITEMS	PERFORM		ATA
1.02	INSPECT THE FABRICATED STEEL OR ERECTED STEEL FRAME, AS APPROPRIATE, TO VERIFY COMPLIANCE WITH THE DETAILS SHOWN, SUCH AS BRACES, STIFFENERS, MEMBER LOCATIONS AND PROPER APPLICATION OF JOINT DETAILS AT EACH CONNECTION.	PERFORM		ATA
2.00	INSPECTION TASKS PRIOR TO WELDING:		AISC 360 SEC. N5.4	
2.01	WELDING PROCEDURE SPECIFICATIONS (WPS) AVAILABLE	PERFORM		ATA
2.02	MANUFACTURER CERTIFICATIONS FOR WELDING CONSUMABLES AVAILABLE	PERFORM		ATA
2.03	MATERIAL IDENTIFICATION (TYPE/GRADE)	OBSERVE		ATA
2.04	WELDER IDENTIFICATION SYSTEM (a)	OBSERVE		ATA
2.05	FIT-UP OF GROOVE WELDS (INCLUDING JOINT GEOMETRY), JOINT PREPARATION, DIMENSIONS (ALIGNMENT, ROOT OPENING, ROOT FACE, BEVEL), CLEANLINESS (CONDITION OF STEEL SURFACES), TACKING (TACK WELD QUALITY AND LOCATION), AND BACKING TYPE AND FIT (IF APPLICABLE)	OBSERVE		ATA
2.06	CHECK WELDING EQUIPMENT	OBSERVE		ATA
3.00	INSPECTION TASKS DURING WELDING:		AISC 360 SEC. N5.4	
3.01	USE OF QUALIFIED WELDERS	OBSERVE		ATA
3.02	CONTROL AND HANDLING OF WELDING CONSUMABLE PACKAGING AND EXPOSURE CONTROL	OBSERVE		ATA
3.03	NO WELDING OVER CRACKED TACK WELDS	OBSERVE		ATA
3.04	ENVIRONMENTAL CONDITIONS INCLUDING WIND SPEED WITHIN LIMITS, PRECIPITATION, AND TEMPERATURE	OBSERVE		ATA
3.05	WPS FOLLOWED INCLUDING SETTINGS ON WELDING EQUIPMENT, TRAVEL SPEED, SELECTED WELDING MATERIALS, SHIELDING GAS TYPE/FLOW RATE, PREHEAT APPLIED, INTERPASS TEMPERATURE MAINTAINED (MIN/MAX), AND PROPER POSITION (F, V, H, OH)	OBSERVE		ATA
3.06	WELDING TECHNIQUES INCLUDING: INTERPASS AND FINAL CLEANING, EACH PASS WITHIN PROFILE LIMITATIONS, EACH PASS MEETS QUALITY REQUIREMENTS	OBSERVE		ATA
4.00	INSPECTION TASKS AFTER WELDING:		AISC 360 SEC. N5.4	
4.01	WELDS CLEANED	OBSERVE		ATA
4.02	SIZE, LENGTH, AND LOCATION OF WELDS	PERFORM		ATA
4.03	WELDS MEET VISUAL ACCEPTANCE CRITERIA FOR: CRACK PROHIBITION, WELD/BASE-METAL FUSION, CRATER CROSS SECTION, WELD PROFILES, WELD SIZE, UNDERCUT, AND POROSITY	PERFORM		ATA
4.04	ARC STRIKES	PERFORM		ATA
4.05	REPAIR ACTIVITIES	PERFORM		ATA
5.00	INSPECTION TASKS PRIOR TO BOLTING:		AISC 360 SEC. N5.6	
5.01	MANUFACTURER'S CERTIFICATIONS AVAILABLE FOR FASTENER MATERIALS	PERFORM		ATA
5.02	FASTENERS MARKED IN ACCORDANCE WITH ASTM REQUIREMENTS	OBSERVE		ATA
5.03	PROPER FASTENERS SELECTED FOR THE JOINT DETAIL (GRADE, TYPE, BOLT LENGTH IF THREADS ARE TO BE EXCLUDED FROM SHEAR PLANE)	OBSERVE		ATA
5.04	PROPER BOLTING PROCEDURE SELECTED FOR JOINT DETAIL	OBSERVE		ATA
5.05	CONNECTING ELEMENTS, INCLUDING THE APPROPRIATE FAYING SURFACE CONDITION AND HOLE PREPARATION, IF SPECIFIED, MEET APPLICABLE REQUIREMENTS	OBSERVE		ATA
5.06	PRE-INSTALLATION VERIFICATION TESTING BY INSTALLATION PERSONNEL OBSERVED AND DOCUMENTED FOR FASTENER ASSEMBLIES AND METHODS USED	OBSERVE		ATA
5.07	PROPER STORAGE PROVIDED FOR BOLTS, NUTS, WASHERS AND OTHER FASTENER COMPONENTS	OBSERVE		ATA
6.00	INSPECTION TASKS DURING BOLTING:		AISC 360 SEC. N5.6	
6.01	FASTENER ASSEMBLIES, OF SUITABLE CONDITION, PLACED IN ALL HOLES AND WASHERS (IF REQUIRED) ARE POSITIONED AS REQUIRED	OBSERVE		ATA
6.02	JOINT BROUGHT TO THE SNUG-TIGHT CONDITION PRIOR TO THE PRETENSIONING OPERATION	OBSERVE		ATA
6.03	FASTENER COMPONENT NOT TURNED BY THE WRENCH PREVENTED FROM ROTATING	OBSERVE		ATA
6.04	FASTENERS ARE PRETENSIONED IN ACCORDANCE WITH THE RCSC SPECIFICATION, PROGRESSING SYSTEMATICALLY FROM THE MOST RIGID POINT TOWARD THE FREE EDGES	OBSERVE		ATA
7.00	INSPECTION TASKS AFTER BOLTING:		AISC 360 SEC. N5.6	
7.01	DOCUMENT ACCEPTANCE OR REJECTION OF BOLTED CONNECTIONS	PERFORM		ATA
NOTES:	(a) THE FABRICATOR OR ERECTOR, AS APPLICABLE, SHALL MAINTAIN A SYSTEM BY WHICH A WELDER WHO HAS WELDED A JOINT OR MEMBER CAN BE IDENTIFIED. STAMPS, IF USED, SHALL BE THE LOW-STRESS TYPE.			
	(b) WHEN WELDING OF DOUBLER PLATES, CONTINUITY PLATES OR STIFFENERS HAS BEEN PERFORMED IN THE K-AREA, VISUALLY INSPECT THE WEB K-AREA FOR CRACKS WITHIN 3 IN. (75MM) OF THE WELD.			

Soils

NO.	INSPECTION TASK	FREQUENCY	REFERENCE FOR CRITERIA	AGENT
1.00	VERIFY MATERIALS BELOW SHALLOW FOUNDATIONS ARE ADEQUATE TO ACHIEVE THE DESIGN BEARING CAPACITY.	PERIODIC		GEOR
2.00	VERIFY EXCAVATIONS ARE EXTENDED TO PROPER DEPTH AND HAVE REACHED PROPER MATERIAL.	PERIODIC		GEOR
3.00	PERFORM CLASSIFICATION AND TESTING OF COMPACTED FILL MATERIALS.	PERIODIC		GEOR
4.00	VERIFY USE OF PROPER MATERIALS, DENSITIES AND LIFT THICKNESSES DURING PLACEMENT, AND COMPACTION OF COMPACTED FILL.	CONTINUOUS		GEOR
5.00	PRIOR TO PLACEMENT OF COMPACTED FILL, INSPECT SUBGRADE AND VERIFY THAT SITE HAS BEEN PREPARED PROPERLY.	PERIODIC		GEOR



Shendon Huckestein architects, PC
architecture . planning . interior design
2126 Morris Avenue
Birmingham, AL 35203
Phone (205) 322-1731
Fax (205) 322-1778
email info@shplusha.com
www.hplusha.com

A New Branch Bank for
Tyndall
FEDERAL CREDIT UNION
Dothan, Alabama

RELEASES / DESCRIPTION / DATES

NOT FOR CONSTRUCTION
RELEASED FOR CONSTRUCTION

DATE 06.23.2020
DRAWN GVA
CHECKED WAW
APPROVED ROW

PROJECT NUMBER 20012.01

SHEET TITLE
SPECIAL INSPECTIONS

DRAWING NO.