

REFER TO SHEETS E0.3 & E0.4 FOR CAR WASH EQUIPMENT INFORMATION.

EQUIPMENT I.D. TAG (TYPICAL) X-X
 PANEL & CKT. # (TYPICAL) MCC-


NORTH

 FLOOR PLAN EQUIPMENT - ELECTRICAL
 SCALE: 1/4" = 1' - 0"


- GENERAL NOTES:
1. PROVIDE DEDICATED NEUTRAL WITH ALL 120V BRANCH CIRCUITS.
 2. EQUIPMENT IS BASED ON EQUIPMENT INFORMATION PROVIDED AT THE TIME OF DESIGN. CONTRACTOR SHALL VERIFY FINAL EQUIPMENT SELECTIONS AND REQUIREMENTS (INCLUDING ROUGH-IN LOCATIONS, ELEVATIONS, CONNECTION REQUIREMENTS, DISCONNECT REQUIREMENTS, ETC.) AND LAYOUT INFORMATION AT ROUGH-IN; NOTIFY ENGINEER OF ANY DISCREPANCIES.
 3. SEE VENDOR SHOP DRAWINGS FOR LOW-VOLTAGE DEVICE/WIRING REQUIREMENTS, ADDITIONAL EQUIPMENT ROUGH-IN REQUIREMENTS, AND DETAILS.

ARD PROJECT #0052
 APPLIED RESEARCH AND DESIGN, INC.
 2623 S. BLAIRSTONE ROAD
 TALLAHASSEE, FL 32301
 FL CA#8948
 JAMES M. LAMB, PE#52688
 Tel: (850) 668-6324 -- E-mail: jlamb@ard-eng.com

CONN + ARCHITECTS
 Tallahassee, Florida 32308 | 850-878-8784
 www.connarchitects.com | Lic. No. AA-C001662

DATE	APRIL 28, 2020
DRAWN BY	MRC/JML
REVISED	
JOB NO.	19-249-1
James M. Lamb	
SHEET NUMBER	E1.3

COPYRIGHT © CONN + ARCHITECTS, INC. ALL RIGHTS RESERVED. PRINTED IN THE UNITED STATES OF AMERICA. NO PART OF THESE DOCUMENTS MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM, OR TRANSMITTED, IN ANY FORM OR BY ANY MEANS, WITHOUT THE PRIOR WRITTEN PERMISSION OF CONN + ARCHITECTS, INC.