

PANEL & CIRCUITS BY G.C. ELECTRICIAN

PANEL SCHEDULE									
VOLTS: 120/208		PHASE: 3		WIRE: 4		MARK CW		MAINS:	
CKT No.	DEVICE AMP TRIP POLES	DESCRIPTION	CONN. LOAD OA	(WATTS) OC	DEM %	DEM WATTS	COND	WIRE	
2	20 1	TUNNEL LIGHTING			100				
4	20 1	TUNNEL LIGHTING			100				
6	20 1	VACUUM LIGHTING			100				
8	20 1	VACUUM LIGHTING			100				
10		SPARE			100				
12	15 1	CONTROL_120V (1-A)			100				
14		SPARE			100				
16	15 1	CONTROL_120V (1-DE)			100				
18		SPARE			100				
20	15 1	AIR DRYER (10-L)			100				
22		SPARE			100				
24	10 1	CONTROL BOX (27-C)			100				
26		SPARE			100				
28	20 1	WAIT & GO (30-C)			100				
30		SPARE			100				
32	15 1	CONTROL_120V (32)			100				
34	20 2	UNIMAC (32)			100				
36		SPARE			100				
38		SPARE			100				
40	20 1	MAT MACH. (38)			100				
42		SPARE			100				

CKT No.	DEVICE AMP TRIP POLES	DESCRIPTION	CONN. LOAD OA	(WATTS) OC	DEM %	DEM WATTS	COND	WIRE
1	20 1	E.ROOM LIGHTING			100			
3		SPARE			100			
5	20 1	NEON SIGNS			100			
7	20 1	NEON SIGNS			100			
9		SPARE			100			
11	20 1	PINNACLE ARCH (40-E)			100			
13		SPARE			100			
15	20 1	MASTER COMP.			100			
17	10 1	DIGITAL QUEUE (20)			100			
19	20 1	RELAY BOX (20-1)			100			
21	20 1	POINT OF SALE (20-C)			100			
23	20 1	POINT OF SALE (20-C)			100			
25	20 1	GATE (20-D)			100			
27	20 1	GATE (20-D)			100			
29	10 1	POS CAMERA (20-i)			100			
31	10 1	POS CAMERA (20-i)			100			
33	20 1	MENU SIGN (30-i)			100			
35	20 1	MENU SIGN (30-i)			100			
37		SPARE			100			
39		SPARE			100			
41		SPARE			100			

TOTALS		A.I.C. RATING (VERIFY)		TOTAL CONNECTED _____ WATTS	
		MOUNTING SURFACE		TOTAL DEMAND _____ WATTS	
				TOTAL AMPS _____ AMPS	

PANEL & CIRCUITS BY G.C. ELECTRICIAN

PANEL SCHEDULE									
VOLTS: 277/480		PHASE: 3		WIRE: 4		MARK CW		MAINS:	
CKT No.	DEVICE AMP TRIP POLES	DESCRIPTION	CONN. LOAD OA	(WATTS) OC	DEM %	DEM WATTS	COND	WIRE	
2	15 3	RECLAIM UNIT (1-A)			100				
4					100				
6					100				
8		SPARE			100				
10	15 3	RO UNIT (1-D)			100				
12					100				
14					100				
16		SPARE			100				
18	15 3	RO REPRESSURIZER (1-E)			100				
20					100				
22					100				

CKT No.	DEVICE AMP TRIP POLES	DESCRIPTION	CONN. LOAD OA	(WATTS) OC	DEM %	DEM WATTS	COND	WIRE
1	25 3	COMPRESSOR.10HP (10-A)			100			
3					100			
5					100			
7		SPARE			100			
9	25 3	COMPRESSOR.10HP (10-A)			100			
11					100			
13					100			
15		SPARE			100			
17		SPARE			100			
19		SPARE			100			
21		SPARE			100			

TOTALS		A.I.C. RATING (VERIFY)		TOTAL CONNECTED _____ WATTS	
		MOUNTING SURFACE		TOTAL DEMAND _____ WATTS	
				TOTAL AMPS _____ AMPS	

NOT FOR CONSTRUCTION UNTIL APPROVED BELOW.
 APPROVED BY: _____ DATE: _____

DISCLAIMER
 ALTHOUGH BUILDING CODES HAVE BEEN CONSIDERED IN DEVELOPING THIS DRAWING, VERIFICATION OF SITE SPECIFIC CONDITIONS AND COMPLIANCE WITH FEDERAL, STATE AND LOCAL BUILDING CODES IS THE EXCLUSIVE RESPONSIBILITY OF THE CUSTOMER AND/OR ARCHITECT AND ENGINEER. THESE DRAWINGS REFLECT REQUIREMENTS FOR SONNY'S FURNISHED EQUIPMENT ONLY UNLESS OTHERWISE NOTED. PLEASE REFER TO OTHER MANUFACTURERS, IF ANY, FOR THEIR EQUIPMENT REQUIREMENTS.


CONFIDENTIAL WARNING:
 THIS SHEET CONTAINS AND CONSTITUTES CONFIDENTIAL INFORMATION, IMAGES AND TRADE SECRETS OF SONNY'S ENTERPRISES INC. ANY UNAUTHORIZED USE OR DISCLOSURE OF ANY OR PORTION THEREOF, IS STRICTLY PROHIBITED. THIS WORK IS THE EXCLUSIVE PROPERTY OF SONNY'S ENTERPRISES INC. ALL RIGHTS RESERVED.

19581-D9-CALIBER LAKE WALES

SCALE: N.T.S. LOCATION: -FL-

Sheet 9.5 Rev. --

DATE: 09.25.19 REVISION DATE: 03.06.20
 CREATED BY: LV REVISED BY: FAO CHECKED BY: Luis V.



http://www.SonnysDirect.com

5605 Hiatus Road, Tamarac, FL. 33321 USA. TEL. 800-327-8723

ELECTRICAL PANEL; GC SCHEMATIC

© 2020 SONNY'S ENTERPRISES, INC.