



GENERAL NOTES:

1. LIGHT FIXTURES INDICATED SHALL BE RE-USED ALL OTHER FIXTURES SHALL BE REMOVED BY G.C. SEE SHEET E004 FOR NEW LIGHTING PLAN.
2. CONTRACTOR TO SURVEY ALL ELECTRICAL CIRCUITS AND OUTLETS PRIOR TO RE-CIRCUITING. CIRCUITS WITH EXISTING DEVICES TO REMAIN SHALL BE LEFT IN PLACE. USE SPARE CIRCUITS OR SPACES IN PANELBOARD FOR NEW CIRCUITS. BALANCE LOADS IN PANELBOARD AS NECESSARY.
3. CONTRACTOR SHALL SURVEY PANELBOARDS AND TEST CIRCUITS ACCORDINGLY. DISCONNECT CIRCUITS FOR EQUIPMENT TO BE REMOVED AFTER EQUIPMENT REMOVAL.
4. EXISTING CIRCUITS TO REMAIN SHALL BE TESTED AND WIRING REPLACED IF NECESSARY.
5. CONTRACTOR SHALL REMOVE ALL UNUSED CONDUIT, WIRING, FIXTURES, ETC. AND DISCARD OFFSITE. ABANDONED ITEMS LEFT ABOVE CEILING/ONSITE SHALL NOT BE ACCEPTABLE.

DEMOLITION LIGHTING NOTES

1. ALL LIGHTING FIXTURES AND COMMUNICATION DEVICES THAT ARE EXISTING TO REMAIN ARE SHOWN LIGHT, SOLID. ALL LIGHTING FIXTURES AND COMMUNICATION DEVICES TO BE REMOVED ARE SHOWN HEAVY, DASHED.
2. REMOVE EXISTING LIGHTING FIXTURE AND ALL ASSOCIATED WIRING BACK TO SOURCE.
3. REMOVE EXISTING LIGHT SWITCH AND ALL ASSOCIATED WIRING BACK TO SOURCE.
4. REMOVE EXISTING EMERGENCY EXIT SIGN AND ALL ASSOCIATED WIRING BACK TO SOURCE.
5. REMOVE EXISTING EMERGENCY EGRESS LIGHT FIXTURE AND ALL ASSOCIATED WIRING BACK TO SOURCE.
6. REMOVE EXISTING PANELBOARD. SEE SHEET 91.01, FOR ADDITIONAL INFORMATION.
7. EXISTING PANELBOARD TO REMAIN. SEE SHEET 91.01, FOR ADDITIONAL INFORMATION.
8. EXISTING EXTERIOR LIGHT TO REMAIN.
9. EXISTING JUNCTION BOX FOR EXTERIOR SIGNAGE TO REMAIN AND BE USED FOR FUTURE VERIZON SIGNAGE. SEE SHEET 92.01 FOR ADDITIONAL INFORMATION. COORDINATE WITH VZ PROJECT MANAGER.
10. NOTE: ALL CONDUIT AND CABLE SHALL BE REMOVED IN ITS ENTIRETY AND THAT EXPOSED CEILING IN NEW WORK PHASE SHALL BE FREE AND CLEAR OF ALL VISIBLE CABLE AND CONDUIT. EXISTING CONDUIT/CABLE SERVING ADJACENT TENANT SPACES SHALL BE DISCONNECTED FROM THEIR SOURCE AND REROUTED CONCEALED ALONG EXISTING JOISTS/BEAMS, AS NOT VISIBLE FROM BELOW. COORDINATE RECONNECTION/EXTENSION OF NEW WIRING WITH ADJACENT TENANTS. COORDINATE EXTENT OF NEW TENANT WIRING/CABLING WITH VERIZON REPRESENTATIVE IN THE FIELD.

100 DEMOLITION LIGHTING PLAN
SCALE: 1/4" = 1'-0"

Order Plans @

WWW.LDILLING.COM



NO.	REVISION	DATE
FILE	20013J	
DRAWN	CBH	06/19/2020
ISSUED		

SHEET TITLE
Demolition Lighting Plan

SHEET NUMBER

91.01

