DRAWING NOTES

1. EXISTING PAD MOUNTED UTILITY TRANSFORMER 1000KVA, 20kV PRIMARY - 277/480V SECONDARY.
2. EXISTING SERVICE ENTRANCE SWITCHBOARD MSA. UTILITY PROVIDED 12 MONTH PEAK kW - 213kW. TOTAL LOAD REQUIRED = ((213/0.8) kVA x 1.25) = 332.24kVA = 372.05kVA.
3. PROVIDE A NEW 70A/3P CIRCUIT BREAKER IN EXISTING OPEN SPACE ON EXISTING MAIN SWITCHBOARD. MATCH EXISTING CIRCUIT BREAKER CHARACTERISTICS INCLUDING MANUFACTURER, TYPE AND KAIC RATING. MANUFACTURE IS "EATON-CUTLER-HAMMER POW_R_LINE C SWITCHBOARD", TYPE IS "HFD", 65KAIC.



1 **DETAIL - ONE-LINE DIAGRAM**
SCALE: N.T.S.

Order Plans @ WWW.LDILine.com

ISS	100% CD SET	01/06/2020

VANDERLYN ELEMENTARY SCHOOL
GYM HVAC DESIGN
1877 Vanderlyn Drive
Dunwoody, Georgia 30338

STANLEY LOVE-STANLEY P.C.
ARCHITECTURE
INTERIORS PLANNING
PROGRAM MANAGEMENT
1090 SPRING STREET, N.W.
ATLANTA, GEORGIA 30309-3910
404-876-9000 tel
404-876-9001 fax
www.stanleylove-stanleypc.com

DRAWING TITLE
ELECTRICAL ONE-LINE DIAGRAM

PROFESSIONAL SEAL
GEORGIA REGISTERED No. PE037830 PROFESSIONAL ENGINEER JEFFREY ANN CRUTCHFIELD

CONSULTANT

SCALES AS STATED HEREON ARE VALID ON THE ORIGINAL DRAWING. THE DIMENSIONS OF WHICH ARE SHOWN IN INCHES. THE SCALES NOTED HEREON ARE MERELY GIVEN BY THE RATIO OF THE ORIGINAL DRAWING AND MAY NOT BE CORRESPONDING OF THE PRINT TO CORRESPONDING DIMENSIONS OF THE ORIGINAL DRAWING.

THIS DRAWING IS THE PROPERTY OF STANLEY, LOVE-STANLEY, P.C. AND MAY NOT BE REPRODUCED OR COPIED IN WHOLE OR IN PART. IT IS ONLY TO BE USED FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREIN AND IS NOT TO BE USED ON ANY OTHER PROJECT. IT IS TO BE RETURNED UPON REQUEST.

COPYRIGHT © 2015 - ALL RIGHTS RESERVED
STANLEY, LOVE-STANLEY, P.C.

DRAWING NO.

DATE
01/06/2020
PROJECT NO.
6919.8
DRAWING NO.
E-501

RELEASED FOR CONSTRUCTION 01/06/2020