

6" CONCRETE PAD

NOTE:

1. SIZE PAD 6" LARGER ALL AROUND TO SUIT EQUIPMENT FURNISHED

1 DETAIL - CONCRETE PAD
SCALE: N.T.S.



FULL RADIUS ELBOWS WHERE POSSIBLE (R = W)



MITERED ELBOWS

DUCT OFFSETS



(BRANCH FLOW LESS THAN 25% OF MAIN FLOW)



(BRANCH FLOW GREATER THAN 25% OF MAIN FLOW)

BRANCH TAKE OFFS



RADIUS ELBOW



RECTANGULAR ELBOW

LOW VELOCITY ELBOWS



DIVERGING FLOW



CONVERGING FLOW

RECTANGULAR TO RECTANGULAR TRANSITIONS

2 DETAIL - RECTANGULAR DUCT FITTINGS
SCALE: N.T.S.



NOTES

1. REFER TO MANUFACTURER'S WRITTEN INSTRUCTIONS FOR PIPE SIZES AND TRAP CONFIGURATION.

3 DETAIL - COIL CONDENSATE DEEP SEAL TRAP (PAD)
SCALE: N.T.S.



4 DETAIL - ROUND DUCT JOINT
SCALE: N.T.S.



5 DETAIL - SINGLE ROW SUSPENSION - FABRIC DUCT
SCALE: N.T.S.



6 DETAIL - FABRIC DUCT INTERNAL SUPPORT
SCALE: N.T.S.



NOTES:

1. PROVIDE GALVANIZED SHEET METAL SLEEVES FOR DUCTWORK PASSING THROUGH ALL FULL HEIGHT WALLS, FIRE RATED PARTITIONS OR SMOKE PARTITIONS. DUCT SLEEVES SHALL BE LARGE ENOUGH TO PASS DUCT WITH INSULATION AND SHALL HAVE 2 (TWO) INCH FLANGES RETURNED AGAINST WALL OR PARTITION. WHERE FIRE DAMPERS ARE REQUIRED, PROVIDE SLEEVES AS REQUIRED BY THE DAMPER MANUFACTURER.
2. AT ALL SLEEVES, WHERE NOISE CAN BE TRANSMITTED AND AT FIRE RATED SEPARATIONS, SEAL ALL OPENINGS BETWEEN DUCTS AND CORRESPONDING SLEEVE TO PREVENT SOUND TRANSMISSION AND MAINTAIN FIRE RATING OF THE WALL. SUBMIT METHOD OF SEALING SLEEVES FOR APPROVAL. U.L. ASSEMBLY RATING OF FIRE WALLS SHALL BE MAINTAINED AT ALL TIMES. ALL SLEEVES INSTALLED IN METAL PANEL CONSTRUCTION SHALL BE GROUTED IN PLACE.

7 DETAIL - ACOUSTICAL DUCTWORK PENETRATION
SCALE: N.T.S.



INSTALLED AT ZIPPER LOCATION AT INLET OR AS SPECIFIED IN OTHER LOCATIONS. ZIPPER TO ZIPPER CONNECTION AS SHOWN. EXTERNAL LABEL IDENTIFIES LOCATION.

8 DETAIL - ADJUSTABLE FLOW DEVICE
SCALE: N.T.S.



9 DETAIL - INLET ATTACHMENT
SCALE: N.T.S.



NOTES

1. COORDINATE EXTERIOR DUCT STRUCTURAL SUPPORTS WITH MANUFACTURER DUCT CONNECTION HEIGHTS. PROVIDE SUPPORTS EVERY 4'-0" OF HORIZONTAL RUN.

10 DETAIL - EXTERIOR DUCTWORK SUPPORTS
SCALE: N.T.S.

Order Plans @ WWW.LDILine.com

CD	100% CD SET	01/31/2020

WADSWORTH MAGNET SCHOOL
GYM HVAC DESIGN
3039 Santa Monica Drive
Decatur, Georgia 30032

STANLEY LOVE-STANLEY P.C.
ARCHITECTURE
INTERIORS PLANNING
PROGRAM MANAGEMENT
1996 SPRING STREET, N.W.
ATLANTA, GEORGIA 30309-3810
404-876-3366
404-876-8641 fax
www.stanleylove-stanleypc.com

DRAWING TITLE
MECHANICAL DETAILS

PROFESSIONAL SEAL
GEORGIA REGISTERED NO. PE PERSON EXPIRATION DATE ENGINEER DANIEL NOTO

CONSULTANT
rmr Engineering
910 HAMMOND DRIVE SUITE 725
ATLANTA, GA 30328 678 916 9309

SCALES AS STATED HEREON ARE VALID ON THE ORIGINAL DRAWING. THE DIMENSIONS OF THE PRINT MAY VARY FROM SCALES AS NOTED HEREON ARE HEREBY CHANGE BY THE RATIO OF THE OVERALL SHEET DIMENSIONS OF THE PRINT TO CORRESPONDING DIMENSIONS OF THE ORIGINAL DRAWING.
THE DRAWING IS THE PROPERTY OF STANLEY, LOVE-STANLEY, P.C. AND IS NOT TO BE REPRODUCED OR COPIED IN WHOLE OR IN PART. IT IS ONLY TO BE USED FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREIN AND IS NOT TO BE USED ON ANY OTHER PROJECT. IT IS TO BE RETURNED UPON REQUEST.
COPYRIGHT © 2019 - ALL RIGHTS RESERVED STANLEY, LOVE-STANLEY, P.C.

DRAWING NO.

DATE
01/31/2020
PROJECT NO.
6919.6
DRAWING NO.
M-401

RELEASED FOR CONSTRUCTION 01/31/2020