

FIRE ALARM LEGEND

SYMBOL	DEVICES	SUPPLIED BY	INSTALLED BY	CONDUCTOR
FACP	FIRE ALARM PANEL-INSTALLED 5'-0" AFF CS-3000	F/A CONT	F/A CONT	
PS	POWER SUPPLY 24 VDC 5A FIRE LITE PS-1245B	F/A CONT	F/A CONT	
CC	CELLULAR COMMUNICATOR TELEWIRE TD-IFS	F/A CONT	F/A CONT	
KP	KEYSET LCD ANNUNCIATOR KEY PAD. MOUNT TOP @ 4'-0" A.F.F. FIRE-LITE: AM-60	F/A CONT	F/A CONT	4#18AWG FPL
BACS	BURGLAR ALARM CONTROL PANEL DSC POWER 832 W/ 4 ZONE EXPANDER WITH LOCAL 7Ah BATTERY	F/A CONT	F/A CONT	4#18AWG FPL
HD	HEAT DET. - 9 @ 50 @ 57-87 A.F.F. LOCATE AS REQUIRED BY LOCAL AUTHORITY	F/A CONT	F/A CONT	2#18 FPL
J-BOX	JUNCTION BOX - 12"L (5")L x 4" MOUNTED AT CEILING 10'-0" A.F.F.)	ELECTRICAL	ELECTRICAL	
H	HORN/ LED PLT W/ FIRE INSTALL IN L WALL @ 7'-0 A.F.F., BENCH SIGNS	F/A CONT	F/A CONT	4#18 FPL 2#18 FPL
SSO	OUTDOOR AUXILIARY SIREN - AMSECO "SSO-12" INSTALL IN 4" SQ. BOX	F/A CONT	F/A CONT	2#14 FPL
SD	SURFACE MTD. DUCT DETECTOR W/ DUCT SMOKE PROBE	F/A CONT	F/A CONT	2#14AWG FPL
F/S SD/AM	STROBE/SMOKE DETECTOR - MOUNT @ 80" A.F.F. W/ SMOKE HEAD AT 96"	F/A CONT	F/A CONT	2#14AWG FPL
S	FIRE ALARM HORN/STROBE-WALL INSTALLED @ 80" A.F.F. W/ CANDELA WALL BRACKET	F/A CONT	F/A CONT	2#14AWG FPL
F/S CEIL	FIRE ALARM HORN/STROBE-CEILING MOUNTED @ 96" A.F.F. W/ CANDELA WALL BRACKET	F/A CONT	F/A CONT	2#14AWG FPL
S	FIRE ALARM STROBE-WALL MOUNTED @ 80" A.F.F. W/ CANDELA WALL BRACKET	F/A CONT	F/A CONT	2#14AWG FPL
S	FIRE ALARM STROBE-WALL MOUNTED @ 96" A.F.F. W/ CANDELA WALL BRACKET	F/A CONT	F/A CONT	2#14AWG FPL
S	FIRE ALARM STROBE-CEILING MOUNTED @ 96" A.F.F. W/ CANDELA WALL BRACKET	F/A CONT	F/A CONT	2#14AWG FPL
M	DUCT SMOKE DETECTOR CONNECT BY FLEXIBLE CONDUIT TO J-BOX 1-MOD 4SQ4" W/ SAMPLING TUBE TYPE LITE 1135BPA	F/A CONT	MECHANICAL	2#18 FPL
T	RETURN MOUNTED PHOTO ELECTRIC SMOKE DETECTOR FIRE LITE 1135BD	F/A CONT	F/A CONT	2#18 FPL
MR	MINI-REMOTE ANNUNCIATOR	F/A CONT	F/A CONT	2#18 FPL

SYMBOL	DEVICES	SUPPLIED BY	INSTALLED BY	CONDUCTOR
	ANSUL SYSTEM CAP 1320SS DUAL CSM1407S	MECHANICAL	MECHANICAL	2#18 FPL
	FIRE ALARM MANUAL PULL STATION INSTALLED @ 48" TO 54" SINGLE GANG "N-BOX" MOUNT BOX TO A/F.F. FIRE-LITE: NBG-12LSKSP2 "RED BOX"	F/A CONT	F/A CONT	2#18 FPL
	CEILING MOUNTED MIST OF MONITORED ADDRESSABLE INTERFACE FIRE-LITE: I-ADB	F/A CONT	F/A CONT	2#18 FPL
	SAFE-T-SOFE CONTACT INSTALLED IN 4" SQ BOX, MC-HOSE	F/A CONT	F/A CONT	2#18 FPL
	WELL-O DOOR CONTACT INSTALL IN 4" SQ X 2 1/2" DEEP JUNCTION BOX OR HOSE	F/A CONT	F/A CONT	2#18 FPL
	DIRECTIONAL INFRARED DETECTOR SENTRICON II, SMD, MTD @ 9'-0" A.F.F. 1000SQ. FEET/SD	F/A CONT	F/A CONT	4#18 FPL
	MAP INFRARED DETECTOR SENTRICON II, SMALL GANG MOUNT 1000SQ/FT	F/A CONT	F/A CONT	4#18 FPL
	ADDRESSABLE RELAY MODULE CAT. "DOR"-320	F/A CONT	F/A CONT	
	GLASS BREAK SENSOR - SINGLE GANG MTD AT CEILING HONEYWELL #1985DST	F/A CONT	F/A CONT	4#22 FPL
	REMOTE TEST STATION - BUTTON WITH 1" LED & PLASTER RING TP-8"-A.F.F.3 ON SEL. MTG. TO	F/A CONT	F/A CONT	4#14 FPL
	FLOW SWITCH-CONNECTED BY FLEXIBLE CONDUIT FROM 4" SQ. BOX. MODULE MAP-300	SPRINKLER	SPRINKLER	2#18 FPL
	FARMER PROOF SWITCH-CONNECTED BY FLEXIBLE CONDUIT FROM 4" SQ. BOX. MODULE MAP-300	SPRINKLER	SPRINKLER	2#18 FPL
PS	PRESSURE SWITCH-CONNECTED BY FLEXIBLE CONDUIT FROM 4" SQ. BOX. MODULE MAP-300	SPRINKLER	SPRINKLER	2#18 FPL
EOL	END OF LINE RESISTOR	F/A CONT	F/A CONT	
SS	CIRCUIT SURGE SUPPRESSION DEVICE DH-ESCD-FIRE	F/A CONT	F/A CONT	2#18AWG FPL
M	ADDRESSABLE MONITOR MODULE MONITOR MODULE FIRE-LITE: FMM-1	F/A CONT	F/A CONT	2#18AWG FPL

HC - HORN CIRCUIT BBS - BURGLARY BOOSTER
SH - SHIELDED SMP - SMOKE DETECTOR PANEL

MINIMUM FIRE ALARM AND SECURITY ALARM PERFORMANCE SPECIFICATIONS

GENERAL:

- THE PURPOSE OF THIS DRAWING IS TO ASSIST PROVIDE ELECTRICAL CONTRACTOR WITH A MINIMUM LEVEL AND QUALITY SYSTEM THAT REPRESENTS A LAYOUT DESIGN SUPPLIED AND ASSIGNED BY THE FIRE/SECURITY ALARM CONSULTANT IN ORDER TO ACCURATELY PREPARE A BID PACKAGE AND TO PERMIT THE FIRE/SECURITY ENGINEER WITH CERTAIN DESIGN CRITERIA.
- THE FIRE ALARM MANUFACTURER'S REPRESENTATIVE (FARR) SHALL SUBMIT SHOP DRAWINGS OF A FIRE/ALARM AND SECURITY BURGLAR SYSTEM, SIGNED AND SEALED BY AN ELECTRICAL ENGINEER LICENSED IN THE STATE WHERE THIS PROJECT IS TO BE BUILT. THE SUBMITTED DESIGN SHALL ACCOMMODATE THE LAYOUT AND APPEARANCE OF THE SYSTEM COMPONENTS BUT MAY ALTERNATE OR ADD DEVICES AND/OR CIRCUITRY AND/OR OTHER COMPONENTS AS NECESSARY TO MEET OTHER CRITERIA.
- SUBMIT DATA SHEETS FOR ALL COMPONENTS REQUIRED BY THE DESIGN SHALL BE SUBMITTED.
- THE SUBMITTAL SHALL BE PROVIDED TO THE OWNER, GENERAL CONTRACTOR, AND ELECTRICAL CONTRACTOR FOR REVIEW/APPROVAL.
- IF REQUIRED BY THE AUTHORITY HAVING JURISDICTION (AHJ), COMPLETE PLANS AND CALCULATIONS SHALL BE SUBMITTED TO THE AUTHORITY FOR APPROVAL.
- IF REQUIRED BY THE OWNER OR IF ANY RECEPTACLE OR OUTLETS ARE REQUIRED TO BE MODIFIED FROM WHAT IS INDICATED ON THE DRAWINGS, ANY OR ALL INFORMATION, INCLUDING RELATED CALCULATIONS, SHALL BE SUBMITTED TO THE ENGINEER OF RECORD FOR REVIEW AND APPROVAL.
- NON-COMPLIANCE WITH THE FIRE ALARM SYSTEM SHALL COMPLY WITH FEDERAL AND/OR STATE ADA REQUIREMENTS. DEPARTURES FROM PARTICULAR TECHNICAL AND DESIGNS REQUIREMENTS OF APPLICABLE CODES BY THE USE OF OTHER DESIGNS AND TECHNOLOGIES AND PERMITTED WHERE THE ALTERNATIVE DESIGNS AND TECHNOLOGIES PROVIDE EQUIVALENT OR POTENTIALLY EQUIVALENT OR GREATER ACCESS TO AND USABILITY OF THE SPACE.

ALARM REQUIREMENTS:

- THE FIRE ALARM SHALL CONSIST OF A POWER LIMITED, FULLY ADDRESSABLE SYSTEM WITH FULL NOTIFICATION CAPABILITY.
- THE BURGLAR SYSTEM SHALL BE SEPARATE FROM THE FIRE ALARM SYSTEM.

LOCATION AND ACCESSIBILITY:

- SECURITY ALARM DEVICES TO BE INSTALLED AT EACH EXIT/ENTRANCE, CORRIDOR CRUCIS AND ROOF HATCH.
- FIRE ALARM DEVICES TO BE INSTALLED IN COMPLIANCE WITH APPLICABLE CODES ON WALLS IN WORK SPACES AND SUSPENDED FROM CEILING OVER THE SALES FLOOR AREAS. THE MAXIMUM MOUNTING HEIGHT FOR WALL STROBES SHALL BE WITHIN THE SPACE AS THE LUMINAIRE SERVING THE AREA BUT NO HIGHER THAN 28'-0" A.F.F. WITH COVERAGES AS PER NFPA 72, 2013.
- COORD. ALL WALL MTD. DEVICES WITH OTHER TRADES AND EQUIPMENT.
- NOTIFICATION APPLIANCE CIRCUITS (NAC) TO BE CLASS 'B', STYLE 'Y'.
- INTENSITIES OF AUDIBLE AND VISUAL DEVICES SHALL MEET REQUIREMENTS OF NFPA 72 AND SHALL BE NOTED ON THE SHOP DRAWINGS.

TYPES OF ALARMS AND INITIATION DEVICES:

- ALARM TYPES TO MEET THE REQUIREMENTS OF NFPA 72 AND LOCAL ORDINANCES. ALL COMPONENTS TO BE COMPATIBLE, U.L. LISTED AND LABELED FOR THE INTENDED LOCATION OF USE.
- INITIATION DEVICE CIRCUITS (IDC) AND COMPONENTS TO BE CLASS 'B'.
- ALL AIR HANDLING UNITS (AHU'S) SHALL SHUT DOWN UPON ALARM VIA FIRE ALARM CONTROL RELAY.
- SEE FIRE ALARM LEGEND (THIS SHEET) FOR SPECIFIC DEVICE REQUIREMENTS.

NOTIFICATION REQUIREMENTS:

- ALL AUDIBLE AND VISUAL DEVICES TO BE SYNCHRONIZED WITH RESPECTIVE DEVICE TYPE.
- FIRE ALARM AND BURGLAR ALARM SYSTEMS SHALL PROVIDE NOTIFICATION OF ALARM TO CENTRAL MONITORING CENTER (MCT).
- CONTRACTOR SHALL VERIFY THAT INTENSITY LEVELS OF AUDIBLE DEVICES MEET OR EXCEED 75 DB OR LOCAL ORDINANCES FOR NON-DECIBEL LEVELS WHERE PRESENT. PROVIDE ADDITIONAL DEVICES AS REQUIRED.
- SEE FIRE ALARM LEGEND (THIS SHEET) FOR SPECIFIC DEVICE REQUIREMENTS.

INSTALLATION REQUIREMENTS:

- ALL CONDUIT AND J-BOXES (RACEWAY SYSTEMS) TO BE INSTALLED BY LICENSED ELECTRICAL CONTRACTOR.
  - a) ALL WALL MTD. AND CEILING MTD. DEVICES ARE TO CONSIST OF A FLUSH MTD. J-BOX WITH 1"C AWAY TO CEILING OR JOIST SPACE.
  - b) ALL ENTRY POINTS FOR CABLE TO CONDUIT OR J-BOXES SHALL HAVE PROPER BUSHINGS INSTALLED AS REQUIRED BY NFPA 70 (NEC).
  - c) ALL CONDUIT CONNECTIONS SHALL BE PROPERLY SUPPORTED AS REQUIRED BY NFPA 70 (NEC).
  - d) MINIMUM SIZE OF CONDUCTORS IN CONDUIT SYSTEMS SHALL COMPLY WITH NFPA 70 (NEC).
  - e) ENSURE DEVICES SHALL BE LOCATED NEAR FRONT ENTRANCE OF BUILDING. VERIFY EXACT LOCATION AND MOUNTING HEIGHT WITH LOCAL A.H.J.
- ALL FIRE ALARM AND BURGLAR ALARM DEVICES AND WIRING SHALL BE SUPPLIED AND INSTALLED BY LICENSED FIRE ALARM CONTRACTOR (FIRE ALARM MANUFACTURERS REPRESENTATIVE - FARR).
  - a) CONTRACTOR SHALL PERFORM WIRE-WORK (EXPOSED CONDUCTORS PARALLEL OR PERPENDICULAR TO BUILDING LINES).
  - b) ALL EXPOSED CONDUCTORS SHALL BE INSTALLED ONLY AFTER COMPLETION OF PAINTING IN EFFECTED AREA.
  - c) CEILING MTD. WALL SMOKE DETECTORS SHALL BE INSTALLED 3'-0" FROM AIR SUPPLY DIFFUSER AND NOT IN AIR FLOW.
  - d) DUCT MTD. SMOKE DETECTORS SHALL BE INSTALLED BY MECH. CONTRACTOR, AND WIRED BY FIRE ALARM CONTRACTOR.
  - e) ONE FINAL SET OF SHOP DRAWINGS SHALL BE USED FOR HORNS AND HORN STROBES MOUNTED ON COLUMNS OR WINDOWED COMMUNICATION POLES.

BACKUP POWER REQUIREMENTS:

- BATTERY BACKUP, POWER SUPPLY AND VOLTAGE DROP CALCULATIONS SHALL BE INCLUDED ON SHOP DRAWINGS.
- BATTERY BACKUP SHALL COMPLY WITH NFPA REQUIREMENTS OF NFPA 72.

APPLICABLE REGULATORY REQUIREMENTS:

- THE FIRE ALARM AND SECURITY ALARM DESIGN SHALL COMPLY WITH MINIMUM REQUIREMENTS OF NFPA 70 (NEC), NFPA 72, NFPA 70BA, NFPA 101, NFPA, FBC 11-4.26.3 AND FBC 11-4.3 ALL APPLICABLE CODES AND ORDINANCES.

MINIMUM DESIGN DOCUMENT CRITERIA:

- SYSTEM RISER DIAGRAM
- DEVICE TYPES AND LOCATIONS
- TYPES OF CONDUCTORS INCLUDING:
  - a) VOLTAGE DROP CALCULATIONS
  - b) BATTERY BACKUP REQUIREMENTS
  - c) LISTING REQUIREMENTS
- NOTIFICATION REQUIREMENTS
- BACKUP POWER REQUIREMENTS

GENERAL FIRE/SECURITY ALARM NOTES

1. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR THE COMPLETE PERMIT, INSTALLATION, AND PROGRAMMING, OF THE FIRE ALARM AND SECURITY ALARM SYSTEM.
2. INSTALLATION OF THE FIRE ALARM AND SECURITY ALARM SYSTEMS SHALL COMPLY WITH THE INFORMATION IN THESE DRAWINGS AND FIRE ALARM AND SECURITY ALARM SYSTEM SPECIFICATIONS ON DWG. E-7a
3. THE ELECTRICAL CONTRACTOR SHALL OBTAIN ALL BUILDABLE PERMIT PLANS FOR THE PROJECT FROM PUBLIX'S FIRE ALARM AND SECURITY ALARM ENGINEER, TROCEN ENGINEERS, INC. CONTACT DENNIS VANN 813 227 9195.
4. NO SUBSTITUTIONS OF ANY FIRE ALARM OR SECURITY ALARM SYSTEMS IN WHOLE OR PART SHALL BE ALLOWED. ALL DEVICES AND COMPONENTS SHALL BE AS SPECIFIED ON THIS DRAWING AND IN SHOP SUBMITTALS.
5. NO DEVIATION FROM THE DESIGN INDICATED IN THIS DRAWING SHALL BE ALLOWED WITHOUT SUBMITTING IN WRITING A REQUEST FOR REVIEW, APPROVAL AND PLANS REVISION, FROM PUBLIX ENGINEER OF RECORD OR THE FIRE ALARM/SECURITY ALARM ENGINEER OF RECORD.
6. THE FIRE ALARM/SECURITY ALARM CONTRACTOR WILL BE RESPONSIBLE FOR ALL PERMITS, INSPECTIONS, AND ASSOCIATED COSTS NECESSARY FOR A COMPLETE AND OPERATIONAL SYSTEM.
7. THE FIRE ALARM CONTRACTOR SHALL PROVIDE A 11"X17" LAMINATED ZONE MAP ADJACENT TO THE FIRE ALARM KEYPAD AT THE ENTRANCE. THE DRAWING FOR THE ZONE MAP SHALL BE ACQUIRED FROM TROCEN ENGINEERS.
8. ALL BURGLAR ALARM INITIATING DEVICES CONNECT TO A PERPIT.



1 FIRE/BURGLAR ALARM
SCALE: 1/2"=1'-0"

NOTE:

THE JURISDICTION MAY REQUIRE A BI-DIRECTIONAL AMPLIFIER SYSTEM (BDA) BE INSTALLED TO DISTRIBUTE RADIO SIGNALS WITHIN THE BUILDING. UPON COMPLETION OF THE BUILDING INTERIOR WALLS, THE ELECTRICAL CONTRACTOR SHALL RETAIN THE SERVICES OF A QUALIFIED COMMUNICATIONS CONTRACTOR TO PERFORM A STUDY TO DETERMINE THE NECESSITY OF A BDA. A COPY OF THE REPORT SHALL BE SUBMITTED TO THE FIRE DEPARTMENT AND THE ENGINEER OF RECORD NO LATER THAN 60 DAYS PRIOR TO SCHEDULED DATE OF SUBSTANTIAL COMPLETION. THE QUALIFIED COMMUNICATION CONTRACTOR SHALL UTILIZE THE FOLLOWING CONTRACTOR:

- AFL – (813) 299-5750 CONTACT: DAN HENDERSON

ADDITIONALLY, THE ELECTRICAL CONTRACTOR SHALL INCLUDE IN THEIR QUOTE AN ADD ALTERNATE TO PROVIDE THE BDA SYSTEM.

SCALE = 1/8" = 1'-0"

APOLLO ENGINEERING, LLC
CONSULTING ENGINEERS
FE#7005883
6946 U.S. Hwy 41 North, Suite 3900, Apollo Beach, FL 33572
Phone: 813.909.5800 / Fax: 813.908.5905
Job # 12012
Copyright 2020 - All rights reserved.

Order Plans @ WWW.LDINE.com

THE DRAWINGS ARE ALL INSTRUMENTS OF SERVICE PROVIDED BY FISHER AND ASSOCIATES, ARCHITECTS, PLANNERS, INTERIOR DESIGNERS AND ARE THE PROPERTY OF FISHER AND ASSOCIATES, P.A. THEY ARE NOT TO BE USED BY ANY PERSON, FIRM OR CORPORATION FOR ANY PURPOSES WHATSOEVER WITHOUT THE WRITTEN CONSENT OF FISHER AND ASSOCIATES, P.A. AND WITHOUT PAYMENT OF ALL FEES DUE THEREFOR. ALL RIGHTS RESERVED UNDER COMMON LAW, 1980 OR PUBLISHED, ALL RIGHTS RESERVED.

THE WORD 'SET OF DRAWINGS' OR 'SET OF CONSTRUCTION DOCUMENTS' SHALL MEAN ANY COMBINATION OF DRAWINGS, SPECIFICATIONS AND/OR OTHER DOCUMENTS PREPARED BY FISHER AND ASSOCIATES, P.A. AND ITS CONSULTANTS.

PUBLIX PROTOTYPE
BASIS OF DESIGN
20M
EXPANDED
RECEIVED: 09.14.18

CORPORATE OFFICES, FACILITIES DESIGN
BOX 407, LAKELAND, FL 33802
(863) 688-3295
PHYSICAL ADDRESS:
3300 AIRPORT RD., LAKELAND, FL 33811

Publix
SUPER MARKETS

FISHER AND ASSOCIATES, LLC.
ARCHITECTS
PLANNERS
INTERIOR DESIGNERS
ASSOCIATES
2255 BELLEAIR RD. CLEARWATER, FL. 33764 727.443.4456

ELECTRICAL FIRE/BURGLER ALARM DEVICE LAYOUT

EAST COBB PUBLIX - #1745
EAST COBB CROSSING SHOPPING CENTER
ROSEWELL ROAD
MARIETTA, GA. 30062

RELEASED FOR:	
BID	
PERMIT	07/16/20
CONSTR.	

REVISIONS:

HAROLD A SCOTT
GEORGIA P.E. #027906

E-7

Issue Date: 04-01-20
Project No.: 220006