

10 CORNER GUARD DETAIL
3" = 1'-0"



09 PLYWOOD WALL BACKING OVER CMU
1 1/2" = 1'-0"



07 SS WALL OVER FIRE RATED WALL
1 1/2" = 1'-0"

NOTES:
PUTTY PAD MUST BE FIRE RATED IN FIRE RATED PARTITIONS.



NOTES:
1. ELECTRICAL OUTLETS ON OPPOSITE SIDES OF A SOUND-RATED WALL ARE TO BE SPACED TO PROVIDE A MINIMUM OF ONE STUD BETWEEN THE BOXES.
2. THE PUTTY PAD IS TO COMPLETELY SEAL ALL SIDES OF EACH OUTLET BOX.
3. WHERE PARTITIONS ARE SCHEDULED TO BE SOUND RATED PROVIDE ACOUSTICAL PUTTY PAD AT ALL OUTLET LOCATIONS.

06 ACOUSTICAL PUTTY PAD SOUND ATTENUATION IN INTERIOR PARTITION
1 1/2" = 1'-0"



08 PLYWOOD WALL BACKING
1 1/2" = 1'-0"



NOTES:
1. CUT, FOLD, AND TAPE THE FLAPS OF THE VAPOR RETARDER TO THE INSIDE OF THE BARRIER BOX PRIOR TO INSTALLING THE ELECTRICAL OUTLET BOX.
2. SEAL THE SPACE BETWEEN THE ELECTRICAL OUTLET BOX AND THE BARRIER BOX WITH INSULATION.
3. REINFORCE AND SEAL EDGES OF THE BARRIER BOX TO THE VAPOR RETARDER.

05 ONE PIECE BARRIER BOX IN EXTERIOR WALL/ INTERIOR SIDE VAPOR RETARDER
1 1/2" = 1'-0"

REFERENCE:
VERTICAL - 2HR UL DESIGN U497
HORIZONTAL - 2HR UL DESIGN G586



04 HORIZONTAL ENCLOSURE AT DUCTWORK FIRE RATED - 2HR
3" = 1'-0"

NOTE:
HORIZONTAL SHAFT ENCLOSURES IN EXCESS OF 10'-0" WIDE IN ANY DIRECTION, PROVIDE DELEGATED ENGINEERING FOR STUD DESIGN

REFERENCE:
VERTICAL - 2HR UL DESIGN U497
HORIZONTAL - 2HR UL DESIGN G586



03 HORIZONTAL ENCLOSURE AT BOTTOM OF SHAFTS FIRE RATED - 2HR
3" = 1'-0"

NOTE:
HORIZONTAL SHAFT ENCLOSURES IN EXCESS OF 10'-0" WIDE IN ANY DIRECTION, PROVIDE DELEGATED ENGINEERING FOR STUD DESIGN

REFERENCE:
VERTICAL - 2HR UL DESIGN U497
HORIZONTAL - 2HR UL DESIGN G586



02 HORIZONTAL ENCLOSURE AT TOP OF SHAFTS FIRE RATED - 2HR
3" = 1'-0"



01 SECTION THROUGH PARTITION INTERRUPTED BY NON-SPECIFIC OBSTRUCTION
1 1/2" = 1'-0"

© 2020 HKS ARCHITECTS, INC.

Order Plans @ WWW.IDILine.com

PLOT DATE: 5/22/2020 5:18:35 PM TEMPLATE VERSION: 3.0 C.2017.DGD

HKS

ARCHITECT
HKS ARCHITECTS, INC.
#AA 26001119
3500 SALZEDO ST, 4TH FLOOR
CORAL GABLES, FL 33134

STRUCTURAL CONSULTANT
THORNTON TOMASETTI
101 NE THIRD AVE., SUITE 1170
FORT LAUDERDALE, FL 33301-1159

MEP CONSULTANT
THOMPSON EHLE
50 TECHNOLOGY PKWY S. PEACHTREE CORNERS, GA 30092

KITCHEN CONSULTANT
INNOVATIVE FOOD SERVICE
11101 NORTH 46TH STREET, TAMPA, FL 33617

WATERPROOFING CONSULTANT
CDC USA
8070 Park Ln., Suite 400 Dallas, TX 75231

CODE & LIFE SAFETY CONSULTANT
HOWE ENGINEERS
101 LONGWATER CIR. NORWELL, MA 02061

MARRIOTT SAWGRASS CABANA CLUB

619 PONTE VEDRA BLVD
PONTE VEDRA BEACH, FL 32082

OWNER
WATERMARK CAPITAL PARTNERS, LLC
150 NORTH RIVERSIDE PLAZA SUITE 4700
CHICAGO, IL 60606

OWNER'S CONSULTANT
THE JOHN HARDY GROUP INC.
6095 BARFIELD RD. SUITE 200
ATLANTA, GA 30328

CIVIL ENGINEER AND LANDSCAPE CONSULTANT
KIMLEY-HORN
12740 GRAN BAY PARKWAY WEST
SUITE 2350
JACKSONVILLE, FL 32258

INTERIOR DESIGN CONSULTANT
HBA DESIGN
3216 NEBRASKA AVENUE, SANTA MONICA, CALIFORNIA 90404 U. S. A.

STATE OF FLORIDA
JONATHAN G. BORRELL
AR99092
REGISTERED ARCHITECT

JONATHAN G. BORRELL, STATE OF FLORIDA, REGISTERED ARCHITECT, LICENSE NO. AR99092
THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY JONATHAN G. BORRELL, ON 05/22/2020
USING A DIGITAL SIGNATURE.
PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

KEY PLAN



REVISION

NO.	DESCRIPTION	DATE

HKS PROJECT NUMBER
22808.001

DATE
05/22/2020

ISSUE
PERMIT SET

SHEET TITLE
GYP BD DETAILS 01

SHEET NO.
A3.04