

GENERAL ELECTRICAL / COMMUNICATION / SECURITY NOTES

- 01 HFT COMMUNICATIONS CONTRACTOR SHALL PROVIDE & INSTALL ALL CABLE, JACKS, PATCH CORDS, TELEPHONE EQUIPMENT ETC FOR A COMPLETE LOW VOLTAGE COMMUNICATIONS SYSTEM. GC IS RESPONSIBLE FOR COMPLETE SECURITY SYSTEM INSTALLATION. REFER TO VENDOR SCOPE OF WORK SUMMARY ON SHEET A10.0 FOR ANY HFT VENDOR PROVIDED ITEMS.
- 02 THE ELECTRICAL CONTRACTOR SHALL PROVIDE ALL CONDUIT, BOXES, PULL STRINGS, 120V POWER SLEEVES FOR COMMUNICATIONS WIRING & EQUIPMENT. COORDINATE WITH COMMUNICATIONS CONTRACTOR & SEE SYMBOL LEGEND FOR ADDITIONAL DETAILS. THE E.C. SHALL PROVIDE WIRE AND COMPLETELY INSTALL ALL COMPONENTS OF THE SECURITY SYSTEM INCLUDING BUT NOT LIMITED TO COMPONENTS, DEVICES, PANELS, WIRE, CONDUIT, BOXES, AND SYSTEM INTERCONNECTIONS.
- 03 ALL CONDUITS SHALL BE PROVIDED WITH PLASTIC BUSHINGS AT EACH END, PULL STRINGS & BE BONDED TO LOCAL BUILDING STEEL.
- 04 ALL LOW VOLTAGE CABLES SHALL BE PLENUM RATED.
- 05 THE COMMUNICATIONS CONTRACTOR SHALL PROVIDE A COMPLETE DATA COMMUNICATIONS SYSTEM WITH EQUIPMENT, PATCH PANELS, CABLE, JACKS, HOOKS, BOXES, LABELING, TESTING, ETC. ALL EQUIPMENT SHALL BE SUPPLIED & INSTALLED PER CATEGORY 6 (B) AND EIA/TIA INSTALLATION STANDARDS.
- 06 THE COMMUNICATIONS CONTRACTOR SHALL PROVIDE A COMPLETE COMMUNICATIONS SYSTEM LABELING SYSTEM, INCLUDE BUT NOT LIMITED TO: CABLES, JACKS, PATCH PANEL RACKS, ETC. ALL LABELING SHALL COMPLY WITH STANDARDS OF EIA/TIA 606.
- 07 THE COMMUNICATIONS CONTRACTOR SHALL TEST EACH CABLE AFTER INSTALLATION AND TERMINATION TO CERTIFY THAT EACH CABLE COMPLES WITH TRADE CATEGORY 6 STANDARDS. PROVIDE DOCUMENTATION PER HFT REQUIREMENTS.
- 08 SECURITY SYSTEM WIRING SHALL BE HONEYWELL #104501 PLENUM GENESIS 22/4 STRANDED UNSHELOED CABLE.
- 09 EACH SPECIFIED ALARM CONTACT AND EACH SPECIFIED ALARM SENSOR SHOULD BE WIRED IN A CLOCKWISE MANNER TO ITS OWN DESIGNATED ZONE STARTING AT THE MAIN CUSTOMER ENTRANCE / EXIT DOOR CONTACTS.
- 10 EACH SPECIFIED ALARM CONTACT AND EACH SPECIFIED ALARM SENSOR SHOULD BE SPECIFICALLY LABELED ACCORDING TO ITS DESIGNATED CONTACT OR SENSOR NAME, ITS LOCATION WITHIN THE STORE & PROGRAMMED SEPARATELY TO ITS OWN DESIGNATED ZONE.
- 11 THE CONTRACTOR SHOULD NEVER PROGRAM / INSTALL ANY TYPE OF LOCKOUT CODE INTO THE PANEL OR EXPANDER.
- 12 COORDINATE CONDUIT AND/OR JUNCTION BOXES AS REQUIRED FOR SECURITY SYSTEM.
- 13 ALL PRODUCTS SPECIFIED ARE FEATURED IN PRODUCT 1 BROCHURES FROM THE MANUFACTURER.

CONDUITS, LOW VOLTAGE WIRING OR MOUNTING HARDWARE SHALL NOT BE DIRECTLY MOUNTED TO THE ROOF DECK.

SECURITY SYSTEM NOTES

- 51 (1)HONEYWELL ADEMPD0 VISTA - 20P (B) ZONE CONTROL PANEL AND (1) HONEYWELL #4219 ADEMOO VISTA EXPANDER MOUNTED IN THE CASH OFFICE ABOVE CEILING. SECURITY CONTRACTOR TO CLEARLY LABEL SECURITY PANEL.
- 52 (1)HONEYWELL #6160 KEYPAD MOUNTED OUTSIDE OF THE MANAGERS OFFICE WALL. BOTTOM OF KEYPAD SHALL BE 44" AFF.
- 53 (1)HONEYWELL WAVE2 2-TONE BELL (GREEN HORN) ON THE MANAGERS OFFICE WALL FACING THE SALES FLOOR MOUNTED AT 12" AFF.
- 54 (1)HONEYWELL #G125 GLASS BREAK DETECTOR CEILING MOUNTED IN THE MIDDLE OF THE VESTIBULE 5 FEET FROM THE PERIMETER GLASS PANE ENTRANCE/EXIT DOORS. GLASS BREAK DETECTOR SHOULD FACE GLASS PANE.
- 55 (1)HONEYWELL #FG125 GLASS BREAK DETECTOR ALONG THE INTERIOR OF GLASS STOREFRONT 5 FEET FROM GLASS PANE FOR EVERY 25 FEET OF STOREFRONT GLASS. GLASS BREAK DETECTORS SHOULD FACE GLASS PANE.
- 56 (1)WALL MOUNTED BOSCH #SC-POL 1-W180 SERIES TRITECH PIR/MICROWAVE DETECTOR MOUNTED AT 9'-0" AFF FOR 90 LINEAR FOOT OF STOREFRONT GLASS SHOOTING SIDEWAYS ACROSS THE GLASS. NO MOTION DETECTORS IN THE VESTIBULE.
- 57 (1)CEILING MOUNTED 360° BOSCH #058270 PANDORA™ TRITECH DETECTOR AT 12" TO 25" AFF FOR STOREFRONT GLASS IN THE EVENT (S) CANNOT BE WALL MOUNTED.
- 58 (1)WALL MOUNTED BOSCH #SC-CD 1-W150 SERIES TRITECH PIR/MICROWAVE DETECTOR ABOVE VESTIBULE DOOR FRAME FACING SALES FLOOR MOUNTED AT 9'-0" AFF.
- 59 (1)CEILING MOUNTED 360° BOSCH #058270 PANDORA™ TRITECH DETECTOR IN THE CENTER OF THE CASH OFFICE AWAY FROM ANY AFR DEVICES.
- 60 (1)WALL MOUNTED BOSCH #05880 SERIES TRITECH PIR/MICROWAVE DETECTOR ABOVE ALL EGRESS DOOR FRAMES (EXCEPT IF EGRESS DOOR IS ADJACENT TO RELIEFING OVERHEAD DOOR) AT 9'-0" AFF.
- 61 MAIN CUSTOMER ENTRANCE / EXIT DOORS FOR NEW DORMA DOORS, WIRE INTO THE DOOR FRAME HEADER TO POINT OF CONNECTION TERMINAL STRIP.
- 62 (1) NASCOM 1200AJUST DOOR CONTACT FOR EXIT DOORS AND ROOF HATCH (IF APPLICABLE). (2) DOOR CONTACTS REQUIRED AT DOUBLE DOORS.
- 63 (1) HONEYWELL #936 DOOR CONTACT FOR OVERHEAD DOOR.
- 64 (1) CEILING MOUNTED 300° BOSCH #058370 PANDORA™ TRITECH DETECTOR IN THE CENTER OF THE RECEIVING AREA MOUNTED AT 15" TO 25" AFF. (NO OTHERS NEEDED IN SALES REPLACEMENT).

GENERAL ELECTRICAL DEMOLITION NOTES

- 1) NO ATTEMPT HAS BEEN MADE TO INDICATE ALL EXISTING ELECTRICAL DEVICES, LIGHT FIXTURES, COMMUNICATION DEVICES, WIRES, CONDUIT, ETC. TO BE REMOVED AND/OR RELOCATED. HOWEVER, THE ELECTRICAL CONTRACTOR SHALL FIELD VERIFY THE EXTENT OF DEMOLITION PRIOR TO SUBMITTING BID.
- 2) REMOVE AND/OR RELOCATE EXISTING DEVICES ON WALLS OR CEILING BEING REMOVED. COORDINATE SUCH CONDITIONS WITH ARCHITECTURAL DRAWINGS.
- 3) ALL UNUSED WIRE (POWER & COMMUNICATION) SHALL BE REMOVED.
- 4) ALL EXISTING WIRING (POWER & COMMUNICATION) THAT IS TO REMAIN SHALL BE REWORKED OR REPLACED WITH CODE COMPLIANT MATERIAL & SUPPORTS. ANY EXISTING SURFACE MOUNTED CONDUITS SHALL BE REMOVED OR RELOCATED SO THAT THEY ARE IN THE JOIST SPACE OR WITHIN WALL CAVITIES.

ELECTRICAL KEY NOTES

- E1 4"x6"x3/4" PAINTED FIRE RATED PLYWOOD FOR TELEPHONE BACKBOARD. REFER TO DETAIL ON SHEET E2.2 FOR MORE DETAILS.
- E2 1/2" EMT CONDUIT FROM 9' AFF TO JOIST SPACE HORIZONAL CONTINUOUS CONDUIT TO TELEPHONE DEMARK. (COORDINATE LOCATION WITH LANDLORD). STUB CONDUIT AT 9' AFF TO TELEPHONE DEMARK.
- E3 12"x4"x1/2" COPPER BUS BAR MOUNTED AT 84" AFF U.O.N. ON INSULATORS. PROVIDE BUS WITH (8) ELECTRICALLY SPACED 3/8" DIAMETER HOLES. CONNECT BARS TO HFT'S MAIN PANELS GROUND BAR THROUGH WIRING CONDUIT.
- E4 4" DIAMETER EMT CONDUIT RISER FROM JOIST SPACE INTO TELEPHONE CABINET.
- E5 2 COMPARTMENT POWER POLE.
- E6 NOTE NOT USED.
- E7 20A 120 VOLT DUPLEX RECEPTACLE AT 1' SPACE FROM TELEPHONE CAMERA MONITOR. COORDINATE EXACT LOCATION WITH COMMUNICATIONS CONTRACTOR. MOUNT FLUSH IN CEILING WHERE CEILING OCCUR. RECEPTACLE SHALL BE WHITE WITH WHITE COVER PLATE. COORDINATE EXACT LOCATION WITH SECURITY VENDOR.
- E8 PROVIDE 2 GANG BOX WITH 1/2" CONDUIT & PULL STRING TO JOIST SPACE.
- E9 (3) 1/2" CONDUIT & PULL STRING FROM TOP OF SECURITY PANEL TO JOIST SPACE.
- E10 1/2" CONDUIT WITH TELEPHONE FROM AMPLIFIER TO JOIST SPACE.
- E11 CONDUIT TO BE USED BETWEEN BACKBOARD & EXISTING TELEPHONE CABINET.
- E12 NOTE NOT USED.
- E13 FLUSH SINGLE GANG BOX MOUNTED AT 48" AFF WITH 3/4" EMT CONDUIT STUB TO CEILING JOIST.
- E14 FLUSH SINGLE GANG BOX MOUNTED AT 114" AFF AT VESTIBULE AND AT 96" AT ALL OTHER LOCATIONS WITH 3/4" EMT CONDUIT TO JOIST SPACE FOR MOTION SENSOR.
- E15 3/4" CONDUIT STUBBED INTO DOOR FRAME FOR DOOR CONTACT.
- E16 PROVIDE 3/4" EMT CONDUIT DROP FROM JOIST & SINGLE GANG BOX MOUNTED AT 12'-0" FOR SALES REPLACEMENT MOTION SENSOR.
- E17 PROVIDE 2 GANG BOX AT 4' AFF. WITH 3/4" CONDUIT STUB TO JOIST SPACE FOR OVERHEAD DOOR CONTACT.
- E18 PROVIDE OCTAGONAL BOX ON BOTTOM OF JOIST.

COMMUNICATIONS KEY NOTES

- C1 25 PAIR CAT3 24AWG TWISTED PAIR CABLE. TERMINATE AT TELEPHONE DEMARK AS DIRECTED BY TELEPHONE COMPANY. TERMINATE AT HFT PHONE BOARD ON 68 PUNCH DOWN BLOCK.
- C2 (3) 4 PAIR CAT 6 24AWG CABLES BETWEEN HFT PHONE BOARD & RACK. TERMINATE ON BOTH ENDS.
- C3 24"x48"x87/8" FLOOR MOUNTED LOCKABLE RACK PER HFT STANDARDS.
- C4 (2) 4 PAIR CAT 6 24AWG DATA CABLE BETWEEN REGISTERS & HFT RACK. TERMINATE ON BOTH ENDS.
- C5 (1) 4 PAIR CAT 6 24AWG CABLE BETWEEN REGISTER & HFT RACK FOR TELEPHONE. TERMINATE ON BOTH ENDS.
- C6 HFT VENDOR SHALL PROVIDE, WIRE & INSTALL SALES AREA SPEAKERS.
- C7 HFT VENDOR SHALL PROVIDE, WIRE & INSTALL SALES REPLACEMENT AREA SPEAKERS.
- C8 (1) 4 PAIR CAT 6 24AWG CABLE BETWEEN DOOR DOOR & HFT RACK FOR TELEPHONE. TERMINATE ON BOTH ENDS.
- C9 SECURITY CAMERA & (1) CAT 6 24AWG 4 PAIR CABLE FROM CAMERA TO RACK. TERMINATE CABLES AT BOTH ENDS. VERIFY EXACT LOCATION OF CAMERAS WITH CCTV VENDOR PRIOR TO HOUGH IN.
- C10 (1) CAT 6 24AWG CABLE FROM TRAFFIC COUNTER TO HFT RACK. TERMINATE AT BOTH ENDS.
- C11 (1) CAT 6 24AWG CABLE FROM WIRELESS ACCESS POINT TO HFT RACK. TERMINATE AT BOTH ENDS.
- C12 (1) CAT 6 24AWG 4 PAIR CABLE FROM TIME CLOCK (CENTERED BETWEEN WINDOW & DOOR) TO HFT RACK. TERMINATE AT BOTH ENDS.
- C13 (2) CAT 6 24AWG 4 PAIR CABLES FROM FRONT/BACK TO HFT RACK. TERMINATE AT BOTH ENDS.
- C14 (2) CAT 6 24AWG 4 PAIR CABLES FROM MANAGERS WORK STATION TO HFT RACK. TERMINATE AT BOTH ENDS.
- C15 (2) CAT 6 24AWG 4 PAIR CABLES FROM MANAGERS WALL TO HFT RACK. TERMINATE AT BOTH ENDS.
- C16 NOTE NOT USED.
- C17 (1) R359 COAXIAL CABLE FROM CCTV MONITOR TO RACK. TERMINATE AT BOTH ENDS.
- C18 (1) CAT 6 24AWG 4 PAIR CABLE FROM CASH ROOM TO HFT RACK. TERMINATE AT BOTH ENDS.
- C19 (1) RJ30X PHONE JACK MOUNTED AT 1'-0" AFF FOR SECURITY PANEL.
- C20 (1) RJ30X PHONE JACK & 4 PAIR CAT 6 24AWG CABLE BETWEEN PHONE BOARD & HFT RACK FOR FIRE ALARM PANEL. TERMINATE ON BOTH ENDS. (TO BE PROVIDED WHEN FIRE ALARM SYSTEM IS TO BE INSTALLED).

COMMUNICATIONS SYMBOL LEGEND

SYMBOL	DESCRIPTION
	SECURITY CAMERA
	DOOR CONTACT
	GLASS BREAK DETECTOR
	CEILING MOUNTED 360° DETECTOR
	WALL MOUNTED MOTION DETECTOR
	POWER POLE
	SPEAKERS
	WIRELESS ACCESS POINT
	DATA CABLE
	SPEAKERS & AMPLIFIER

DO NOT SCALE THESE DRAWINGS



ARCHITECTS, INC.
17710 Detroit Avenue, Lakewood, Ohio 44107
Phone (216) 521-5134 Fax (216) 521-1824
www.adaarchitects.com

HARBOR FREIGHT TOOLS

705 WYATT ROAD NORTHWEST CLEVELAND, TN 37312

This document (instrument of service) was prepared by ADA Architects, Inc. ("ADA") specifically for the referenced project and is not intended for any other use. ADA makes no warranty, express or implied, for the use of this document for any other project or for any other purpose. In addition, the use of this document for any other project or for any other purpose without ADA's prior written consent. Any unauthorized use of this instrument of service shall be at the user's sole risk and without liability to ADA. ADA makes no warranty, express or implied, of merchantability or of fitness for a particular purpose.

REVISIONS	
#	DATE
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	

COMMUNICATIONS PLAN
DATE 06/02/20
JOB NO. 19155
E1.2A
SHEET NO.

Order Plans @ www.LDILLINE.com