DIFFUSERS, GRILLES AND REGISTERS

MARK	SERVICE	LOCATION	CEILING TYPE	MANUFAC.	CATALOG NUMBER	REMARKS
D-1	SUPPLY	CEILING	AC TILE	TITUS	TMSA X 24X24 3 26 D-75	SEE PLAN FOR NECK SIZE
D-2	SUPPLY	CEILING	GYP. BD.	TITUS	TMSA X 12X12 1 26 D-75	SEE PLAN FOR NECK SIZE
G-1	RETURN	CEILING	AC TILE	TITUS	50F X X 3 26 B	SEE PLAN FOR SIZE

ALTERNATE MANUFACTURERS: CARNES, METAL-AIRE, KRUEGER, NAILOR, OR E.H. PRICE

EXHAUST FANS

MARK	LOCATION	SERVICE	CFM	EXT. S.P. (IN W.G.)	SONES	MOTOR DATA				RPM	MFR.	REMARKS
						HP.	VOLTS	PH	CYC.			
EF-1	ROOF	TOILETS	200	0.50	6.6	1/20	115	1	60	1,550	GREENHECK	G-085-[illegible]2,3,4]

NOTES:
1. PROVIDE SOLID STATE SPEED CONTROL.
2. PROVIDE MOTORIZED BACKDRAFT DAMPER.
3. PROVIDE MINIMUM 14" HEIGHT ROOF CURB.
4. INTERLOCK WITH EACH TOILET ROOM LIGHT SWITCH. REFERENCE ELECTRICAL SHEET.



1 TYP. DIFFUSER OR GRILLE CONNECTION
NOT TO SCALE



2 TYPICAL ROUND DUCT FITTINGS
NOT TO SCALE



3 ROOF EXHAUST FAN DETAIL
NOT TO SCALE

Order Plans @ WWW.LDILinc.com

PROJECT COORDINATOR

idGROUP
2641 IRVING BLVD.
DALLAS, TEXAS 75207
TEL: 214-638-6800

SEAL

CONSULTING ENGINEER

Schnackel engineers
New York - Omaha - Los Angeles - Seattle - Honolulu
800-581-0963 www.schnackel.com

ARCHITECTURAL PROJECT NO.: 80-7922
MEP PROJECT NO.: 200183
STRUCTURAL PROJECT NO.: ---
CIVIL PROJECT NO.: ---

FedEx Office SM

JOHNSON CITY, TN
N ROAN RD
2116 N ROAN ST, SUITE 1A
JOHNSON CITY, TN 37601

CENTER NO.: 0531 SITE ID NO.: LX779947 PROGRAM: RTSZ

STIPULATION FOR REUSE

THIS DRAWING WAS PREPARED FOR USE ON A SPECIFIC SITE
JOHNSON CITY, TX 37601

CONTEMPORANEOUSLY WITH ITS ISSUE DATE
08/07/2020

AND IT IS NOT SUITABLE FOR USE ON A DIFFERENT PROJECT
A LATER TIME. USE OF THIS DRAWING FOR REFERENCE ON
ON ANOTHER PROJECT REQUIRES THE SERVICES OF PROPER
LICENSED ARCHITECTS and ENGINEERS. REPRODUCTION OF THIS
DRAWING FOR REUSE ON ANOTHER PROJECT IS NOT AUTHORIZ
IS CONTRARY TO THE LAW. THESE DRAWINGS AND SPECIFICAT
ARE THE PROPERTY OF FEDEX OFFICE INC. AND SHALL NOT B
DISPLAYED IN ANY MANNER OR USED ON ANY OTHER WORK E
WRITTEN AGREEMENT WITH FEDEX OFFICE. WRITTEN DIMENSION
TAKE PREFERENCE OVER SCALED DIMENSIONS AND SHALL BE
ON THE JOB SITE. FEDEX OFFICE IS TO BE NOTIFIED IN WRITI
DISCREPANCIES IN DIMENSIONS PRIOR TO THE CONSTRUCTION
ANY WORK. THESE DRAWINGS ARE INTENDED FOR DESIGN INF
ONLY AND NOT FOR USE IN CONSTRUCTION UNLESS APPROVED
SUCH BY GOVERNING AUTHORITIES.

PERMIT/ BID SET

? 2020 FedEx Office

NO.	REVISIONS:	DATE:
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		

PERMIT SET ISSUE DATE: 08/07/202
BID SET ISSUE DATE: 08/07/202
CONSTRUCTION SET ISSUE DATE: ---

DRAWING TITLE:
H.V.A.C. SCHEDULES AND DETAILS

DRAWING NUMBER:
M-2.0

TEMPLATE (30X42) ISSUE: 10/28/19